

This is a preview - click here to buy the full publication



IEC TR 63127

Edition 1.1 2024-04
CONSOLIDATED VERSION

TECHNICAL REPORT



Guideline for the system design of HVDC converter stations with line-commutated converters

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.240.01; 29.240.10

ISBN 978-2-8322-8767-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	9
3 Terms and definitions	9
4 Symbols	10
4.1 Letter symbols for variables	10
4.2 Subscripts.....	11
5 Overview of HVDC system design	11
5.1 General.....	11
5.2 Formulation of system design	13
5.2.1 HVDC system ratings.....	13
5.2.2 HVDC system configuration	13
5.2.3 Reactive power compensation and control	13
5.2.4 AC/DC interaction and control.....	13
5.2.5 Insulation coordination.....	14
5.2.6 AC/DC harmonic filtering	14
5.2.7 Environmental considerations	14
5.3 System studies and simulations	14
6 Determination of design conditions and requirements	16
6.1 Environmental conditions and requirements	16
6.2 DC transmission line (cable) and earth electrode	17
6.2.1 Parameters of DC overhead transmission line	17
6.2.2 Parameters of DC cable.....	18
6.2.3 Parameters of electrode line and ground electrode	18
6.3 AC system conditions.....	18
6.3.1 Operating scenarios of AC/DC system	18
6.3.2 AC system modelling	18
6.3.3 Relevant AC system protection	19
6.3.4 Reactive power supply and absorption.....	19
6.3.5 Short-circuit current or capacity	20
6.3.6 AC bus voltage	21
6.3.7 AC system frequency.....	21
6.3.8 Pre-existing harmonic and negative sequence voltage	22
6.4 Requirements for HVDC systems arising from AC/DC interaction	22
6.5 AC system equivalents.....	23
6.5.1 General	23
6.5.2 Equivalent for AC/DC system dynamic or transient simulation	23
6.5.3 Impedance equivalent for AC filter design.....	24
6.5.4 System equivalent for low order harmonic resonance study	26
7 Main circuit design.....	26
7.1 Ratings	26
7.1.1 Rated power	26
7.1.2 Rated voltage	27
7.1.3 Rated current.....	28
7.2 Configurations	28

7.2.1	Pole and return path	28
7.2.2	Converter topology	29
7.2.3	DC switchyard configuration	30
7.2.4	Reactive power equipment.....	38
7.3	Determination of main circuit parameters	38
7.3.1	General	38
7.3.2	Control strategy	39
7.3.3	Tolerances and errors.....	40
7.3.4	Determination of converter transformer impedance	40
7.3.5	Relative inductive voltage drop (d_{xN}) and relative resistive voltage drop (d_{rN}).....	40
7.3.6	Ideal no-load DC voltage	41
7.3.7	DC voltage and DC current.....	41
7.3.8	Rated capacity of converter transformer	42
7.3.9	Converter transformer taps.....	43
7.3.10	Inductance of smoothing reactor.....	44
8	Insulation coordination.....	44
9	Filter design	45
9.1	General.....	45
9.2	AC filter design	45
9.3	DC filter design.....	45
9.4	Power line carrier (PLC) filters	46
9.5	Radio frequency interference (RFI)	46
10	Reactive power compensation and control.....	47
10.1	General.....	47
10.2	Reactive power consumption	47
10.2.1	Reactive power consumption calculation.....	47
10.2.2	Maximum reactive power consumption.....	48
10.2.3	Minimum reactive power consumption	48
10.3	Determination of reactive power equipment capacity.....	48
10.3.1	General	48
10.3.2	Capacity of reactive power supply equipment	48
10.3.3	Capacity of reactive power absorption equipment	48
10.3.4	Sizing of reactive power sub-bank	49
10.3.5	Sizing of reactive power bank	49
10.4	Reactive power control	49
10.4.1	General	49
10.4.2	Reactive power exchange control/voltage control	50
10.4.3	Voltage limitation.....	50
10.5	Temporary overvoltage control.....	51
11	Basic parameters of main equipment	51
11.1	General.....	51
11.2	Converter valves.....	51
11.2.1	General	51
11.2.2	Valve hall environment	51
11.2.3	Current rating	52
11.2.4	Voltage rating	52
11.2.5	Losses of converter valves	53
11.2.6	Testing requirements	53

11.3	Converter transformers	53
11.3.1	General	53
11.3.2	Current rating	54
11.3.3	Voltage rating	54
11.3.4	Other rating	54
11.3.5	Rated loss	54
11.3.6	Test requirements.....	55
11.4	Smoothing reactor.....	55
11.4.1	General	55
11.4.2	Current ratings.....	55
11.4.3	Voltage rating	56
11.4.4	Other ratings	56
11.4.5	Losses.....	56
11.4.6	Test requirements.....	56
11.5	Wall bushings	56
11.5.1	General	56
11.5.2	Current rating	56
11.5.3	Voltage rating	56
11.5.4	Testing requirement.....	56
11.6	AC and DC filter equipment.....	57
11.7	PLC filter equipment	57
11.8	Other equipment in DC yard.....	57
Annex A (informative) Typical control, measurement and equipment manufacturing tolerance in HVDC systems		58
Annex B (informative) Technical parameters for equipment specification		59
B.1	Converter valve.....	59
B.2	Converter transformer.....	61
B.3	Smoothing reactor.....	62
Bibliography.....		63
Figure 1 – System design in an HVDC project.....		12
Figure 2 – Example of schematic diagram of AC system frequency variation range.....		22
Figure 3 – Sector diagram of system harmonic impedance.....		25
Figure 4 – Circle diagram of system harmonic impedance.....		25
Figure 5 – Structure of equivalent network for low order harmonic resonance study.....		26
Figure 6 – Converter transformer connection topology		30
Figure 7 – Sketch maps of the DC yard switches of HVDC system.....		33
Figure 8 – Schematic diagram of converter parallel connection		33
Figure 9 – Schematic diagram of pole line parallel connection		34
Figure 10 – Procedure of NBS disconnecting DC fault		34
Figure 11 – Current transfer path of the MRTS.....		35
Figure 12 – Current transfer path of ERTS.....		35
Figure 13 – Connection and function of the NBES.....		36
Figure 14 – Commutating process of NBES in case of DMR.....		36
Figure 15 – High speed bypass switch		37
Figure 16 – Converter paralleling switches.....		37

Table 1 – Studies and simulations in HVDC system design	15
Table 2 – Preferred rated voltages for overhead line HVDC power transmission	27
Table 3 – Preferred rated voltages for submarine HVDC power transmission	28
Table A.1 – Tolerance for main circuit calculation	58
Table A.2 – Control parameters for main circuit calculation	58

INTERNATIONAL ELECTROTECHNICAL COMMISSION

GUIDELINE FOR THE SYSTEM DESIGN OF HVDC CONVERTER STATIONS WITH LINE-COMMUTATED CONVERTERS

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC TR 63127 edition 1.1 contains the first edition (2019-06) [documents 115/195/DTR and 115/203/RVDTR] and its amendment 1 (2024-04) [documents 115/361/DTR and 115/364/RVDTR].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 63127, which is a Technical Report, has been prepared by IEC technical committee 115: High Voltage Direct Current (HVDC) transmission for DC voltages above 100 kV.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The '*colour inside*' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

HVDC is an established technology that has been in commercial use for more than 60 years. With the changes in demands due to evolving environmental needs, installation of HVDC systems has increased dramatically in the last 30 years and ~~almost~~ more than half of HVDC projects were commissioned after the year 2000. HVDC has become a common tool in the design of future global transmission systems.

HVDC systems transmit more electrical power over longer distances than a similar alternating current (AC) transmission system, which means fewer transmission lines are needed, saving both money and land and simplifying permissions. In addition to significantly lowering electrical losses over long distances, HVDC transmission is also very stable and easily controlled, and can stabilize and interconnect AC power networks that are otherwise incompatible. Typically ~~line-commutated converter (LCC)~~ HVDC systems provide unique or superior capabilities in the following aspects:

- long distance bulk power transmission;
- asynchronous interconnections;
- long distance cable;
- controllability;
- lower losses;
- environmental concerns;
- limitation of short-circuit currents.

Simply due to these technical merits, the market demand for HVDC transmission technology is spreading widely over the world. There are many HVDC power transmission systems with a DC voltage from 50 kV up to ~~660~~ 1 100 kV in different countries. ~~In addition, there are several ± 800 kV HVDC power transmission systems which have been built or operated or which are under construction in China, India and Brazil. In 2016, one ± 1 100 kV HVDC power transmission system project was started in China.~~

The fast development of the HVDC power transmission and distribution industry has been accompanied by IEC standardization work. More than 40 IEC documents, from DC equipment to DC systems, have been published. Among these, the IEC TR 60919 series, IEC 60633, IEC 60071-5, the IEC TR 62001 series and the IEC 60700 series provide essential information for the design and operation of HVDC power transmission systems.

However, this document provides only a basic guide and refers to typical numbers and examples. Other points and values may also be valid in particular cases and should also be considered accordingly.

GUIDELINE FOR THE SYSTEM DESIGN OF HVDC CONVERTER STATIONS WITH LINE-COMMUTATED CONVERTERS

1 Scope

System design is the basis of construction and operation of HVDC systems. It defines the overall philosophy for the HVDC transmission system and enables the ratings and specifications for the equipment integrated in the project.

This document focuses on the system design of converter stations. It is applicable to point-to-point and back-to-back HVDC systems based on line-commutated converter (LCC) technology.

This document provides guidance and supporting information on the procedure for system design and the technical issues involved in the system design of HVDC transmission projects for both purchaser and potential suppliers. It can be used as the basis for drafting a procurement specification and as a guide during project implementation.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60633, *High-voltage direct current (HVDC) transmission – Vocabulary*

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	9
3 Terms and definitions	9
4 Symbols	10
4.1 Letter symbols for variables	10
4.2 Subscripts.....	11
5 Overview of HVDC system design	11
5.1 General.....	11
5.2 Formulation of system design	13
5.2.1 HVDC system ratings.....	13
5.2.2 HVDC system configuration	13
5.2.3 Reactive power compensation and control	13
5.2.4 AC/DC interaction and control.....	13
5.2.5 Insulation coordination.....	14
5.2.6 AC/DC harmonic filtering	14
5.2.7 Environmental considerations	14
5.3 System studies and simulations	14
6 Determination of design conditions and requirements	16
6.1 Environmental conditions and requirements	16
6.2 DC transmission line (cable) and earth electrode	17
6.2.1 Parameters of DC overhead transmission line	17
6.2.2 Parameters of DC cable.....	18
6.2.3 Parameters of electrode line and ground electrode	18
6.3 AC system conditions.....	18
6.3.1 Operating scenarios of AC/DC system	18
6.3.2 AC system modelling	18
6.3.3 Relevant AC system protection	19
6.3.4 Reactive power supply and absorption.....	19
6.3.5 Short-circuit current or capacity	20
6.3.6 AC bus voltage	20
6.3.7 AC system frequency.....	21
6.3.8 Pre-existing harmonic and negative sequence voltage	22
6.4 Requirements for HVDC systems arising from AC/DC interaction	22
6.5 AC system equivalents.....	23
6.5.1 General	23
6.5.2 Equivalent for AC/DC system dynamic or transient simulation	23
6.5.3 Impedance equivalent for AC filter design.....	24
6.5.4 System equivalent for low order harmonic resonance study	26
7 Main circuit design.....	26
7.1 Ratings	26
7.1.1 Rated power	26
7.1.2 Rated voltage	27
7.1.3 Rated current.....	28
7.2 Configurations	28

7.2.1	Pole and return path	28
7.2.2	Converter topology	29
7.2.3	DC switchyard configuration	30
7.2.4	Reactive power equipment.....	38
7.3	Determination of main circuit parameters	38
7.3.1	General	38
7.3.2	Control strategy	39
7.3.3	Tolerances and errors.....	40
7.3.4	Determination of converter transformer impedance	40
7.3.5	Relative inductive voltage drop (d_{xN}) and relative resistive voltage drop (d_{rN}).....	40
7.3.6	Ideal no-load DC voltage	41
7.3.7	DC voltage and DC current.....	41
7.3.8	Rated capacity of converter transformer	42
7.3.9	Converter transformer taps.....	43
7.3.10	Inductance of smoothing reactor.....	44
8	Insulation coordination.....	44
9	Filter design	45
9.1	General.....	45
9.2	AC filter design	45
9.3	DC filter design.....	45
9.4	Power line carrier (PLC) filters	46
9.5	Radio frequency interference (RFI)	46
10	Reactive power compensation and control.....	47
10.1	General.....	47
10.2	Reactive power consumption	47
10.2.1	Reactive power consumption calculation.....	47
10.2.2	Maximum reactive power consumption.....	48
10.2.3	Minimum reactive power consumption	48
10.3	Determination of reactive power equipment capacity.....	48
10.3.1	General	48
10.3.2	Capacity of reactive power supply equipment	48
10.3.3	Capacity of reactive power absorption equipment	48
10.3.4	Sizing of reactive power sub-bank	49
10.3.5	Sizing of reactive power bank	49
10.4	Reactive power control	49
10.4.1	General	49
10.4.2	Reactive power exchange control/voltage control	50
10.4.3	Voltage limitation.....	50
10.5	Temporary overvoltage control.....	51
11	Basic parameters of main equipment	51
11.1	General.....	51
11.2	Converter valves.....	51
11.2.1	General	51
11.2.2	Valve hall environment	51
11.2.3	Current rating	52
11.2.4	Voltage rating	52
11.2.5	Losses of converter valves	53
11.2.6	Testing requirements	53

11.3	Converter transformers	53
11.3.1	General	53
11.3.2	Current rating	54
11.3.3	Voltage rating	54
11.3.4	Other rating	54
11.3.5	Rated loss	54
11.3.6	Test requirements.....	55
11.4	Smoothing reactor.....	55
11.4.1	General	55
11.4.2	Current ratings.....	55
11.4.3	Voltage rating	56
11.4.4	Other ratings	56
11.4.5	Losses.....	56
11.4.6	Test requirements.....	56
11.5	Wall bushings	56
11.5.1	General	56
11.5.2	Current rating	56
11.5.3	Voltage rating	56
11.5.4	Testing requirement.....	56
11.6	AC and DC filter equipment.....	57
11.7	PLC filter equipment	57
11.8	Other equipment in DC yard.....	57
Annex A (informative) Typical control, measurement and equipment manufacturing tolerance in HVDC systems		58
Annex B (informative) Technical parameters for equipment specification		59
B.1	Converter valve.....	59
B.2	Converter transformer.....	61
B.3	Smoothing reactor.....	62
Bibliography.....		63
Figure 1 – System design in an HVDC project.....		12
Figure 2 – Example of schematic diagram of AC system frequency variation range.....		22
Figure 3 – Sector diagram of system harmonic impedance.....		25
Figure 4 – Circle diagram of system harmonic impedance.....		25
Figure 5 – Structure of equivalent network for low order harmonic resonance study.....		26
Figure 6 – Converter transformer connection topology		30
Figure 7 – Sketch maps of the DC yard switches of HVDC system.....		33
Figure 8 – Schematic diagram of converter parallel connection		33
Figure 9 – Schematic diagram of pole line parallel connection		34
Figure 10 – Procedure of NBS disconnecting DC fault		34
Figure 11 – Current transfer path of the MRTS.....		35
Figure 12 – Current transfer path of ERTS.....		35
Figure 13 – Connection and function of the NBES.....		36
Figure 14 – Commutating process of NBES in case of DMR.....		36
Figure 15 – High speed bypass switch		37
Figure 16 – Converter paralleling switches.....		37

Table 1 – Studies and simulations in HVDC system design	15
Table 2 – Preferred rated voltages for overhead line HVDC power transmission	27
Table 3 – Preferred rated voltages for submarine HVDC power transmission	28
Table A.1 – Tolerance for main circuit calculation	58
Table A.2 – Control parameters for main circuit calculation	58

INTERNATIONAL ELECTROTECHNICAL COMMISSION

GUIDELINE FOR THE SYSTEM DESIGN OF HVDC CONVERTER STATIONS WITH LINE-COMMUTATED CONVERTERS

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC TR 63127 edition 1.1 contains the first edition (2019-06) [documents 115/195/DTR and 115/203/RVDTR] and its amendment 1 (2024-04) [documents 115/361/DTR and 115/364/RVDTR].

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 63127, which is a Technical Report, has been prepared by IEC technical committee 115: High Voltage Direct Current (HVDC) transmission for DC voltages above 100 kV.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

HVDC is an established technology that has been in commercial use for more than 60 years. With the changes in demands due to evolving environmental needs, installation of HVDC systems has increased dramatically in the last 30 years and more than half of HVDC projects were commissioned after the year 2000. HVDC has become a common tool in the design of future global transmission systems.

HVDC systems transmit more electrical power over longer distances than a similar alternating current (AC) transmission system, which means fewer transmission lines are needed, saving both money and land and simplifying permissions. In addition to significantly lowering electrical losses over long distances, HVDC transmission is also very stable and easily controlled, and can stabilize and interconnect AC power networks that are otherwise incompatible. Typically line-commutated converter (LCC) HVDC systems provide unique or superior capabilities in the following aspects:

- long distance bulk power transmission;
- asynchronous interconnections;
- long distance cable;
- controllability;
- lower losses;
- environmental concerns;
- limitation of short-circuit currents.

Simply due to these technical merits, the market demand for HVDC transmission technology is spreading widely over the world. There are many HVDC power transmission systems with a DC voltage from 50 kV up to 1 100 kV in different countries.

The fast development of the HVDC power transmission and distribution industry has been accompanied by IEC standardization work. More than 40 IEC documents, from DC equipment to DC systems, have been published. Among these, the IEC TR 60919 series, IEC 60633, IEC 60071-5, the IEC TR 62001 series and the IEC 60700 series provide essential information for the design and operation of HVDC power transmission systems.

However, this document provides only a basic guide and refers to typical numbers and examples. Other points and values may also be valid in particular cases and should also be considered accordingly.

GUIDELINE FOR THE SYSTEM DESIGN OF HVDC CONVERTER STATIONS WITH LINE-COMMUTATED CONVERTERS

1 Scope

System design is the basis of construction and operation of HVDC systems. It defines the overall philosophy for the HVDC transmission system and enables the ratings and specifications for the equipment integrated in the project.

This document focuses on the system design of converter stations. It is applicable to point-to-point and back-to-back HVDC systems based on line-commutated converter (LCC) technology.

This document provides guidance and supporting information on the procedure for system design and the technical issues involved in the system design of HVDC transmission projects for both purchaser and potential suppliers. It can be used as the basis for drafting a procurement specification and as a guide during project implementation.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60633, *High-voltage direct current (HVDC) transmission – Vocabulary*