



IEC 61850-7-410

Edition 1.0 2007-08

# INTERNATIONAL STANDARD

**Communication networks and systems for power utility automation –  
Part 7-410: Hydroelectric power plants – Communication for monitoring and  
control**

Withhold

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

PRICE CODE

**XC**

## CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references.....	9
3 Terms and definitions.....	10
4 Abbreviations.....	10
5 Basic concepts for hydropower plant control and supervision.....	11
5.1 Functionality of a hydropower plant.....	11
5.2 Principles for water control in a river system.....	11
5.2.1 General.....	11
5.2.2 Principles for electrical control of a hydropower plant.....	12
5.3 Logical structure of a hydropower plant.....	13
6 Modelling concepts and examples.....	19
6.1 The concept of Logical Devices.....	19
6.2 Logical nodes for sensors, transmitters, supervising and monitoring functions.....	19
6.3 Address strings.....	20
6.4 Naming of logical nodes.....	21
6.5 Recommended naming structure for automatic control functions.....	21
6.6 Summary of logical nodes to be used in hydropower plants.....	22
6.6.1 General.....	22
6.6.2 Group C – Control functions.....	23
6.6.3 Group F – Functional blocks.....	23
6.6.4 Group H – Hydropower specific logical nodes.....	23
6.6.5 Group I – Interface and archiving.....	24
6.6.6 Group K – Mechanical and non-electrical primary equipment.....	25
6.6.7 Group L – Physical devices and common logical nodes.....	25
6.6.8 Group M – Metering and measurement.....	25
6.6.9 Group P – Protection functions.....	25
6.6.10 Group R – Protection related functions.....	26
6.6.11 Group S – Supervision and monitoring.....	26
6.6.12 Group T – Transducers and instrument transformers.....	27
6.6.13 Group X – Switchgear.....	27
6.6.14 Group Y – Power transformers.....	27
6.6.15 Group Z – Power system equipment.....	28
7 Logical Node Classes.....	28
7.1 Abbreviations and definitions used in Logical Node tables.....	28
7.1.1 Interpretation of Logical Node tables.....	28
7.1.2 Abbreviated terms used in Attribute Names.....	29
7.2 Logical Nodes representing functional blocks LN group F.....	30
7.2.1 Modelling remarks.....	30
7.2.2 LN: Counter Name: FCNT.....	30
7.2.3 LN: Curve shape description Name: FCSD.....	30
7.2.4 LN: Generic Filter Name: FFIL.....	31
7.2.5 LN: Control function output limitation Name: FLIM.....	31
7.2.6 LN: PID regulator Name: FPID.....	32

7.2.7	LN: Ramp function Name: FRMP .....	33
7.2.8	LN: Set-point control function Name: FSPT .....	34
7.2.9	LN: Action at over threshold Name: FXOT .....	35
7.2.10	LN: Action at under threshold Name: FXUT .....	35
7.3	Hydropower specific Logical Nodes LN group H .....	36
7.3.1	Modelling remarks .....	36
7.3.2	LN: Turbine – generator shaft bearing Name: HBRG .....	36
7.3.3	LN: Combinator Name: HCOM .....	36
7.3.4	LN: Hydropower dam Name: HDAM .....	37
7.3.5	LN: Dam leakage supervision Name: HDLS .....	37
7.3.6	LN: Gate position indicator Name: HGPI .....	37
7.3.7	LN: Dam gate Name: HGTE .....	38
7.3.8	LN: Intake gate Name: HITG .....	38
7.3.9	LN: Joint control Name: HJCL .....	39
7.3.10	LN: Leakage supervision Name: HLKG .....	40
7.3.11	LN: Water level indicator Name: HLVL .....	40
7.3.12	LN: Mechanical brake Name: HMBR .....	41
7.3.13	LN: Needle control Name: HNDL .....	41
7.3.14	LN: Water net head data Name: HNHD .....	41
7.3.15	LN: Dam over-topping protection Name: HOTP .....	42
7.3.16	LN: Hydropower/water reservoir Name: HRES .....	42
7.3.17	LN: Hydropower unit sequencer Name: HSEQ .....	43
7.3.18	LN: Speed monitoring Name: HSPD .....	43
7.3.19	LN: Hydropower unit Name: HUNT .....	44
7.3.20	LN: Water control Name: HWCL .....	45
7.4	Logical Nodes for interface and archiving LN group I .....	45
7.4.1	Modelling remarks .....	45
7.4.2	LN: Safety alarm function Name: ISAF .....	46
7.5	Logical Nodes for mechanical and non-electric primary equipment LN group K .....	46
7.5.1	Modelling remarks .....	46
7.5.2	LN: Fan Name: KFAN .....	46
7.5.3	LN: Filter Name: KFIL .....	47
7.5.4	LN: Pump Name: KPMP .....	47
7.5.5	LN: Tank Name: KTNK .....	48
7.5.6	LN: Valve control Name: KVLV .....	48
7.6	Logical Nodes for metering and measurement LN group M .....	49
7.6.1	Modelling remarks .....	49
7.6.2	LN: Environmental information Name: MENV .....	49
7.6.3	LN: Hydrological information Name: MHYD .....	49
7.6.4	LN: DC measurement Name: MMDC .....	50
7.6.5	LN: Meteorological information Name: MMET .....	50
7.7	Logical Nodes for protection functions LN group P .....	51
7.7.1	Modelling remarks .....	51
7.7.2	LN: Rotor protection Name: PRTR .....	52
7.7.3	LN: Thyristor protection Name: PTHF .....	52
7.8	Logical nodes for protection related functions LN Group R .....	52
7.8.1	Modelling remarks .....	52
7.8.2	LN: synchronising or synchro-check device Name: RSYN .....	52

7.9	Logical Nodes for supervision and monitoring LN group S .....	54
7.9.1	Modelling remarks .....	54
7.9.2	LN: temperature supervision Name: STMP .....	54
7.9.3	LN: vibration supervision Name: SVBR.....	54
7.10	Logical Nodes for instrument transformers and sensors LN group T .....	55
7.10.1	Modelling remarks .....	55
7.10.2	LN: Angle sensor Name: TANG .....	55
7.10.3	LN: Axial displacement sensor Name: TAXD.....	55
7.10.4	LN: Distance sensor Name: TDST .....	56
7.10.5	LN: Flow sensor Name: TFLW .....	56
7.10.6	LN: Frequency sensor Name: TFRQ .....	56
7.10.7	LN: Humidity sensor Name: THUM .....	57
7.10.8	LN: Level sensor Name: TLEV.....	57
7.10.9	LN: Magnetic field sensor Name: TMGF .....	57
7.10.10	LN: Movement sensor Name: TMVM.....	57
7.10.11	LN: Position indicator Name: TPOS .....	58
7.10.12	LN: Pressure sensor Name: TPRS.....	58
7.10.13	LN: Rotation transmitter Name: TRTN .....	58
7.10.14	LN: Sound pressure sensor Name: TSND .....	59
7.10.15	LN: Temperature sensor Name: TTMP.....	59
7.10.16	LN: Mechanical tension /stress sensor Name: TTNS.....	59
7.10.17	LN: Vibration sensor Name: TVBR.....	60
7.10.18	LN: Water pH sensor Name: TWPH.....	60
7.11	Logical Nodes for power system equipment LN group Z .....	60
7.11.1	Modelling remarks .....	60
7.11.2	LN: Neutral resistor Name: ZRES .....	60
7.11.3	LN: Semiconductor rectifier controller Name: ZSCR.....	61
7.11.4	LN: Synchronous machine Name: ZSMC .....	61
8	Data name semantics.....	63
9	Common data classes .....	76
9.1	General.....	76
9.2	Device ownership and operator (DOO) .....	76
9.3	Maintenance and operational tag (TAG) .....	76
9.4	Operational restriction (RST).....	77
10	Data attribute semantics.....	77
Annex A (informative) Algorithms used in logical nodes for automatic control .....		80
Bibliography.....		86
Figure 1 – Structure of a hydropower plant .....		11
Figure 2 – Principles for the joint control function.....		13
Figure 3 – Water control functions .....		14
Figure 4 – Water flow control of a turbine.....		15
Figure 5 – Typical turbine control system.....		16
Figure 6 – Excitation system.....		17
Figure 7 – Electrical protections of a generating unit.....		18

Figure 8 – Conceptual use of transmitters .....	19
Figure 9 – Logical Device Name .....	20
Figure 10 – Example of naming structure, in a pumped storage plant, based on IEC 61346-1 .....	20
Figure A.1 – Example of curve based on an indexed gate position providing water flow .....	80
Figure A.2 – Example of curve based on an indexed guide vane position (x axis) vs net head (y axis) giving an interpolated Runner Blade position (Z axis) .....	81
Figure A.3 – Example of a proportional-integral-derivate controller .....	82
Figure A.4 – Example of a Power stabilisation system .....	83
Figure A.5 – Example of a ramp generator .....	83
Figure A.6 – Example of an interface with a set-point algorithm .....	84
Figure A.7 – Example of a physical connection to a set-point device .....	85
Table 1 – Example of Logical Device over-current protection .....	19
Table 2 – recommended LN prefixes .....	22
Table 3 – Logical nodes for control functions .....	23
Table 4 – Logical nodes representing functional blocks .....	23
Table 5 – Hydropower specific logical nodes .....	23
Table 6 – Logical nodes for interface and archiving .....	24
Table 7 – Logical nodes for mechanical and non-electric primary equipment .....	25
Table 8 – Logical nodes for physical devices and common LN .....	25
Table 9 – Logical nodes for metering and measurement .....	25
Table 10 – Logical nodes for protections .....	26
Table 11 – Logical nodes for protection related functions .....	26
Table 12 – Logical nodes for supervision and monitoring .....	26
Table 13 – Logical nodes for sensors .....	27
Table 14 – Logical nodes for switchgear .....	27
Table 15 – Logical nodes for power transformers .....	27
Table 16 – Logical nodes for power system equipment .....	28
Table 17 – Interpretation of Logical Node tables .....	28
Table 18 – Conditional attributes in FPID .....	32
Table 19 – Description of data .....	63
Table 20 – Semantics of data attributes .....	78

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

#### Part 7-410: Hydroelectric power plants – Communication for monitoring and control

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees, any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61850-410 has been prepared by IEC technical committee 57: *Power systems management and associated information exchange*.

It has been decided to amend the general title of the IEC 61850 series to *Communication networks and systems for power utility automation*. Henceforth, new editions within the IEC 61850 series will adopt this new general title.

The text of this standard is based on the following documents:

FDIS	Report on voting
57/886/FDIS	57/905/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61850 series, under the general title *Communication networks and systems for power utility automation*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

Withdrawn

## INTRODUCTION

The present standard includes all additional logical nodes, not included in IEC 61850-7-4:2003, required to represent the complete control and monitoring system of a hydropower plant.

Most of the Logical Nodes in IEC 61850-7-410 that are of general use, Logical Nodes the names of which do not start with the letter “H”, will be transferred to the future Edition 2 of IEC 61850-7-4. In the same manner, all Common Data Classes specified in IEC 61850-7-410 will be transferred to future Edition 2 of IEC 61850-7-3.

Once future Editions 2 of IEC 61850-7-3 and IEC 61850-7-4 are published, IEC 61850-7-410 will be revised to include only those Logical Nodes that are specific to hydropower use.

Before Edition 2 of IEC 61850-7-410 is published, there will be a period where the Common Data Class (CDC) and Logical Node (LN) specifications will overlap with IEC 61850-7-3 (future Edition 2) and IEC 61850-7-4 (future Edition 2). During this time, the specifications in IEC 61850-7-3 (future Edition 2) and IEC 61850-7-4 (future Edition 2) will apply.

Withdrawn



## COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

### Part 7-410: Hydroelectric power plants – Communication for monitoring and control

#### 1 Scope

IEC 61850-7-410 is part of the IEC 61850 series. This part of IEC 61850 specifies the additional common data classes, logical nodes and data objects required for the use of IEC 61850 in a hydropower plant.

The Logical Nodes and Data Objects defined in this part of IEC 61850 belong to the following fields of use:

- **Electrical functions.** This group includes LN and DO used for various control functions, essentially related to the excitation of the generator. New LN and DO defined within this group are not specific to hydropower plants; they are more or less general for all types of larger power plants.
- **Mechanical functions.** This group includes functions related to the turbine and associated equipment. The specifications of this document are intended for hydropower plants, modifications might be required for application to other types of generating plants. Some more generic functions are though defined under Logical Node group K.
- **Hydrological functions.** This group of functions includes objects related to water flow, control and management of reservoirs and dams. Although specific for hydropower plants, the LN and DO defined here can also be used for other types of utility water management systems.
- **Sensors.** A power plant will need sensors providing measurements of other than electrical data. With a few exceptions, such sensors are of general nature and not specific for hydropower plants.

NOTE All Logical Nodes with names not starting with the letter "H" will be included in a future edition 2 of IEC 61850-7-4. When that document is published, the Logical Nodes in IEC 61850-7-4 (Edition 2) will take precedence over Logical Nodes with the same name in this part IEC 61850-7-410.

#### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies:

IEC 61850-2, *Communication networks and systems in substations – Part 2: Glossary*

IEC 61850-5, *Communication networks and systems in substations – Part 5: Communication requirements for functions and device models*

IEC 61850-6, *Communication networks and systems in substations – Part 6: Configuration description language for communication in electrical substations related to IEDs*

IEC 61850-7-2:2003, *Communication networks and systems in substations – Part 7-2: Basic communication structure for substation and feeder equipment – Abstract communication services interface (ACSI)*

IEC 61850-7-3:2003, *Communication networks and systems in substations – Part 7-3: Basic communication structure for substation and feeder equipment – Common data classes*

IEC 61850-7-4:2003, *Communication networks and systems in substations – Part 7-4: Basic communication structure for substation and feeder equipment – Compatible logical node classes*

Withdrawn