

This is a preview - click here to buy the full publication

INTERNATIONAL STANDARD

IEC 60488-2

First edition
2004-05

IEEE 488.2™

Standard digital interface for programmable instrumentation –

Part 2: Codes, formats, protocols and common commands

© IEEE 2004 — Copyright - all rights reserved

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Inc.

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch

The Institute of Electrical and Electronics Engineers, Inc, 3 Park Avenue, New York, NY 10016-5997, USA
Telephone: +1 732 562 3800 Telefax: +1 732 562 1571 E-mail: stds-info@ieee.org Web: www.standards.ieee.org



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия



This is a preview - click here to buy the full publication

CONTENTS

Foreword	6
1. Introduction	10
1.1 Scope	10
1.2 Objectives	11
1.3 Notation	11
2. References	11
3. System Considerations	12
3.1 Definitions	12
3.2 System Message Traffic	13
3.3 Functional Layers	14
4. Device Compliance Criteria	15
4.1 IEEE 488.1 Requirements	16
4.2 Message Exchange Requirements	16
4.3 Syntax Requirements	16
4.4 Status Reporting Requirements	18
4.5 Common Commands	21
4.6 Synchronization Requirements	24
4.7 System Configuration Capability	24
4.8 Controller Capability	25
4.9 Device Documentation Requirements	25
5. Device Interface Function Requirements	26
5.1 Handshake Requirements	26
5.2 Address Requirements	27
5.3 Talker Requirements	27
5.4 Listener Requirements	27
5.5 Service Request Requirements	28
5.6 Remote/Local Requirements	28
5.7 Parallel Poll Requirements	30
5.8 Device Clear Requirements	31
5.9 Device Trigger Requirements	31
5.10 Controller Function Requirements	31
5.11 Electrical Requirements	31
5.12 Power-On Requirements	32
6. Message Exchange Control Protocol	33
6.1 Functional Elements	33
6.2 Protocol Overview	45
6.3 Message Exchange Control Operation	47
6.4 Protocol Rules	52
6.5 Protocol Exceptions	55
7. Device Listening Formats	57
7.1 Overview	57
7.2 Notation	58
7.3 Terminated Program Messages – Functional Syntax	61

7.4	Separator Functional Elements	65
7.5	<PROGRAM MESSAGE TERMINATOR>	67
7.6	Program Header Functional Elements	67
7.7	<PROGRAM DATA> Functional Elements	72
8.	Device Talking Elements	87
8.1	Overview	87
8.2	Notation	88
8.3	Terminated Response Messages – Functional Syntax	88
8.4	Separator Functional Elements	92
8.5	<RESPONSE MESSAGE TERMINATOR>	93
8.6	<RESPONSE HEADER>	94
8.7	<RESPONSE DATA> Functional Elements	95
9.	Message Data Coding	106
9.1	ASCII 7 bit Codes	107
9.2	Binary 8 Bit Integer Codes	109
9.3	Binary Floating Point Code	110
10.	Common Commands and Queries	113
10.1	*AAD, Accept Address Command	116
10.2	*CAL?, Calibration Query	116
10.3	*CLS, Clear Status Command	117
10.4	*DDT, Define Device Trigger Command	118
10.5	*DDT?, Define Device Trigger Query	119
10.6	*DLF, Disable Listener Function Command	120
10.7	*DMC, Define Macro Command	120
10.8	*EMC, Enable Macro Command	123
10.9	*EMC?, Enable Macro Query	124
10.10	*ESE, Standard Event Status Enable Command	125
10.11	*ESE?, Standard Event Status Enable Query	125
10.12	*ESR?, Standard Event Status Register Query	126
10.13	*GMC?, Get Macro Contents Query	126
10.14	*IDN?., Identification Query	127
10.15	*IST?, Individual Status Query	129
10.16	*LMC?, Learn Macro Query	129
10.17	*LRN?, Learn Device Setup Query	130
10.18	*OPC, Operation Complete Command	131
10.19	*OPC?, Operation Complete Query	131
10.20	*OPT?, Option Identification Query	132
10.21	*PCB, Pass Control Back	133
10.22	*PMC, Purge Macros Command	134
10.23	*PRE, Parallel Poll Enable Register Command	134
10.24	*PRE?, Parallel Poll Enable Register Query	135
10.25	*PSC, Power-On Status Clear Command	136
10.26	*PSC?, Power-On Status Clear Query	137
10.27	*PUD, Protected User Data Command	137
10.28	*PUD?, Protected User Data Query	138
10.29	*RCL, Recall Command	139
10.30	*RDT, Resource Description Transfer Command	140

This is a preview - click here to buy the full publication

- 10.31 *RDT?, Resource Description Transfer Query..... 141
- 10.32 *RST, Reset Command 142
- 10.33 *SAV, Save Command..... 143
- 10.34 *SRE, Service Request Enable Command..... 143
- 10.35 *SRE?, Service Request Enable Query..... 144
- 10.36 *STB?, Read Status Byte Query 145
- 10.37 *TRG, Trigger Command 145
- 10.38 *TST?, Self-Test Query..... 146
- 10.39 *WAI, Wait-to-Continue Command..... 147
- 10.40 *RMC, Remove Individual Macro Command..... 147
- 10.41 *SDS, Save Default Device Settings Command..... 148

- 11. Device Status Reporting 149
 - 11.1 Overview 149
 - 11.2 Status Byte Register 150
 - 11.3 Service Request Enabling 155
 - 11.4 Status Data Structures 161
 - 11.5 Standard Status Data Structure..... 166
 - 11.6 Parallel Poll Response Handling..... 173

- 12. Device/Controller Synchronization Techniques 174
 - 12.1 Overview 174
 - 12.2 Sequential and Overlapped Commands..... 175
 - 12.3 Pending-Operation Flag 176
 - 12.4 No-Operation-Pending Flag..... 176
 - 12.5 Controller/Device Synchronization Commands..... 176
 - 12.6 Synchronization With External-Control-Signals..... 180
 - 12.7 Improper Usage of *OPC and *OPC? 181
 - 12.8 Design Considerations 182

- 13. Automatic System Configuration 184
 - 13.1 Introduction 184
 - 13.2 Overview 185
 - 13.3 Generic Approach to Automatic System Configuration 186
 - 13.4 Detailed Requirements of the Auto Configuration Commands 191
 - 13.5 Additional Automatic Configuration Techniques 197
 - 13.6 Examples 197

- 14. Controller Compliance Criteria 197
 - 14.1 IEEE 488.1 Requirements..... 197
 - 14.2 Message Exchange Requirements 198
 - 14.3 Protocols..... 198
 - 14.4 Functional Element Handling 200
 - 14.5 Controller Specification Requirements..... 200

- 15. I IEEE 488.2 Controller Requirements..... 200
 - 15.1 Controller Interface Function Requirements..... 200
 - 15.2 Additional IEEE 488.2 Controller Requirements..... 201
 - 15.3 IEEE 488.2 Controller Recommendations 202

16.	Controller Message Exchange Protocols.....	202
	16.1 Definitions.....	203
	16.2 Control Sequences.....	205
17.	Common Controller Protocols	213
	17.1 Reset Protocol	214
	17.2 Find Device Requesting Service Protocol	215
	17.3 Serial Poll All Devices Protocol	216
	17.4 Pass Control Protocol.....	218
	17.5 Requesting Control.....	219
	17.6 Find Listeners Protocol	220
	17.7 Set Address Protocol.....	221
	17.8 Test System Protocol.....	226
	Annex A Compound Headers – Usage and Examples (Informative)	228
	Annex B Device/Controller Synchronization Techniques (Informative).....	232
	Annex C Automatic System Configuration Example (Informative).....	244
	Annex D Reset Guidelines (Informative).....	250
	Annex E List of Participants (Informative).....	256

This is a preview - click here to buy the full publication

INTERNATIONAL ELECTROTECHNICAL COMMISSION

STANDARD DIGITAL INTERFACE FOR PROGRAMMABLE INSTRUMENTATION – Part 2: Codes, formats, protocols and common commands

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC/IEEE 60488-2 has been processed through subcommittee 65C: Digital communications, of IEC technical committee 65: Industrial-process measurement and control.

This standard cancels and replaces the second edition of IEC 60625-2 (1993).

At times in this standard, specific reference is made to IEEE Std 488.1:1987, which constituted an earlier version of IEEE Std 488.1:2003, the IEEE edition upon which IEC/IEEE 60488-1:2004 is based. Where specific dated references were made to the 1987 edition, these references have been maintained.

The text of this standard is based on the following documents:

IEEE Std	FDIS	Report on voting
488.2 (1992)	65C/320/FDIS	65C/326/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives.

The committee has decided that the contents of this publication will remain unchanged until 2009.

IEC/IEEE 60488 consists of the following publications:

- Higher performance protocol for the standard digital interface for programmable instrumentation – Part 1: General (60488-1).
- Standard digital interface for programmable instrumentation – Part 2: Codes, formats, protocols and common commands (60488-2).

IEC/IEEE Dual Logo International Standards

This Dual Logo International Standard is the result of an agreement between the IEC and the Institute of Electrical and Electronics Engineers, Inc. (IEEE). The original IEEE Standard was submitted to the IEC for consideration under the agreement, and the resulting IEC/IEEE Dual Logo International Standard has been published in accordance with the ISO/IEC Directives.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEC/IEEE Dual Logo International Standard is wholly voluntary. The IEC and IEEE disclaim liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEC or IEEE Standard document.

The IEC and IEEE do not warrant or represent the accuracy or content of the material contained herein, and expressly disclaim any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEC/IEEE Dual Logo International Standards documents are supplied "AS IS".

The existence of an IEC/IEEE Dual Logo International Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEC/IEEE Dual Logo International Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEC and IEEE are not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Neither the IEC nor IEEE is undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEC/IEEE Dual Logo International Standards or IEEE Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

Interpretations – Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration.

Comments for revision of IEC/IEEE Dual Logo International Standards are welcome from any interested party, regardless of membership affiliation with the IEC or IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board, 445 Hoes Lane, P.O. Box 1331, Piscataway, NJ 08855-1331, USA and/or General Secretary, IEC, 3, rue de Varembe, PO Box 131, 1211 Geneva 20, Switzerland.

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

NOTE – Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents for which a license may be required by an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

**IEEE Standard Codes, Formats,
Protocols, and Common Commands for
use With IEEE Std 448.1-1987,
IEEE Standard Digital Interface for
Programmable Instrumentation**

Sponsor

**Automated Instrumentation Committee
of the
IEEE Instrumentation and Measurement Society**

Approved June 18, 1992

IEEE Standards Board

Approved January 4, 1993

American National Standards Institute

Abstract: A set of codes and formats to be used by devices connected via the IEEE 488.1 bus is specified. This standard also defines communication protocols that are necessary to effect application-independent and device-dependent message exchanges, and further defines common commands and characteristics useful in instrument system applications. It is intended to apply to small-scale to medium-scale instrument systems comprised mainly of measurement, stimulus, and interconnect devices outside the scope of the instrument system environment. IEEE 488.1 subsets, standard message-handling protocols including error handling, unambiguous program and response-message syntactic structures, common commands useful in a wide range of instrument system applications, standard status reporting structures, and system configuration and synchronization protocols are covered.

Keywords: controller, device, system, system bus, system interface

IEEE Foreword

IEEE Std 488 has been in existence for seventeen years, during which time its power and versatility have been proven decisively. Probably its most important contribution to test system automation has been the standardization of system interconnection and communication. A large and growing base of design and application experience has allowed this further standardization of the IEEE Std 488 bus. The additional standardization sought by the original IEEE Std 488.2-1987 was founded on the premise that the existing investment in IEEE Std 488 resources must be protected. Thus, IEEE Std 488.2 describes functionality that complements and is based upon IEEE Std 488.1-1987. Every effort has been made to reap the benefits of standardization without limiting the freedom and creativity of the device designer.

Since the introduction of IEEE Std 488-1978, individual manufacturers of devices have developed internal standards that address the code, format, protocol, syntax, and semantic concepts. System integrators have identified requirements useful in configuring systems. All these sources have been used and refined in developing this standard.

This revision of the original 1987 document contains many minor changes, too numerous to list, plus a few major changes. The changes are intended to be optional additions and clarifications to the 1987 standard. The goal of the working group was to allow devices and controllers designed in compliance with IEEE Std 488.2-1978 to remain in compliance with IEEE Std 488.2-1992.

Major new features include the addition of an <EXPRESSION RESPONSE DATA> element; the expanded use of <SUFFIX PROGRAM DATA>; the addition of the *RMC, Remove Individual Macro Command; the addition of the *SDS, Save Default Device Settings Command; the modification of *DDT, *DMC, *PUD, and *RDT commands to accept block or string data; and a new appendix on Reset Guidelines. There are many clarifications including a macro expansion algorithm; the removal of ambiguity in the definition of suffixes; and the scope of *LRN?, *SAV, *RCL, and *RST, to name a few.

The hope is that this new revision, incorporating five years of experience with IEEE Std 488.2-1987, will provide an even more solid foundation for the standardized communication of test and measurement systems.

STANDARD DIGITAL INTERFACE FOR PROGRAMMABLE INSTRUMENTATION -

Part 2: Codes, formats, protocols and common commands

1. Introduction

1.1 Scope

This standard specifies a set of codes and formats to be used by **devices** connected via the IEEE 488.1 bus. This standard also defines communication protocols necessary to effect application independent device-dependent message exchanges and further defines common commands and characteristics useful in instrument **system** applications.

This standard is intended to apply directly to small-scale to medium-scale instrument **systems**. It applies to **systems** comprised mainly of measurement, stimulus, and interconnect **devices** with an instrumentation **controller**. The standard may also apply to certain **devices** outside the scope of the instrument **system** environment.

As well as defining a variety of device-dependent messages, this standard extends and further interprets certain interface functions contained in IEEE Std 488.1-1987 [4]¹ while remaining compatible with that standard.

This standard covers the following topics:

- 1) IEEE 488.1 subsets
- 2) Standard message handling protocols including error handling
- 3) Unambiguous program and response message syntactic structures
- 4) Common commands useful in a wide range of instrument **system** applications
- 5) Standard status reporting structures
- 6) **System** configuration and synchronization protocols

Use of this standard does not relieve the user from the burden of responsibility for **system** compatibility at the application level. The user must be familiar with the characteristics of all the **system** components in order to configure an optimum **system**.

The intended readers of this standard include both **controller** and **device** designers.

¹The numbers in brackets correspond to those of the references in Section 2.

1.2 Objectives

The objectives of this standard are

- 1) To provide a well-defined and unambiguous structure of codes, formats, protocols, and common commands
- 2) To retain generality to accommodate the needs of a wide variety of applications within the scope of the standard
- 3) To promote the degree to which **devices** from different manufacturers may be interconnected and used, without modification
- 4) To enable the interconnection of instrumentation and related **devices** with both limited and extensive capability to generate, process, and interpret a variety of different message types
- 5) To define codes, formats, protocols, and common commands that will reduce the costs of generating application software and the costs of **system** integration
- 6) To permit direct communication among instrument **system devices** without extraordinary translation and conversion of special codes and formats

1.3 Notation

This standard defines several common English words that have special meaning in the context of this standard. These words have different connotations in IEEE Std 488.1-1987 [4], but are, for reasons of readability and conciseness of text, the preferred words for use in this standard. To avoid confusion, these words always appear in bold type when referenced in this document. Words that appear in bold type are: **system**, **device**, **controller**, **system bus**, and **system interface**. Local messages peculiar to IEEE 488.2 will also appear in lowercase bold type.

This standard also defines syntactic elements that are used to describe messages transferred on the bus. Syntactic elements are enclosed by angle brackets, for example, <syntactic element>, to set them off from local messages, remote messages, and normal text.

2. References

This standard shall be used in conjunction with the following publications:

- [1] ANSI X3.4-1986, American National Standard Code for Information Interchange Coded Character Set—7-Bit.²
- [2] ANSI X3.42-1990, American National Standard Representation of Numeric Values in Character Strings for Information Interchange.
- [3] IEEE Std 260-1978, (Reaff 1985). IEEE Standard Letter Symbols for Units of Measurement (SI Units, Customary Inch-Pound Units, and Certain Other Units) (ANSI, DoD).³
- [4] IEEE Std 488.1-1987, IEEE Standard Digital Interface for Programmable Instrumentation (ANSI)*.

²ANSI publications are available from the Sales Department, American National Standards Institute, 11 West 42nd Street, 13th Floor, New York, NY 10036, USA.

³IEEE publications are available from the Institute of Electrical and Electronics Engineers, Service Center, 445 Hoes Lane, P.O. Box 1331, Piscataway, NJ 08855-1331, USA.

* Reference is made in this standard to IEEE Std 488.1:1987, an earlier edition of the IEEE document upon which IEC/IEEE 60488-1:2004 is based.

- [5] IEEE Std 754-1985 (Reaff 1991), IEEE Standard for Binary Floating-Point Arithmetic.
- [6] ISO 31-1: 1992, Quantities and units — Part 1: Space and time.⁴
- [7] ISO 31-2: 1992, Quantities and units — Part 2: Periodic and related phenomena.
- [8] ISO 31-3: 1992, Quantities and units — Part 3: Mechanics.
- [9] ISO 31-4: 1992, Quantities and units — Part 4: Heat.
- [10] ISO 31-5: 1992, Quantities and units — Part 5: Electricity and magnetism.
- [11] ISO 31-6: 1992, Quantities and units — Part 6: Light and related electromagnetic radiations.
- [12] ISO 31-7: 1992, Quantities and units — Part 7: Acoustics.
- [13] ISO 31-8 : 1992, Quantities and units — Part 8: Physical chemistry and molecular physics.
- [14] ISO 31-9: 1992, Quantities and units — Part 9: Atomic and nuclear physics.
- [15] ISO 31-10: 1992, Quantities and units — Part 10: Nuclear reactions and ionizing radiations.
- [16] ISO 31-11: 1992, Quantities and units — Part 11: Mathematical signs and symbols for use in the physical sciences and technology.
- [17] ISO 31-12: 1992, Quantities and units — Part 12: Characteristic numbers.
- [18] ISO 1000: 1992, SI units and recommendations for the use of their multiples and of certain other units.
- [19] ISO 2955: 1983, Information processing—Representation of SI and other units in systems with limited character sets.
- [20] Mueller, J. E., “Efficient Instrument Design Using IEEE 488.2,” *IEEE Transactions on Instrumentation and Measurement*, vol. IM-39, pp. 146–150, Feb. 1990.

⁴ISO publications are available from ISO, Case Postale 56, 1 rue de Varembe, CH-1211, Genève 20, Switzerland/Suisse. ISO publications are also available in the United States from the Sales Department, American National Standards Institute, 11 West 42nd Street, 13th Floor, New York, NY 10036, USA.