

This is a preview - click here to buy the full publication



IEC 62439-5

Edition 1.0 2010-02

# INTERNATIONAL STANDARD

Industrial communication networks – High availability automation networks –  
Part 5: Beacon Redundancy Protocol (BRP)



WITHDRAWN

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

PRICE CODE

X

ICS 25.040, 35.040

ISBN 978-2-88910-708-7

## CONTENTS

FOREWORD .....	4
INTRODUCTION .....	6
1 Scope .....	7
2 Normative references .....	7
3 Terms, definitions, abbreviations, acronyms, and conventions .....	7
3.1 Terms and definitions .....	7
3.2 Abbreviations and acronyms .....	8
3.3 Conventions .....	8
4 BRP overview .....	8
5 BRP principle of operation .....	8
5.1 General .....	8
5.2 Network topology .....	8
5.3 Network components .....	10
5.4 Rapid reconfiguration of network traffic .....	11
6 BRP stack and fault detection features .....	11
7 BRP protocol specification .....	13
7.1 MAC addresses .....	13
7.2 EtherType .....	13
7.3 Fault detection mechanisms .....	13
7.4 End node state diagram .....	13
7.5 Beacon end node state diagram .....	21
8 BRP message structure .....	27
8.1 General .....	27
8.2 ISO/IEC 8802-3 (IEEE 802.3) tagged frame header .....	28
8.3 Beacon message .....	28
8.4 Learning_Update message .....	28
8.5 Failure_Notify message .....	29
8.6 Path_Check_Request message .....	29
8.7 Path_Check_Response message .....	29
9 BRP fault recovery time .....	29
10 BRP service definition .....	30
10.1 Supported services .....	30
10.2 Common service parameters .....	31
10.3 Set_Node_Parameters service .....	31
10.4 Get_Node_Parameters service .....	33
10.5 Add_Node_Receive_Parameters service .....	35
10.6 Remove_Node_Receive_Parameters service .....	37
10.7 Get_Node_Status service .....	38
11 BRP Management Information Base (MIB) .....	39
Bibliography .....	41
Figure 1 – BRP star network example .....	9
Figure 2 – BRP linear network example .....	9
Figure 3 – BRP ring network example .....	10
Figure 4 – BRP stack architecture .....	11

Figure 5 – BRP state diagram of end node.....	14
Figure 6 – BRP state diagram for beacon end node .....	21
Table 1 – BRP end node flags .....	16
Table 2 – BRP end node state transition table .....	17
Table 3 – BRP beacon end node flags .....	23
Table 4 – BRP beacon end node state transition table .....	24
Table 5 – BRP common header with ISO/IEC 8802-3 (IEEE 802.3) tagged frame format.....	28
Table 6 – BRP beacon message format .....	28
Table 7 – BRP Learning_Update message format.....	28
Table 8 – BRP Failure_Notify message format.....	29
Table 9 – BRP Path_Check_Request message format .....	29
Table 10 – BRP Path_Check_Response message format .....	29
Table 11 – BRP Set_Node_Parameters service parameters.....	32
Table 12 – BRP Get_Node_Parameters service parameters .....	34
Table 13 – BRP Add_Node_Receive_Parameters service parameters .....	36
Table 14 – BRP Remove_Node_Receive_Parameters service parameters .....	37
Table 15 – BRP Get_Node_Status service parameters .....	38

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### INDUSTRIAL COMMUNICATION NETWORKS – HIGH AVAILABILITY AUTOMATION NETWORKS –

#### Part 5: Beacon Redundancy Protocol (BRP)

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

International Standard IEC 62439-5 has been prepared by subcommittee 65C: Industrial Networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This standard cancels and replaces IEC 62439 published in 2008. This first edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to IEC 62439 (2008):

- adding a calculation method for RSTP (rapid spanning tree protocol, IEEE 802.1Q),
- adding two new redundancy protocols: HSR (High-availability Seamless Redundancy) and DRP (Distributed Redundancy Protocol),
- moving former Clauses 1 to 4 (introduction, definitions, general aspects) and the Annexes (taxonomy, availability calculation) to IEC 62439-1, which serves now as a base for the other documents,
- moving Clause 5 (MRP) to IEC 62439-2 with minor editorial changes,

- moving Clause 6 (PRP) was to IEC 62439-3 with minor editorial changes,
- moving Clause 7 (CRP) was to IEC 62439-4 with minor editorial changes, and
- moving Clause 8 (BRP) was to IEC 62439-5 with minor editorial changes,
- adding a method to calculate the maximum recovery time of RSTP in a restricted configuration (ring) to IEC 62439-1 as Clause 8,
- adding specifications of the HSR (High-availability Seamless Redundancy) protocol, which shares the principles of PRP to IEC 62439-3 as Clause 5, and
- introducing the DRP protocol as IEC 62439-6.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/583/FDIS	65C/589/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This International Standard is to be read in conjunction with IEC 62439-1:2010, *Industrial communication networks – High availability automation networks – Part 1: General concepts and calculation methods*.

A list of the IEC 62439 series can be found, under the general title *Industrial communication networks – High availability automation networks*, on the IEC website.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

The committee has decided that the contents of this amendment and the base publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this standard may be issued at a later date.

**IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.**

## INTRODUCTION

The IEC 62439 series specifies relevant principles for high availability networks that meet the requirements for industrial automation networks.

In the fault-free state of the network, the protocols of the IEC 62439 series provide ISO/IEC 8802-3 (IEEE 802.3) compatible, reliable data communication, and preserve determinism of real-time data communication. In cases of fault, removal, and insertion of a component, they provide deterministic recovery times.

These protocols retain fully the typical Ethernet communication capabilities as used in the office world, so that the software involved remains applicable.

The market is in need of several network solutions, each with different performance characteristics and functional capabilities, matching diverse application requirements. These solutions support different redundancy topologies and mechanisms which are introduced in IEC 62439-1 and specified in the other Parts of the IEC 62439 series. IEC 62439-1 also distinguishes between the different solutions, giving guidance to the user.

The IEC 62439 series follows the general structure and terms of IEC 61158 series.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of a patent concerning fault-tolerant Ethernet provided through the use of special interfaces providing duplicate ports that may be alternatively enabled with the same network address. Switching between the ports corrects for single faults in a two-way redundant system. This is given in Clauses 5 and 6.

IEC takes no position concerning the evidence, validity and scope of this patent right.

The holder of this patent right has assured the IEC that he/she is willing to negotiate licences either free of charge or under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of this patent right is registered with IEC. Information may be obtained from:

Rockwell Automation Technologies  
1 Allen-Bradley Drive  
Mayfield Heights  
Ohio  
USA

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

ISO ([www.iso.org/patents](http://www.iso.org/patents)) and IEC ([http://www.iec.ch/tctools/patent\\_decl.htm](http://www.iec.ch/tctools/patent_decl.htm)) maintain on-line data bases of patents relevant to their standards. Users are encouraged to consult the data bases for the most up to date information concerning patents.

## INDUSTRIAL COMMUNICATION NETWORKS – HIGH AVAILABILITY AUTOMATION NETWORKS –

### Part 5: Beacon Redundancy Protocol (BRP)

#### 1 Scope

The IEC 62439 series is applicable to high-availability automation networks based on the ISO/IEC 8802-3 (IEEE 802.3) (Ethernet) technology.

This part of the IEC 62439 series specifies a redundancy protocol that is based on the duplication of the network, the redundancy protocol being executed within the end nodes, as opposed to a redundancy protocol built in the switches. Fast error detection is provided by two beacon nodes, the switchover decision is taken in every node individually. The cross-network connection capability enables single attached end nodes to be connected on either of the two networks.

#### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-191, *International Electrotechnical Vocabulary – Chapter 191: Dependability and quality of service*

IEC 62439-1:2010, *Industrial communication networks – High availability automation networks – Part 1: General concepts and calculation methods*

ISO/IEC/TR 8802-1, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 1: Overview of Local Area Network Standards* (IEEE 802.1)

ISO/IEC 8802-3:2000, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications*

IEEE 802.1D, *IEEE standard for local and metropolitan area networks Media Access Control (MAC) Bridges*

IEEE 802.1Q, *IEEE standards for local and metropolitan area network. Virtual bridged local area networks*