

INTERNATIONAL STANDARD

IEC 62271-200

First edition
2003-11

**High-voltage switchgear and controlgear –
Part 200:
AC metal-enclosed switchgear and controlgear
for rated voltages above 1 kV and up to
and including 52 kV**

*This **English-language** version is derived from the original **bilingual** publication by leaving out all French-language pages. Missing page numbers correspond to the French-language pages.*



Reference number
IEC 62271-200:2003(E)

INTERNATIONAL STANDARD

IEC 62271-200

First edition
2003-11

High-voltage switchgear and controlgear – Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

© IEC 2003 Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE **XC**

For price, see current catalogue

CONTENTS

FOREWORD	9
1 General.....	17
1.1 Scope	17
1.2 Normative references.....	19
2 Normal and special service conditions	21
3 Terms and definitions.....	21
4 Ratings	33
4.1 Rated voltage (U_r).....	33
4.2 Rated insulation level	33
4.3 Rated frequency (f_r)	33
4.4 Rated normal current and temperature rise	33
4.5 Rated short-time withstand current (I_k).....	35
4.6 Rated peak withstand current (I_p).....	35
4.7 Rated duration of short circuit (t_k).....	35
4.8 Rated supply voltage of closing and opening devices and of auxiliary and control circuits (U_a).....	35
4.9 Rated supply frequency of closing and opening devices and of auxiliary circuits.....	35
4.10 Rated pressure of compressed gas supply for insulation and/or operation.....	35
4.10.1 Rated filling level (of fluid-filled compartments).....	35
5 Design and construction.....	37
5.1 Requirements for liquids in switchgear and controlgear	37
5.2 Requirements for gases in switchgear and controlgear	37
5.3 Earthing.....	37
5.4 Auxiliary and control equipment.....	41
5.5 Dependent power operation	41
5.6 Stored energy operation.....	41
5.7 Independent manual operation	41
5.8 Operation of releases.....	41
5.9 Low- and high-pressure interlocking and monitoring devices.....	41
5.10 Nameplates.....	41
5.11 Interlocking devices	43
5.12 Position indication.....	45
5.13 Degrees of protection by enclosures.....	45
5.14 Creepage distances	45
5.15 Gas and vacuum tightness	45
5.16 Liquid tightness.....	47
5.17 Flammability	47
5.18 Electromagnetic compatibility (EMC)	47
6 Type tests	59
6.1 General	59
6.2 Dielectric tests	63
6.3 Radio interference voltage (r.i.v.) test.....	69
6.4 Measurement of the resistance of circuits.....	71
6.5 Temperature-rise tests.....	71
6.6 Short-time withstand current and peak withstand current tests.....	73

6.7	Verification of the protection.....	77
6.8	Tightness tests	77
6.9	Electromagnetic compatibility tests (EMC).....	77
6.10	Additional tests on auxiliary and control circuits	77
7	Routine tests.....	85
7.1	Dielectric test on the main circuit.....	87
7.2	Tests on auxiliary and control circuits	87
7.3	Measurement of the resistance of the main circuit	87
7.4	Tightness test	87
7.5	Design and visual checks.....	87
8	Guide to the selection of metal-enclosed switchgear and controlgear for service.....	91
8.1	Selection of rated values.....	91
8.2	Selection of design and construction	91
8.3	Internal arc classification.....	97
9	Information to be given with enquiries, tenders and orders.....	105
10	Rules for transport, storage, installation, operation and maintenance.....	109
10.1	Conditions during transport, storage and installation.....	109
10.2	Installation	109
10.3	Operation.....	109
10.4	Maintenance	109
11	Safety.....	111
Annex A (normative) Internal fault – Method for testing the metal-enclosed switchgear and controlgear under conditions of arcing due to an internal fault		113
A.1	Introduction.....	113
A.2	Types of accessibility	115
A.3	Test arrangements	115
A.4	Current and voltage applied.....	123
A.5	Test procedure.....	125
A.6	Acceptance criteria.....	127
A.7	Test report.....	129
A.8	Designation of IAC classification.....	131
Annex B (normative) Partial discharge measurement		145
B.1	General.....	145
B.2	Application	145
B.3	Test circuits and measuring instruments.....	147
B.4	Test procedure.....	147
B.5	Maximum permissible partial discharge quantity	149
Annex C (informative) Explanatory notes		157
C.1	Changes in classifications, compared to the third edition (1990) of IEC 60298	157
C.2	ANSI defined metal-clad.....	163

C.3 Former IEC defined metal-clad in terms of IEC 62271-200 definitions	163
C.4 Example of modular fuse-switch type.....	165
Bibliography	169
Figure A.1 – Mounting frame for vertical indicators.....	133
Figure A.2 – Horizontal indicator	133
Figure A.3 – Position of the indicators.....	135
Figure A.4 – Room simulation and indicator positioning for accessibility A, functional unit at or above 1,5 m.....	137
Figure A.5 – Room simulation and indicator positioning for accessibility B, functional unit above 2 m high	139
Figure A.6 – Room simulation and indicator positioning for accessibility B, functional unit below 2 m high	141
Figure A.7 – Test arrangement for overhead connected pole-mounted switchgear and controlgear.....	143
Figure B.1 – Partial discharge test circuit (three-phase arrangement).....	153
Figure B.2 – Partial-discharge test circuit (system without earthed neutral).....	155
Table 1 – Nameplate information	41
Table 2– Locations, causes and examples of measures to decrease the probability of internal faults	99
Table 3 – Summary of technical requirements, ratings and optional tests for metal enclosed switchgear	101
Table B.1 – Test circuits and procedures	151
Table C.1 – Comparison of IEC and IEEE definition of metal-clad	157
Table C.2 – Classification related to personnel safety in case of internal arc	159

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62271-200 has been prepared by subcommittee 17C: High-voltage switchgear and controlgear assemblies, of IEC technical committee 17: Switchgear and controlgear.

This first edition of IEC 62271-200 cancels and replaces the third edition of IEC 60298, published in 1990, and constitutes a technical revision.

Significant technical changes from the third edition of IEC 60298 are as follows:

This revised document has been basically changed to be updated to today's use of high-voltage switchgear and controlgear up to 52 kV. The main changes are: new definitions and classification of equipment, introduction of internal arc classes (IAC) and its testing.

This standard is to be read in conjunction with IEC 60694¹ published in 1996. Clause numbering follows the clause numbering of that standard. Additional subclauses, as they relate to a particular clause or subclause from IEC 60694, are numbered 101, 102, etc.

The text of this standard is based on the following documents:

FDIS	Report on voting
17C/311/FDIS	17C/315/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until 2009. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

Withdrawn

¹ IEC 60694 (1996) will be replaced by IEC 62271-1 as soon as available.

**COMMON NUMBERING OF IEC 62271 PUBLICATIONS FALLING UNDER
THE RESPONSIBILITY OF SUBCOMMITTEES SC 17A AND SC 17C**

In accordance with the decision taken at the joint SC 17A/SC 17C meeting in Frankfurt, June 1998 (item 20.7 of 17A/535/RM), a common numbering system has been established for the publications falling under the responsibility of SC 17A and SC 17C. IEC 62271 – *High-voltage switchgear and controlgear* is the publication number and main title element for the common publications.

The numbering of these publications will apply the following principle.

- a) Common standards prepared by SC 17A and SC 17C will start with IEC 62271-1.
- b) Standards of SC 17A will start with IEC 62271-100.
- c) Standards of SC 17C will start with number IEC 62271-200.
- d) Publications prepared by SC 17A and SC 17C will start with number IEC 62271-300.

The table below relates the new numbers to the old numbers. The parts numbered (xxx) will be given a final number pending the decision to publish the revised publication as standard or technical report.

Withdrawn

Common numbering of IEC 62271 publications falling under the responsibility of subcommittees SC 17A and SC 17C

IEC 62271 series	HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR	Old IEC number, if any
Part	New title	
1	Common specifications	IEC 60694
2	Seismic qualification for rated voltages of 72,5 kV and above	-
100	High-voltage alternating current circuit-breakers	IEC 60056
101	Synthetic testing	IEC 60427
102	High-voltage alternating current disconnectors and earthing switches	IEC 60129
103	Switches for rated voltages above 1 kV and less than 52 kV	IEC 60265-1
104	Switches for rated voltages of 52 kV and above	IEC 60265-2
105	Alternating current switch-fuse combinations	IEC 60420
106	Alternating current contactors and contactor-based motor-starters	IEC 60470
107	Alternating current switchgear-fuse combinations	-
108	Switchgear having combined functions	-
109	Series capacitor by-pass switches	-
200	AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV	IEC 60298
201	Insulation-enclosed switchgear and controlgear for rated voltages up to and including 52 kV	IEC 60466
202	High-voltage/low-voltage prefabricated substations	IEC 61330
203	Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV	IEC 60517
204	High-voltage gas-insulated transmission lines for rated voltages of 72,5 kV and above	IEC 61640
(300)	Guide for seismic qualification of high-voltage alternating current circuit-breakers	IEC 61166
(301)	Guide for inductive load switching	IEC 61233
(302)	Guide for short-circuit and switching test procedures for metal-enclosed and dead tank circuit-breakers	IEC 61633
(303)	Use and handling of sulphur hexafluoride (SF ₆) in high-voltage switchgear and controlgear	IEC 61634
(304)	Additional requirements for enclosed switchgear and controlgear from 1 kV to 72,5 kV to be used in severe climatic conditions	IEC 60932
(305)	Cable connections for gas-insulated metal-enclosed switchgear for rated voltages above 52 kV	IEC 60859
(306)	Direct connection between power transformers and gas-insulated metal-enclosed switchgear for rated voltages above 52 kV	IEC 61639
(307)	Use of electronic and associated technologies in auxiliary equipment of switchgear and controlgear	IEC 62063
308	Guide for asymmetrical short-circuit breaking test duty T100a	-
309	TRV parameters for high-voltage switchgear and controlgear for rated voltages above 1 kV and less than 100 kV	-
310	Electrical endurance testing for circuit-breakers rated 72,5 kV and above	-

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

1 General

1.1 Scope

This part of IEC 62271 specifies requirements for factory-assembled metal-enclosed switchgear and controlgear for alternating current of rated voltages above 1 kV and up to and including 52 kV for indoor and outdoor installation, and for service frequencies up to and including 60 Hz. Enclosures may include fixed and removable components and may be filled with fluid (liquid or gas) to provide insulation.

NOTE 1 Although primarily dedicated to three-phase systems, this standard can also be applied to single-phase or two-phase systems.

This standard defines several types of metal enclosed switchgear and controlgear which differ due to

- the consequences on network service continuity in case of maintenance on the switchgear and controlgear;
- the need and convenience of maintenance of the equipment.

NOTE 2 Safety of an installation results from the design, implementation and coordination of products, installations and operations.

For metal-enclosed switchgear and controlgear containing gas-filled compartments, the design pressure is limited to a maximum of 300 kPa (relative pressure).

NOTE 3 Gas-filled compartments having a design pressure exceeding 300 kPa (relative pressure) should be designed and tested in accordance with IEC 60517.

Metal-enclosed switchgear and controlgear for special use, for example, in flammable atmospheres, in mines or on board ships, may be subject to additional requirements.

Components contained in metal-enclosed switchgear and controlgear are to be designed and tested in accordance with their various relevant standards. This standard supplements the standards for the individual components regarding their installation in switchgear and controlgear assemblies.

This standard does not preclude that other equipment may be included in the same enclosure. In such a case, any possible influence of that equipment on the switchgear and controlgear is to be taken into account.

NOTE 4 Switchgear and controlgear assemblies having an insulation enclosure are covered by IEC 60466.

NOTE 5 Metal-enclosed switchgear and controlgear for rated voltages above 52 kV insulated by ambient air may be covered by this standard taking into account the insulation levels of IEC 60694.

1.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050(151):2001, *International Electrotechnical Vocabulary – Chapter 151: Electrical and magnetic devices*

IEC 60050(441):1984, *International Electrotechnical Vocabulary – Chapter 441: Switchgear, controlgear and fuses*

IEC 60060-1:1989, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60243-1:1998, *Electrical strength of insulating materials – Test methods – Part 1: Tests at power frequencies*

IEC 60265-1:1998, *High-voltage switches – Part 1: Switches for rated voltages above 1 kV and less than 52 kV*

IEC 60270:2000, *High-voltage test techniques – Partial discharge measurements*

IEC 60466:1987, *AC insulation-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 38 kV*

IEC 60470:2000, *High-voltage alternating current contactors and contactor-based motor-starters*

IEC 60480:1974, *Guide to the checking of sulphur hexafluoride (SF₆) taken from electrical equipment*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 60694:1996, *Common specifications for high-voltage switchgear and controlgear standards*

IEC 60909-0:2001, *Short-circuit currents in three-phase a.c. systems – Part 0: Calculation of currents*

IEC 60932:1988, *Additional requirements for enclosed switchgear and controlgear from 1 kV to 72,5 kV to be used in severe climatic conditions*

IEC 61634:1995, *High-voltage switchgear and controlgear – Use and handling of sulphur hexafluoride (SF₆) in high-voltage switchgear and controlgear*

IEC 62271-100:2001, *High-voltage alternating-current circuit-breakers*

IEC 62271-102:2001, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62271-105:2002, *High-voltage switchgear and controlgear – Part 105: Alternating current switch-fuse combinations*

ISO/IEC Guide 51:1999, *Safety aspects – Guidelines for their inclusion in standards*