



TECHNICAL REPORT



Electromagnetic performance of high voltage direct current (HVDC) overhead transmission lines

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE

XD

ICS 29.240.20

ISBN 978-2-8322-1780-1

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Terms and definitions	9
3 Electric field and ion current	10
3.1 Description of the physical phenomena	10
3.2 Calculation methods	13
3.2.1 General	13
3.2.2 Semi-analytic method	14
3.2.3 Finite element method	16
3.2.4 BPA method	17
3.2.5 Empirical methods of EPRI	18
3.2.6 Recent progress	18
3.3 Experimental data.....	19
3.3.1 General	19
3.3.2 Instrumentation and measurement methods.....	19
3.3.3 Experimental results for electric field and ion current.....	21
3.3.4 Discussion.....	21
3.4 Implication for human and natural environment.....	22
3.4.1 General	22
3.4.2 Static electric field	23
3.4.3 Research on space charge	23
3.4.4 Scientific review	28
3.5 Design practice of different countries	29
4 Magnetic field.....	30
4.1 Description of physical phenomena.....	30
4.2 Magnetic field of HVDC transmission lines	31
5 Radio interference (radio noise).....	32
5.1 Description of radio interference phenomena of HVDC transmission system	32
5.1.1 General	32
5.1.2 Physical aspects of d.c. corona	32
5.1.3 Mechanism of formation of a noise field of d.c. line.....	33
5.1.4 Characteristics of radio interference from d.c. line	33
5.1.5 Factors influencing the RI from d.c. line.....	34
5.2 Calculation methods	36
5.2.1 EPRI empirical formula	36
5.2.2 IREQ empirical method.....	37
5.2.3 CISPR bipolar line RI prediction formula.....	38
5.2.4 Comparison of different prediction formula.....	38
5.3 Experimental data.....	38
5.3.1 Measurement apparatus and methods	38
5.3.2 Experimental results for radio interference.....	39
5.4 Criteria of different countries.....	39
6 Audible noise.....	40
6.1 Basic principles of audible noise	40
6.2 Description of physical phenomena.....	41

6.2.1	Lateral profiles.....	42
6.2.2	Statistical distribution	44
6.2.3	Influencing factors	45
6.2.4	Effect of altitude above sea level	47
6.2.5	Concluding remarks.....	47
6.3	Calculation methods	48
6.3.1	General	48
6.3.2	Theoretical analysis of audible noise propagation.....	48
6.3.3	Empirical formulas of audible noise	49
6.3.4	Semi-empirical formulas of audible noise.....	49
6.3.5	CEPRI (China) research results	52
6.3.6	Concluding remarks.....	52
6.4	Experimental data.....	52
6.4.1	Measurement techniques and instrumentation	52
6.4.2	Experimental results for audible noise	53
6.5	Design practice of different countries	53
6.5.1	General	53
6.5.2	The effect of audible noise on people.....	53
6.5.3	The audible noise level and induced complaints	54
6.5.4	Limit values of audible noise of HVDC transmission lines in different countries	57
6.5.5	Recommended noise level limit.....	58
6.5.6	Main conclusion.....	58
Annex A (informative)	Experimental results for electric field and ion current.....	59
A.1	Bonneville Power Administration ±500 kV HVDC transmission line.....	59
A.2	FURNAS ±600 kV HVDC transmission line.....	59
A.3	Manitoba Hydro ±450 kV HVDC transmission line	60
A.4	Hydro-Québec – New England ±450 kV HVDC transmission line	62
A.5	IREQ test line study of ±450 kV HVDC line configuration	63
A.6	HVTRC test line study of ±400 kV HVDC line configuration	64
A.7	Test study in China.....	66
Annex B (informative)	Experimental results for radio interference	68
B.1	Bonneville power administration’s 1 100 kV direct current test project.....	68
B.1.1	General	68
B.1.2	Lateral profile	68
B.1.3	Influence of conductor gradient.....	69
B.1.4	Percent cumulative distribution	70
B.1.5	Influence of wind	72
B.1.6	Spectrum.....	72
B.2	Hydro-Québec institute of research.....	74
B.2.1	General	74
B.2.2	Cumulative distribution	74
B.2.3	Spectrum.....	75
B.2.4	Lateral profiles.....	75
B.2.5	Cumulative distribution under different voltage	76
B.3	d.c. line of China.....	76
Annex C (informative)	Experimental results for audible noise.....	78
Bibliography	81

Figure 1 – Unipolar and bipolar space charge regions of a HVDC transmission line [1]	11
Figure 2 – Lateral profile of magnetic field on the ground of ± 800 kV HVDC lines	32
Figure 3 – The corona current and radio interference field	33
Figure 4 – RI tolerance tests: reception quality as a function of signal-to-noise ratio	40
Figure 5 – Attenuation of different weighting networks used in audible-noise measurements [14]	41
Figure 6 – Comparison of typical audible noise frequency spectra [129]	42
Figure 7 – Lateral profiles of the AN	43
Figure 8 – Lateral profiles of the AN from a bipolar HVDC-line equipped with $8 \times 4,6$ cm ($8 \times 1,8$ in) conductor bundles energized with $\pm 1\,050$ kV [32]	43
Figure 9 – Lateral profiles of fair-weather A-weighted sound level	44
Figure 10 – All weather distribution of AN and RI at +15 m lateral distance of the positive pole from the upgraded Pacific NW/SW HVDC Intertie [32]	45
Figure 11 – Statistical distributions of fair weather A-weighted sound level measured at 27 m lateral distance from the line center during spring 1980	45
Figure 12 – Audible noise complaint guidelines [12]	54
Figure 13 – Measured lateral profile of audible noise on a 330 kV AC transmission line [149]	55
Figure 14 – Subjective evaluation of d.c. transmission line audible noise; EPRI test center study 1974 [31]	55
Figure 15 – Subjective evaluation of d.c. transmission line audible noise; OSU study 1975 [31]	56
Figure 16 – Results of the operators' subjective evaluation of AN from HVDC lines	57
Figure 17 – Results of subjective evaluation of AN from d.c. lines	57
Figure A.1 – Electric field and ion current distributions for Manitoba Hydro ± 450 kV Line [37]	61
Figure A.2 – Cumulative distribution of electric field for Manitoba Hydro ± 450 kV Line [37] 62	
Figure A.3 – Cumulative distribution of ion current density for Manitoba Hydro ± 450 kV line [37]	62
Figure A.4 – Test result for total electric field at different humidity [117]	67
Figure A.5 – Comparison between the calculation result and test result for the total electric field (minimum conductor height is 18 m) [117]	67
Figure B.1 – Connection for 3-section d.c. test line [121]	68
Figure B.2 – Typical RI lateral profile at ± 600 kV, $4 \times 30,5$ mm conductor, 11,2 m pole spacing, 15,2 m average height [12]	69
Figure B.3 – Simultaneous RI lateral, midspan, in clear weather and light wind for three configurations, bipolar ± 400 kV [121]	69
Figure B.4 – RI at 834 kHz as a function of bipolar line voltage $4 \times 30,5$ mm conductor, 11,2 m pole spacing, 15,2 m average height	70
Figure B.5 – Percent cumulative distribution for fair weather, 2×46 mm, 18,3 m pole spacing, ± 600 kV	70
Figure B.6 – Percent cumulative distribution for rain weather, 2×46 mm, 18,3 m pole spacing, ± 600 kV	71
Figure B.7 – Percent cumulative distribution for fair weather, $4 \times 30,5$ mm, 13,2 m pole spacing, ± 600 kV	71

Figure B.8 – Percent cumulative distribution for rain weather, 4 × 30,5 mm, 13,2 m pole spacing, ±600 kV	72
Figure B.9 – Radio interference frequency spectrum	73
Figure B.10 – RI vs. frequency at ±400 kV [121]	73
Figure B.11 – Cumulative distribution of RI measured at 15 m from the positive pole [122]	74
Figure B.12 – Conducted RI frequency spectrum measured with the line terminated at one end [122]	75
Figure B.13 – Lateral profile of RI [122]	76
Figure B.14 – Annual cumulative distribution of RI measured at 15 m from the positive pole [122]	76
Figure B.15 – Comparison between calculation result and test result for RI lateral profile [117]	77
Figure C.1 – Examples of statistical distributions of fair weather audible noise, dB(A) measured at 27 m from line center of a bipolar HVDC test line [14]	79
Table 1 – Electric field and ion current limits of ±800 kV d.c. lines in China	30
Table 2 – Electric field limits of d.c. lines in United States of America [119]	30
Table 3 – Electric field and ion current limits of d.c. lines in Canada	30
Table 4 – Electric field limits of d.c. lines in Brazil	30
Table 5 – Parameters of the IREQ excitation function [120]	38
Table 6 – Comparison of the EPRI and CISPR formula	38
Table 7 – Parameters defining regression equation for generated acoustic power density	51
Table 8 – Typical sound attenuation (in decibels) provided by buildings [155]	58
Table A.1 – BPA ±500 kV line: statistical summary of all-weather ground-level electric field intensity and ion current density [32]	59
Table A.2 – FURNAS ±600 kV line: statistical summary of ground-level electric field intensity and ion current density [36]	60
Table A.3 – Hydro-Québec–New England ±450 kV HVDC transmission line. Bath, NH; 1990-1992 (fair weather), 1992 (rain), All-season measurements of static electric E-field in kV/m [39]	63
Table A.4 – Hydro-Québec – New England ±450 kV HVDC Transmission Line. Bath, NH; 1990-1992, All-season fair-weather measurements of ion concentrations in kions/cm ³ [39]	63
Table A.5 – IREQ ± 450 kV test line: statistical summary of ground-level electric field intensity and ion current density [41]	64
Table A.6 – HVTRC ±400 kV test line: statistical summary of peak electric field and ion currents [42]	65
Table A.7 – Statistic results for the test data of total electric field at ground (50 % value) [117]	66
Table B.1 – Influence of wind on RI	72
Table B.2 – Statistical representation of the long term RI performance of the tested conductor bundle [122]	75
Table B.3 – RI at 0,5 MHz at lateral 20m from positive pole (fair weather)	77
Table C.1 – Audible Noise Levels of HVDC Lines according to [119] and [150]	80

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTROMAGNETIC PERFORMANCE OF HIGH VOLTAGE DIRECT CURRENT (HVDC) OVERHEAD TRANSMISSION LINES

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 62681, which is a technical report, has been prepared by IEC technical committee 115: High Voltage Direct Current (HVDC) transmission for d.c. voltages above 100 kV.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
115/71/DTR	115/84/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

Withdrawn

INTRODUCTION

Electric fields and magnetic fields are produced in the vicinity of an HVDC transmission line. When the electric field at the conductor surface exceeds a critical value, known as the corona onset gradient, positive or negative free charges leave the conductor and interact with the surrounding air and ionization takes place in the layer of surrounding air, leading to the formation of corona discharges. The corona discharge will not only bring out corona loss but also produce electromagnetic environment problems.

The parameters used to describe the electromagnetic environment of an HVDC transmission line mainly include the:

- 1) electric field,
- 2) ion current,
- 3) magnetic field,
- 4) radio interference,
- 5) audible noise.

To control these parameters in a reasonable and acceptable range, for years, a great deal of theoretical and experimental research was conducted in many countries, and relevant national standards or enterprise standards were developed. This Technical Report collects and records the status of study and progress of electric fields, ion current, magnetic fields, radio interference, and audible noise of HVDC transmission lines.

ELECTROMAGNETIC PERFORMANCE OF HIGH VOLTAGE DIRECT CURRENT (HVDC) OVERHEAD TRANSMISSION LINES

1 Scope

This Technical Report provides general guidance on the electromagnetic environment issues of HVDC transmission lines. It concerns the major parameters adopted to describe the electromagnetic environment of a High-Voltage Direct Current (HVDC) transmission line, including electric fields, ion current, magnetic fields radio interference, and audible noise generated as a consequence of such effects. Engineers in different countries can refer to this Technical Report to:

- ensure the safe operation of HVDC transmission lines,
- limit the influence on the environment within acceptable ranges, and
- optimize engineering costs.

Withdrawal