


IEC TS 62910

Edition 1.0 2015-10

TECHNICAL SPECIFICATION



Utility-interconnected photovoltaic inverters – Test procedure for low voltage ride-through measurements



ICS 27.160 ISBN 978-2-8322-2957-6

Warning! Make sure that you obtained this publication from an authorized distributor.

-2-

CONTENTS

F	OREWO	PRD	4			
1	Scope6					
2	Norm	native references	6			
3	Term	Terms, definitions, symbols and abbreviations				
	3.1	Terms, definitions and symbols				
	3.2	Abbreviations				
4	Test	circuit and equipment	9			
	4.1	General	9			
	4.2	Test circuit				
	4.3	Test equipment	9			
	4.3.1	Measuring instruments	9			
	4.3.2	DC source	10			
	4.3.3	Short-circuit emulator				
	4.3.4	Converter based grid simulator	13			
5	Test		13			
	5.1	Test protocol	13			
	5.2	Test curve	15			
	5.3	Test procedure	16			
	5.3.1		_			
	5.3.2		16			
	5.3.3	Tolerance	16			
	5.3.4	Load test	17			
6	Asse	ssment criteria	17			
Αı	nnex A	(informative) Circuit faults and voltage drops	18			
	A.1	Fault types	18			
	A.2	Voltage drops	20			
	A.2.1					
	A.2.2	2 Three-phase short-circuit fault	20			
A.2.3 Two-phase short-circuit fault with ground						
	A.2. ²					
	A.2.5	S (
Αı	nnex B	(informative) Determination of critical performance values in LVRT testing	24			
	B.1	General				
	B.2	Drop depth ratio				
	B.3	Ride-through time				
	B.4	Reactive current				
	B.5	Active power				
Bi	bliograp	bhy	26			
Fi	gure 1 -	- Testing circuit diagram	9			
Fi	Figure 2 – Short-circuit emulator11					
Fi	Figure 3 – Converter device example1					
Fi	Figure 4 – LVRT curve example10					
Fi	Figure 5 – Tolerance of voltage drop17					

IEC TS 62910:2015 © IEC 2015 - 3 -

Figure A.1 – Grid fault diagram	20
Figure A.2 – Diagram of voltage vector for three-phase short-circuit fault	20
Figure A.3 – Diagram of voltage vector of two-phase (BC) short-circuit fault with ground	21
Figure A.4 – Diagram of voltage vector of two-phase (BC) short-circuit fault	22
Figure A.5 – Diagram of voltage vector of single-phase (A) short-circuit fault with ground	23
Figure B.1 – Determination of reactive current output	25
Figure B.2 – Determination of active power recovery	25
Table 1 – Accuracy of measurements	10
Table 2 – Fault type and switch status	12
Table 3 – Test specification for LVRT (indicative)	14
Table A.1 – Short-circuit paths for different fault types	18
Table A.2 – Amplitude and phase changes in three-phase short circuit fault	21
Table A.3 – Amplitude and phase changes in two-phase (BC) short-circuit fault with	22
Table A.4 – Amplitude and phase changes in two phase (BC) short-circuit fault	22
Table A.5 – Amplitude and phase changes in single phase (A) short-circuit fault with ground	23

– 4 –

INTERNATIONAL ELECTROTECHNICAL COMMISSION

UTILITY-INTERCONNECTED PHOTOVOLTAIC INVERTERS – TEST PROCEDURE FOR LOW VOLTAGE RIDE-THROUGH MEASUREMENTS

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and EC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC TS 62910, which is a technical specification, has been prepared by IEC technical committee 82: Solar photovoltaic energy systems.

IEC TS 62910:2015 © IEC 2015

- 5 -

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
82/884/DTS	82/1005/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- · reconfirmed,
- withdrawn,
- · replaced by a revised edition, or
- · amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

IEC TS 62910:2015 © IEC 2015

-6-

UTILITY-INTERCONNECTED PHOTOVOLTAIC INVERTERS – TEST PROCEDURE FOR LOW VOLTAGE RIDE-THROUGH MEASUREMENTS

1 Scope

This Technical Specification provides a test procedure for evaluating the performance of Low Voltage Ride-Through (LVRT) functions in inverters used in utility-interconnected PV systems.

The technical specification is most applicable to large systems where PV inverters are connected to utility HV distribution systems. However, the applicable procedures may also be used for LV installations in locations where evolving LVRT requirements include such installations, e.g. single-phase or 3-phase systems.

The assessed LVRT performance is valid only for the specific configuration and operational mode of the inverter under test. Separate assessment is required for the inverter in other factory or user-settable configurations, as these may cause the inverter LVRT response to behave differently.

The measurement procedures are designed to be as non-site specific as possible, so that LVRT characteristics measured at one test site, for example, can also be considered valid at other sites.

This technical specification is for testing of PV inverters, though it contains information that may also be useful for testing of a complete PV power plant consisting of multiple inverters connected at a single point to the utility grid. It further provides a basis for utility-interconnected PV inverter numerical simulation and model validation.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61400-21.2008, Wind turbines – Part 21: Measurement and assessment of power quality characteristics of grid connected wind turbines