

This is a preview - click here to buy the full publication



IEEE

IEC 60076-21

Edition 2.0 2018-12

INTERNATIONAL IEEE Std C57.15™ STANDARD

**Power transformers –
Part 21: Standard requirements, terminology, and test code for step-voltage
regulators**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.180

ISBN 978-2-8322-6260-3

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	9
1 Scope.....	11
2 Normative references	11
2.1 IEC references.....	11
2.2 IEEE references.....	11
2.3 SAE references.....	12
3 Terms and definitions	12
4 Use of normative references	16
5 Service conditions	17
5.1 Usual service conditions	17
5.1.1 General	17
5.1.2 Temperature	17
5.1.3 Altitude	17
5.1.4 Supply voltage.....	17
5.1.5 Load current	17
5.1.6 Outdoor operation.....	17
5.1.7 Tank or enclosure finish.....	17
5.2 Loading at other than rated conditions	18
5.3 Unusual service conditions	18
5.3.1 General	18
5.3.2 Unusual temperature and altitude conditions	18
5.3.3 Insulation at high altitude.....	18
5.3.4 Other unusual service conditions	19
6 Rating data.....	20
6.1 Cooling classes of voltage regulators.....	20
6.1.1 General	20
6.1.2 Liquid-immersed (fire point ≤ 300 °C) air-cooled	20
6.1.3 Liquid-immersed (fire point > 300 °C) air-cooled	20
6.2 Ratings	20
6.2.1 General	20
6.2.2 Terms in which rating is expressed	21
6.2.3 Preferred ratings.....	21
6.2.4 Supplementary voltage ratings.....	26
6.3 Supplementary continuous-current ratings	27
6.3.1 General	27
6.3.2 Optional forced-air ratings	27
6.4 Taps	28
6.5 Voltage supply ratios	28
6.6 Insulation levels	28
6.7 Losses.....	29
6.7.1 General	29
6.7.2 Total loss.....	29
6.7.3 Tolerance for losses	29
6.7.4 Determination of losses and excitation current.....	29
6.8 Short-circuit requirements.....	30

6.8.1	General	30
6.8.2	Mechanical capability demonstration	31
6.8.3	Thermal capability of voltage regulators for short-circuit conditions	31
6.9	Sound pressure level for liquid-immersed voltage regulators.....	31
6.10	Tests	32
6.10.1	General	32
6.10.2	Routine tests	32
6.10.3	Type tests.....	32
7	Construction	33
7.1	Bushings.....	33
7.2	External dielectric clearances	34
7.3	Terminal markings	34
7.4	Diagram of connections	35
7.5	Nameplates.....	36
7.6	Tank construction	37
7.6.1	General	37
7.6.2	Pressure-relief valve.....	37
7.6.3	Cover assembly.....	37
7.6.4	Sudden pressure relay.....	38
7.6.5	Lifting lugs.....	38
7.6.6	Support lugs	38
7.6.7	Substation bases	40
7.6.8	Tank grounding provisions.....	40
7.7	Components and accessories	41
7.7.1	Components for full automatic control and operation.....	41
7.7.2	Accessories for single-phase step-voltage regulators.....	41
7.7.3	Accessories for three-phase step-voltage regulators.....	42
8	Other requirements.....	42
8.1	General.....	42
8.2	Other components and accessories	42
8.2.1	General	42
8.2.2	Single- and three-phase voltage regulators.....	42
8.2.3	Three-phase voltage regulators	43
9	Test code	43
9.1	General.....	43
9.2	Resistance measurements	43
9.2.1	General	43
9.2.2	Determination of cold temperature.....	43
9.2.3	Conversion of resistance measurements.....	44
9.2.4	Resistance measurement methods	44
9.3	Polarity test	45
9.3.1	General	45
9.3.2	Polarity by inductive kick	46
9.3.3	Polarity by ratio meter.....	46
9.4	Ratio test	46
9.4.1	General	46
9.4.2	Taps	46

9.4.3	Voltage and frequency	47
9.4.4	Three-phase voltage regulators	47
9.4.5	Tolerance for ratio	47
9.4.6	Ratio test methods.....	47
9.5	No-load loss and excitation current	49
9.5.1	General	49
9.5.2	No-load loss test.....	50
9.5.3	Waveform correction of no-load loss	51
9.5.4	Test methods for three-phase voltage regulators	52
9.5.5	Determination of excitation (no-load) current	52
9.5.6	Measurements	53
9.5.7	Correction of loss measurement due to metering phase-angle errors	53
9.6	Load loss and impedance voltage	54
9.6.1	General	54
9.6.2	Factors affecting the values of load loss and impedance voltage	55
9.6.3	Tests for measuring load loss and impedance voltage	56
9.6.4	Calculation of load loss and impedance voltage from test data	58
9.7	Dielectric tests	60
9.7.1	General	60
9.7.2	Lightning impulse type test	61
9.7.3	Lightning impulse routine test	67
9.7.4	Applied-voltage test	69
9.7.5	Induced-voltage test	69
9.7.6	Insulation power factor tests	71
9.7.7	Insulation resistance tests	72
9.8	On-load tap-changer routine tests	73
9.8.1	General	73
9.8.2	Mechanical test	74
9.8.3	Auxiliary circuits insulation test.....	74
9.9	Control system routine tests.....	74
9.9.1	Applied voltage.....	74
9.9.2	Operation	74
9.10	Temperature-rise test.....	74
9.10.1	General	74
9.10.2	Test methods.....	75
9.10.3	Resistance measurements.....	78
9.10.4	Temperature measurements	79
9.10.5	Correction of temperature-rise test results	82
9.11	Short-circuit test	83
9.11.1	General	83
9.11.2	Test connections	83
9.11.3	Test requirements.....	84
9.11.4	Test procedure	84
9.11.5	Proof of satisfactory performance	86
9.12	Determination of sound level.....	87
9.12.1	General	87
9.12.2	Applicability	88

9.12.3	Instrumentation.....	88
9.12.4	Test conditions	88
9.12.5	Microphone positions	90
9.12.6	Sound level measurements.....	91
9.12.7	Determination of sound level of a voltage regulator	95
9.12.8	Presentation of results.....	97
9.13	Calculated data.....	98
9.13.1	Reference temperature	98
9.13.2	Loss and excitation current.....	99
9.13.3	Efficiency.....	99
9.13.4	Calculation of winding temperature during a short-circuit	99
9.13.5	Certified test data	101
10	Component tests	102
10.1	General.....	102
10.2	Enclosure integrity	102
10.2.1	General	102
10.2.2	Static pressure	102
10.2.3	Dynamic pressure.....	103
10.2.4	Type test for fault current capability of a voltage regulator enclosure.....	103
10.3	On-load tap-changer	104
10.3.1	General	104
10.3.2	Type tests.....	104
10.4	Control system.....	109
10.4.1	General	109
10.4.2	Control device construction.....	110
10.4.3	Accuracy	110
10.4.4	Type tests.....	112
11	Universal interface.....	116
11.1	Connection between control enclosure and apparatus.....	116
11.2	Universal interface connector.....	117
Annex A (informative)	Unusual temperature and altitude conditions	120
A.1	Unusual temperatures and altitude service conditions	120
A.2	Effects of altitude on temperature-rise	120
A.3	Operation at rated kVA	120
A.4	Operation at less than rated kVA	120
Annex B (informative)	Field dielectric tests	121
B.1	Tests on bushings.....	121
B.2	Dielectric tests in the field.....	121
Annex C (informative)	Step-voltage regulator construction	122
C.1	General.....	122
C.2	Type A.....	123
C.3	Type B.....	123
C.4	Series transformer construction	124
C.5	Reactor circuit	124
C.6	Equalizer winding.....	124
Annex D (informative)	Hazards of Bypass off Neutral.....	126

Annex E (informative) Overloading of step-voltage regulators	130
Annex F (informative) Power capacitor and distributed generation compatibility	134
F.1 Power capacitor application issues	134
F.1.1 General	134
F.1.2 Power circuit for consideration	134
F.1.3 Voltage regulator incorporating line-drop compensation (LDC) in the control	134
F.1.4 Voltage regulator incorporating line current compensation (LCC) in the control	137
F.2 Distributed generation application issues	137
F.2.1 General	137
F.2.2 Control operation with power reversal recognition	138
F.2.3 Power circuit for consideration	139
F.2.4 Distributed generator alternatives	139
F.2.5 P-Q summary	140
F.2.6 Example system with distribution generation (DG)	140
F.2.7 Expanded example, distributed generation mode	142
F.2.8 Caveats	142
F.2.9 Conclusions	142
Bibliography	143
Figure 1 – Single-phase voltage regulators	35
Figure 2 – Three-phase voltage regulators with two arrangements of bushings	35
Figure 3 – Type-B support lugs	39
Figure 4 – Type-C support lugs	40
Figure 5 – Connections for voltmeter-ammeter method of resistance measurement	44
Figure 6 – Voltage regulator connected for polarity testing – Voltage regulator in Neutral position	46
Figure 7 – Voltmeter arranged to read the difference between the two output side voltages	48
Figure 8 – Voltmeters arranged to read the two series winding voltages	48
Figure 9 – Basic circuit of ratio meter	49
Figure 10 – Connection for no-load loss test of single-phase voltage regulator without instrument transformers	50
Figure 11 – Connections for no-load loss test of a single-phase voltage regulator with instrument transformers	51
Figure 12 – Three-phase voltage regulator connections for no-load loss and excitation current test using three-wattmeter method	53
Figure 13 – Single-phase voltage regulator connections for load loss and impedance voltage test without instrument transformers	57
Figure 14 – Single-phase voltage regulator connections for load loss and impedance voltage test with instrument transformers	57
Figure 15 – Three-phase voltage regulator connections for load loss and impedance voltage test using the three-wattmeter method	58
Figure 16 – Example of loading back method: single-phase	76
Figure 17 – Example of loading back method: three-phase	77

Figure 18 – Microphone location for measuring sound level	90
Figure 19 – Sound reflection correction factor "K" calculated as per Equation (29).....	94
Figure 20 – Measurements using the sound pressure method	98
Figure 21 – Measurements using the sound intensity method	98
Figure 22 – Universal interface specification.....	117
Figure 23 – Socket/pin detail for universal interface	117
Figure 24 – Universal interface locations	119
Figure C.1 – Basic diagram of single-phase, Type A, step-voltage regulator	122
Figure C.2 – Basic diagram of single-phase, Type B, step-voltage regulator	122
Figure C.3 – Type A.....	123
Figure C.4 – Type B.....	123
Figure C.5 – Example of series transformer construction	124
Figure C.6 – Equalizer winding and reactor circuitry – Non-bridging tap position.....	125
Figure C.7 – Equalizer winding and reactor circuitry – Bridging tap position.....	125
Figure D.1 – "Bypass off Neutral" power circuit.....	127
Figure D.2 – Example of "Bypass off Neutral" RMS symmetrical current pattern of a Type A design.....	128
Figure D.3 – Example of "Bypass off Neutral" RMS symmetrical current pattern of a Type B design.....	129
Figure E.1 – Example of overload capability by tap position	131
Figure E.2 – Example of Type A load loss vs tap position	131
Figure E.3 – Example of Type B load loss vs tap position	132
Figure E.4 – Tap-changer arc interruption envelope.....	132
Figure E.5 – Contact wear	133
Figure F.1 – Power distribution substation and representative distribution feeder.....	134
Figure F.2 – Power distribution system with distributed generation	139
Figure F.3 – P-Q diagram quadrant relationships	140
Table 1 – Dielectric strength correction factors for altitudes greater than 1 000 m (3 300 ft).....	19
Table 2 – Limits of temperature-rise.....	21
Table 3 – Ratings for liquid-immersed 60 Hz step-voltage regulators (single-phase)	22
Table 4 – Ratings for liquid-immersed 50 Hz step-voltage regulators (single-phase)	23
Table 5 – Ratings for liquid-immersed 60 Hz step-voltage regulators (three-phase)	25
Table 6 – Ratings for liquid-immersed 50 Hz step-voltage regulators (three-phase)	26
Table 7 – Supplementary voltage ratings	26
Table 8 – Supplementary continuous-current ratings.....	27
Table 9 – Forced-air ratings relationship	28
Table 10 – Values of voltage supply ratios.....	28
Table 11 – Interrelationships of dielectric insulation levels for voltage regulators	29
Table 12 – Values of k	30
Table 13 – Maximum no-load (excitation) sound pressure levels.....	31

Table 14 – Electrical characteristics of voltage regulator bushings.....	34
Table 15 – External dielectric clearances.....	34
Table 16 – Bushing terminal applications.....	41
Table 17 – Requirements for phase-angle error correction.....	54
Table 18 – Measurements to be made in insulation power factor tests.....	72
Table 19 – Ambient sound pressure level correction.....	92
Table 20 – Approximate values of the average acoustic absorption coefficient.....	93
Table 21 – Voltage level values for select line-drop compensation.....	112
Table 22 – Control supply voltage.....	115
Table 23 – Socket pin identification for connector.....	118
Table A.1 – Maximum allowable average temperature of cooling air for rated kVA ^a	120
Table A.2 – Rated kVA correction factors for altitudes greater than 1 000 m (3 300 ft).....	120
Table F.1 – Relevant system voltages and currents with capacitor location.....	136
Table F.2 – System and voltage regulator control response with example distributed generation (DG), no line-drop compensation.....	141

POWER TRANSFORMERS –

Part 21: Standard requirements, terminology, and test code for step-voltage regulators

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation.

IEEE Standards documents are developed within IEEE Societies and Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of IEEE and serve without compensation. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards. Use of IEEE Standards documents is wholly voluntary. *IEEE documents are made available for use subject to important notices and legal disclaimers (see <http://standards.ieee.org/IPR/disclaimers.html> for more information).*

IEC collaborates closely with IEEE in accordance with conditions determined by agreement between the two organizations. This Dual Logo International Standard was jointly developed by the IEC and IEEE under the terms of that agreement.

- 2) The formal decisions of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees. The formal decisions of IEEE on technical matters, once consensus within IEEE Societies and Standards Coordinating Committees has been reached, is determined by a balanced ballot of materially interested parties who indicate interest in reviewing the proposed standard. Final approval of the IEEE standards document is given by the IEEE Standards Association (IEEE-SA) Standards Board.
- 3) IEC/IEEE Publications have the form of recommendations for international use and are accepted by IEC National Committees/IEEE Societies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC/IEEE Publications is accurate, IEC or IEEE cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications (including IEC/IEEE Publications) transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC/IEEE Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC and IEEE do not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC and IEEE are not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or IEEE or their directors, employees, servants or agents including individual experts and members of technical committees and IEC National Committees, or volunteers of IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board, for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC/IEEE Publication or any other IEC or IEEE Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that implementation of this IEC/IEEE Publication may require use of material covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. IEC or IEEE shall not be held responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patent Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

International Standard IEC 60076-21/IEEE Std C57.15-2017 has been prepared by IEC technical committee 14: Power transformers, in cooperation with the Transformers Committee of the IEEE Power and Energy Society¹, under the IEC/IEEE Dual Logo Agreement.

This publication is published as an IEC/IEEE Dual Logo standard. This second edition cancels and replaces IEC 60076-21, published in 2011, and IEEE Std C57.15-2009.

This edition includes the following significant technical changes with respect to IEC 60076-21:2011/IEEE Std C57.15-2009:

- a) updated list of normative and bibliography IEC and IEEE references and their associated text;
- b) updated tables of preferred ratings for inclusion of maximum system voltage (U_m), nominal system voltage and rated voltage (U_r);
- c) inclusion of tables for optional fan-cooled ratings, external dielectric clearances and sound pressure levels;
- d) revision of short-circuit requirements for distribution and substation voltage regulators;
- e) inclusion of an universal interface between control enclosure and apparatus;
- f) inclusion of tap-changer routine and type tests;
- g) inclusion of audible sound pressure emissions test procedures;
- h) inclusion of tank enclosure integrity type test procedures;
- i) update of control environmental IEC reference test standard.

The text of this standard is based on the following documents:

FDIS	Report on voting
14/974/FDIS	14/989/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

International standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

A list of parts of the 60076 International Standard, published under the general title *Power transformers*, can be found on the IEC website.

The IEC Technical Committee and IEEE Technical Committee have decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

¹ A list of IEEE participants can be found at the following URL:
<https://standards.ieee.org/standard/C57.15-2017.html>

POWER TRANSFORMERS –

Part 21: Standard requirements, terminology, and test code for step-voltage regulators

1 Scope

This document describes electrical, mechanical and test requirements of liquid-immersed, single- and three-phase, 50 Hz and 60 Hz, self and forced-air cooled, distribution, overhead and substation, step-voltage regulators, 1 000 kVA (single-phase units) or 3 000 kVA (three-phase units) and smaller, 34 500 volts and below (2 400 V minimum) and their associated controls.

Requirements, references and definitions relevant to either IEC or IEEE contexts are given and their use is described in Clause 4.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

2.1 IEC references

IEC 60050-421, *International Electrotechnical Vocabulary – Chapter 421: Power transformers and reactors*

IEC 60060 (all parts), *High-voltage test techniques*

IEC 60076-2, *Power transformers – Part 2: Temperature rise for liquid-immersed transformers*

IEC 60255-1, *Measuring relays and protection equipment – Part 1: Common requirements*

IEC 60255-21-1, *Electrical relays – Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Section One: Vibration tests (sinusoidal)*

IEC 60255-26, *Measuring relays and protection equipment – Part 26: Electromagnetic compatibility requirements*

IEC 60255-27, *Measuring relays and protection equipment – Part 27: Product safety requirements*

IEC 61672-1, *Electroacoustics – Sound level meters – Part 1: Specifications*

2.2 IEEE references

IEEE Std 4™, *IEEE Standard Techniques for High-Voltage Testing*

IEEE Std C37.90.1™, *IEEE Standard Surge Withstand Capability (SWC) Tests for Relays and Relay Systems Associated with Electric Power Apparatus*

IEEE Std C37.90.2™, *IEEE Standard for Withstand Capability of Relay Systems to Radiated Electromagnetic Interference from Transceivers*

IEEE Std C37.90.3™, *IEEE Standard Electrostatic Discharge Tests for Protective Relays*

IEEE Std C57.12.31™, *IEEE Standard for Pole-Mounted Equipment – Enclosure Integrity*

IEEE Std C57.19.00™, *IEEE Standard General Requirements and Test Procedure for Outdoor Power Apparatus Bushings*

IEEE Std C57.91™, *IEEE Guide for Loading Mineral-Oil-Immersed Transformers*

2.3 SAE references

SAE AS50151, *General specification for connectors, electrical, circular threaded, AN type*²

² SAE (Society of Automotive Engineers) international publications are available from SAE, 400 Commonwealth Drive, Warrendale, PA 15096, USA (<http://sae.org/>).