

This is a preview - click here to buy the full publication



IEC 60287-1-2

Edition 2.0 2023-05

INTERNATIONAL STANDARD

**Electric cables – Calculation of the current rating –
Part 1-2: Current rating equations (100 % load factor) and calculations of losses –
Sheath eddy current loss factors for two circuits in flat formation**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.060.20

ISBN 978-2-8322-6972-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Normative references	5
3 Terms, definitions and symbols.....	5
3.1 Terms and definitions.....	5
3.2 Symbols.....	6
4 Description of method.....	7
4.1 General.....	7
4.2 Outline of method	7
4.3 Criteria for use of formulae and coefficients	8
5 Formulae for sheath loss factors for high-resistance sheaths in a single circuit, λ_{0S}	8
6 Calculation of the coefficients C_H , C_N and C_J	9
6.1 Allocation of coefficients to each cable, time sequence and phase identification	9
6.2 Calculation of coefficients C_H (1, 2 and 3), Table 1.....	10
6.3 Calculation of coefficients C_N (1, 2, 3, 4, 5 and 6), Table 2	11
6.4 Calculation of coefficients C_J (1, 2, 3, 4, 5 and 6), Table 3 to Table 11.....	11
6.5 Calculation of coefficients G_S and g_S	13
7 Notes on transposition of cables	14
8 Worked examples of calculation of eddy current losses	14
8.1 Overview	14
8.2 Example 1.....	14
8.3 Example 2.....	16
Bibliography.....	30
Figure 1 – Cable configuration	8
Table 1 – C_H coefficients	19
Table 2 – C_N coefficients	20
Table 3 – C_J coefficients.....	21
Table 4 – C_J coefficients.....	22
Table 5 – C_J coefficients.....	23
Table 6 – C_J coefficients.....	24
Table 7 – C_J coefficients.....	25
Table 8 – C_J coefficients.....	26
Table 9 – C_J coefficients.....	27
Table 10 – C_J coefficients.....	28
Table 11 – C_J coefficients.....	29

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

Part 1-2: Current rating equations (100 % load factor) and calculation of losses – Sheath eddy current loss factors for two circuits in flat formation

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60287-1-2 has been prepared by IEC technical committee 20: Electric cables. It is an International Standard.

This second edition cancels and replaces the first edition published in 1993. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the symbols have been harmonized and aligned with the symbols used in the IEC 60287 and IEC 60853 series.

The text of this International Standard is based on the following documents:

Draft	Report on voting
20/2097/FDIS	20/2104/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 60287 series, published under the general title *Electric cables – Calculation of the current rating*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

Part 1-2: Current rating equations (100 % load factor) and calculation of losses – Sheath eddy current loss factors for two circuits in flat formation

1 Scope

This part of IEC 60287 provides a method for calculating the eddy current losses in the metallic sheaths of single-core cables arranged as a three-phase double circuit in flat formation. The sheaths are bonded at one point or are cross-bonded so that there are no significant sheath circulating currents. Where metallic sheaths are bonded at both ends there are significant circulating currents which result in a lower current-carrying capacity. A method of calculating circulating current losses for double circuits is provided in IEC 60287-1-3.

The method described in this document provides coefficients which are applied as corrections to the loss factors for the sheaths of one isolated three-phase circuit. These corrections are negligible for cables where the parameter m is less than approximately 0,1 ($m = \omega l(R_s \cdot 10^7)$), which corresponds to a sheath longitudinal resistance higher than 314 $\mu\Omega/m$ at 50 Hz.

Consequently, the method is used for most sizes of aluminium-sheathed cables, but is not required for lead-sheathed cables unless they are unusually large.

The coefficients are provided in tabular form and have been computed from fundamental formulae for sheath losses, the evaluation of which calls for expertise in computer programming which will possibly not be readily available in general commercial situations. The development of simplified formulae for some of the tabulated coefficients is under consideration.

Losses for cables in a single circuit is covered in IEC 60287-1-1.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60287-1-1:2023, *Electric cables – Calculation of the current rating – Part 1-1: Current rating equations (100 % load factor) and calculation of losses – General*