

This is a preview - click here to buy the full publication



IEC 60364-7-721

Edition 2.0 2017-06

INTERNATIONAL STANDARD

**Low-voltage electrical installations –
Part 7-721: Requirements for special installations or locations – Electrical
installations in caravans and motor caravans**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.020; 91.140.50

ISBN 978-2-8322-4425-8

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
721 Electrical installations in caravans and motor caravans	7
721.1 Scope	7
721.2 Normative references	7
721.3 Terms and definitions.....	8
721.31 Purposes, supplies and structure	8
721.313 Supplies.....	8
721.4 Protection for safety.....	9
721.41 Protection against electric shock.....	9
721.411 Protective measure: automatic disconnection of supply.....	9
721.413 Protective measure: electrical separation	9
721.414 Protective measure: extra-low voltage provided by SELV and PELV.....	9
721.415 Additional protection	9
721.43 Protection against overcurrent	10
721.5 Selection and erection of equipment	10
721.51 Common rules.....	10
721.510 Introduction.....	10
721.512 Operational conditions and external influences	10
721.514 Identification	10
721.52 Wiring systems.....	10
721.521 Types of wiring systems	10
721.522 Selection and erection of wiring systems in relation to external influences	11
721.524 Cross-sectional areas of conductors	11
721.526 Electrical connections	11
721.528 Proximity of wiring systems to other services	11
721.53 Isolation, switching and control	12
721.536 Isolation and switching.....	12
721.54 Earthing arrangements and protective conductors.....	12
721.543 Protective conductors.....	12
721.55 Other equipment	12
Annex A (normative) Instructions for electricity supply	14
Annex B (informative) Extra low-voltage DC installations	15
Annex C (informative) Current-carrying capacities	21
Annex D (informative) List of notes concerning certain countries	24
Bibliography.....	25
Figure C.721.1 – Graph for obtaining minimum cross-sectional area for conductors for fixed wiring installations with a voltage drop of 0,8 V	21
Figure C.721.2 – Graph for obtaining minimum cross-sectional area for conductors for battery cable installations with a voltage drop of 0,3 V	22

Table 721.1 – Cross-sectional areas of flexible cords and cables for caravan connection 13

Table B.721.1 – Functional allocation and cross-sectional areas of cores for caravan connectors 18

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 7-721: Requirements for special installations or locations – Electrical installations in caravans and motor caravans

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60364-7-721 has been prepared by IEC technical committee 64: Electrical installations and protection against electrical shock.

This second edition cancels and replaces the first edition published in 2007. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) A minimum height of not less than 500 mm above the base of the cylinders is now required for cables passing through the gas cylinder compartment. Where cables have to run through a compartment such cables shall be protected against mechanical damage by installation within a continuous conduit or duct passing through the compartment (721.528.3.1).

- b) It is now required that each independent installation shall be provided with its own main isolating switch which shall disconnect all live conductors and which shall be suitably placed in a readily accessible location in the caravan.(721.536.2.1.1)
- c) The clause numbers for the protective measures not permitted (obstacles, placing out of reach, non-conducting locations and earth-free local equipotential bonding) have been changed.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
64/2200/FDIS	64/2210/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60364 series, published under the general title *Low-voltage electrical installations*, can be found on the IEC website.

The reader's attention is drawn to the fact that Annex D lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this standard.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

For the purpose of this part (IEC 60364-7-721) the requirements of the general Parts 1 to 6 of IEC 60364 apply.

The IEC 60364-7-7XX parts of IEC 60364 contain particular requirements for special installations or locations which are based on the requirements of the general parts of IEC 60364 (IEC 60364-1 to IEC 60364-6). These IEC 60364-7-7XX parts are considered in conjunction with the requirements of the general parts.

The particular requirements of this part of IEC 60364 supplement, modify or replace certain of the requirements of the general parts of IEC 60364 being valid at the time of publication of this part. The absence of reference to the exclusion of a part or a clause of a general part means that the corresponding clauses of the general part are applicable (undated reference).

Requirements of other 7XX parts being relevant for installations covered by this part also apply. This part may therefore also supplement, modify or replace certain of these requirements valid at the time of publication of this part.

The clause numbering of this part follows the pattern and corresponding references of IEC 60364. The numbers following the particular number of this part are those of the corresponding parts, or clauses of the other parts of the IEC 60364 series, valid at the time of publication of this part, as indicated in the normative references of this document (dated reference).

If requirements or explanations additional to those of the other parts of the IEC 60364 series are needed, the numbering of such items appears as 721.101, 721.102, 721.103 etc.

In the case where new or amended general parts with modified numbering were published after this part was issued, the clause numbers referring to a general part in this 721 part may no longer align with the latest edition of the general part. Dated references should be observed.

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 7-721: Requirements for special installations or locations – Electrical installations in caravans and motor caravans

721 Electrical installations in caravans and motor caravans

721.1 Scope

The particular requirements of this part of IEC 60364 apply to electrical installations in caravans and motor caravans.

They apply to those electrical circuits and equipment intended for the use of the caravan for habitation purposes.

They do not apply to those electrical circuits and equipment for automotive purposes.

They do not apply to the electrical installations of mobile homes, residential park homes and transportable units.

NOTE 1 For mobile homes and residential park homes the general requirements apply.

NOTE 2 For transportable units see IEC 60364-7-717.

NOTE 3 For the purposes of this document, caravans and motor caravans are referred to as “caravans”

The particular requirements of some parts from the IEC 60364-7 series can also apply to such installations in caravans, for example IEC 60364-7-701.

721.2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies

IEC 60038, *IEC standard voltages*

IEC 60309-2, *Plugs, socket-outlets and couplers for industrial purposes – Part 2: Dimensional interchangeability requirements for pin and contact-tube accessories*

IEC 60332-1-2, *Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame*

IEC 60947-2, *Low-voltage switchgear and controlgear – Part 2: Circuit-breakers*

IEC 61008-1, *Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs) – Part 1: General rules*

IEC 61009-1, *Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs) – Part 1: General rules*

IEC 61084 (all parts), *Cables trunking and ducting systems for electrical installations*

IEC 61386 (all parts), *Conduit systems for cable management*

IEC 62423, *Type F and Type B residual current operated circuit-breakers with and without integral overcurrent protection for household and similar uses*