

This is a preview - click here to buy the full publication



IEC 61158-6-3

Edition 4.0 2019-06

# INTERNATIONAL STANDARD

---

**Industrial communication networks – Fieldbus specifications –  
Part 6-3: Application layer protocol specification – Type 3 elements**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 25.040.40; 35.100.70; 35.110

ISBN 978-2-8322-7008-0

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	14
INTRODUCTION.....	16
1 Scope.....	17
1.1 General.....	17
1.2 Specifications .....	18
1.3 Conformance .....	18
2 Normative references .....	18
3 Terms, definitions, abbreviations, symbols and conventions .....	19
3.1 Referenced terms and definitions.....	19
3.1.1 ISO/IEC 7498-1 terms.....	19
3.1.2 ISO/IEC 8822 terms.....	19
3.1.3 ISO/IEC 9545 terms.....	19
3.1.4 ISO/IEC 8824-1 terms.....	20
3.1.5 Fieldbus Data Link Layer terms .....	20
3.2 Additional definitions.....	20
3.3 Abbreviations and symbols .....	23
3.4 Conventions.....	25
3.4.1 General concept .....	25
3.4.2 Abstract syntax conventions .....	25
3.4.3 Convention for the encoding of reserved bits and octets .....	26
3.4.4 Conventions for the common coding s of specific field octets.....	26
3.5 Conventions used in state machines .....	27
3.5.1 State machine conventions .....	27
4 FAL syntax description .....	29
4.1 APDU abstract syntax.....	29
4.2 Data types .....	34
4.2.1 Notation for the Boolean type .....	34
4.2.2 Notation for the Integer type .....	34
4.2.3 Notation for the Unsigned type .....	34
4.2.4 Notation for the Floating Point type.....	35
4.2.5 Notation for the OctetString type.....	35
4.2.6 Notation for VisibleString type .....	35
4.2.7 Notation for BinaryDate type.....	35
4.2.8 Notation for TimeOfDay type.....	35
4.2.9 Notation for TimeDifference type .....	35
4.2.10 Notation for Network Time type.....	35
4.2.11 Notation for Network Time Difference type.....	35
5 Transfer syntax.....	35
5.1 Coding of basic data types.....	35
5.1.1 Encoding of a Boolean value .....	35
5.1.2 Encoding of an Integer value .....	36
5.1.3 Encoding of an Unsigned value.....	36
5.1.4 Encoding of a Floating-Point value .....	36
5.1.5 Encoding of a Visible String value.....	36
5.1.6 Encoding of an Octet String value.....	36
5.1.7 Encoding of a BinaryDate value .....	36

5.1.8	Encoding of a TimeOfDay with and without date indication value .....	36
5.1.9	Encoding of a Time Difference with and without date indication value .....	37
5.1.10	Encoding of a Network Time value .....	37
5.1.11	Encoding of a Network Time Difference value .....	37
5.1.12	Encoding of a Null value .....	37
5.2	Coding section related to data exchange PDUs .....	37
5.2.1	General .....	37
5.2.2	Coding of the field Outp_Data .....	37
5.2.3	Coding of the field Inp_Data .....	37
5.3	Coding section related to slave diagnosis PDUs .....	37
5.3.1	Coding of the field Station_status_1 .....	37
5.3.2	Coding of the field Station_status_2 .....	38
5.3.3	Coding of the field Station_status_3 .....	39
5.3.4	Coding of the field Diag_Master_Add .....	39
5.3.5	Coding of the field Ident_Number .....	39
5.3.6	Coding of the field Header_Octet .....	39
5.3.7	Coding of the field Alarm_Type .....	40
5.3.8	Coding of the field Status_Type .....	41
5.3.9	Coding of the field Slot_Number .....	41
5.3.10	Coding of the field Alarm_Specifier .....	41
5.3.11	Coding of the field Status_Specifier .....	42
5.3.12	Coding of the field Diagnosis_User_Data .....	43
5.3.13	Coding of the field Modul_Status_Array .....	43
5.3.14	Coding of the field Identifier_Diagnosis_Data_Array .....	44
5.3.15	Coding of the field Identifier_Number .....	45
5.3.16	Coding of the field Channel_Number .....	45
5.3.17	Coding of the field Type_of_Diagnosis .....	46
5.3.18	Coding of the field Revision_Number .....	46
5.3.19	Coding of the field Publisher_Address .....	47
5.3.20	Coding of the field Publisher_Status .....	47
5.3.21	Coding of the field RedSpecifier .....	47
5.3.22	Coding of the field Function .....	47
5.3.23	Coding of the field Red_Status1 .....	48
5.3.24	Coding of the field Red_Status2 .....	48
5.3.25	Coding of the field Red_Status3 .....	49
5.4	Coding section related to parameterization PDU .....	49
5.4.1	Coding of the field Station_status .....	49
5.4.2	Coding of the field WD_Fact_1 .....	50
5.4.3	Coding of the field WD_Fact_2 .....	50
5.4.4	Coding of the field min_T <sub>SDR</sub> .....	50
5.4.5	Coding of the field Group_Ident .....	50
5.4.6	Coding of the field User_Prm_Data_Element .....	51
5.4.7	Coding of the field DPV1_Status_1 .....	51
5.4.8	Coding of the field DPV1_Status_2 .....	52
5.4.9	Coding of the field DPV1_Status_3 .....	52
5.4.10	Coding of the field Structure_Length .....	53
5.4.11	Coding of the field Structure_Type .....	53
5.4.12	Coding of the field Version .....	53
5.4.13	Coding of the field Publisher_Addr .....	54

5.4.14	Coding of the field Publisher_Length .....	54
5.4.15	Coding of the field Sample_Offset .....	54
5.4.16	Coding of the field Sample_Length .....	54
5.4.17	Coding of the field Dest_Slot_Number .....	54
5.4.18	Coding of the field Offset_Data_Area .....	54
5.4.19	Coding of the field T <sub>BASE_DP</sub> .....	54
5.4.20	Coding of the field T <sub>DP</sub> .....	55
5.4.21	Coding of the field T <sub>MAPC</sub> .....	55
5.4.22	Coding of the field T <sub>BASE_IO</sub> .....	55
5.4.23	Coding of the field T <sub>I</sub> .....	55
5.4.24	Coding of the field T <sub>O</sub> .....	55
5.4.25	Coding of the field T <sub>DX</sub> .....	55
5.4.26	Coding of the field T <sub>PLL_W</sub> .....	55
5.4.27	Coding of the field T <sub>PLL_D</sub> .....	55
5.4.28	Coding of the field Specifier .....	55
5.4.29	Coding of the field Function .....	55
5.4.30	Coding of the field Properties .....	56
5.4.31	Coding of the field Output Hold Time .....	56
5.4.32	Coding of the field Clock Sync Interval .....	56
5.4.33	Coding of the field CS Delay Time .....	56
5.5	Coding section related to configuration PDUs .....	57
5.5.1	Coding of the field Cfg_Identifier .....	57
5.5.2	Coding of the field Special_Cfg_Identifier .....	57
5.5.3	Coding of the fields Length_Octet .....	58
5.5.4	Coding of the field Manufacturer_Specific_Data .....	58
5.5.5	Coding of the field Extended_Length_Octet .....	58
5.5.6	Coding of the field Data_Type .....	59
5.6	Coding section related to global control PDUs .....	59
5.6.1	Coding of the field Control_Command .....	59
5.6.2	Coding of the field Group_Select .....	60
5.7	Coding section related to clock-value-PDUs .....	61
5.7.1	Coding of the field Clock_value_time_event .....	61
5.7.2	Clock_value_previous_TE .....	61
5.7.3	Coding of the field Clock_value_status1 .....	61
5.7.4	Coding of the field Clock_value_status2 .....	61
5.8	Coding section related to function identification and errors .....	62
5.8.1	Coding of the field Function_Num .....	62
5.8.2	Coding of the field Error Decode .....	64
5.8.3	Coding of the field Error_Code_1 .....	64
5.8.4	Coding of the field Error_Code_2 .....	65
5.9	Coding section related to master diagnosis PDU .....	65
5.9.1	Coding of the field MDiag_Identifier .....	65
5.9.2	Coding of the field System_Diagnosis .....	66
5.9.3	Coding of the field USIF_State .....	66
5.9.4	Coding of the field Hardware_Release_DP .....	67
5.9.5	Coding of the field Firmware_Release_DP .....	67
5.9.6	Coding of the field Hardware_Release_User .....	67
5.9.7	Coding of the field Firmware_Release_User .....	67
5.9.8	Coding of the field Data_Transfer_List .....	67

5.10	Coding section related to upload/download/act para PDUs.....	68
5.10.1	Coding of the field Area_Code_UpDownload .....	68
5.10.2	Coding of the field Timeout.....	68
5.10.3	Coding of the field Max_Len_Data_Unit.....	68
5.10.4	Coding of the field Add_Offset.....	68
5.10.5	Coding of the field Data .....	68
5.10.6	Coding of the field Data_Len .....	68
5.10.7	Coding of the field Area_CodeActBrct.....	69
5.10.8	Coding of the field Area_CodeAct.....	69
5.10.9	Coding of the field Activate.....	69
5.11	Coding section related to the bus parameter set .....	70
5.11.1	Coding of the field Bus_Para_Len.....	70
5.11.2	Coding of the field DL_Add.....	70
5.11.3	Coding of the field Data_rate .....	70
5.11.4	Coding of the fields T <sub>SL</sub> , min T <sub>SDR</sub> , max T <sub>SDR</sub> .....	70
5.11.5	Coding of the fields T <sub>QUI</sub> , T <sub>SET</sub> , G, HSA, max_retry_limit .....	71
5.11.6	Coding of the field T <sub>TR</sub> (Target Token Rotation time).....	71
5.11.7	Coding of the field Bp_Flag (Busparameter flag).....	71
5.11.8	Coding of the field Min_Slave_Interval.....	71
5.11.9	Coding of the field Poll_Timeout.....	71
5.11.10	Coding of the field Data_Control_Time .....	71
5.11.11	Coding of the field Alarm_Max .....	71
5.11.12	Coding of the field Max_User_Global_Control.....	72
5.11.13	Coding of the field Master_User_Data_Len.....	72
5.11.14	Coding of the field Master_Class2_Name .....	72
5.11.15	Coding of the field Master_User_Data .....	72
5.11.16	Coding of the field T <sub>CT</sub> .....	72
5.11.17	Coding of the field maxT <sub>SH</sub> .....	72
5.12	Coding section related to the slave parameter set.....	72
5.12.1	Coding of the field Slave_Para_Len.....	72
5.12.2	Coding of the field SI_Flag (slave flag) .....	72
5.12.3	Coding of the field Slave_Type .....	73
5.12.4	Coding of the field Max_Diag_Data_Len .....	73
5.12.5	Coding of the field Max_Alarm_Len .....	73
5.12.6	Coding of the field Max_Channel_Data_Length .....	73
5.12.7	Coding of the field Diag_Upd_Delay .....	74
5.12.8	Coding of the field Alarm_Mode .....	74
5.12.9	Coding of the field Add_SI_Flag.....	74
5.12.10	Coding of the field MS1_Timeout .....	74
5.12.11	Coding of the field Prm_Data_Len .....	74
5.12.12	Coding of the field Prm_Data.....	74
5.12.13	Coding of the field Cfg_Data_Len .....	75
5.12.14	Coding of the field Cfg_Data.....	75
5.12.15	Coding of the field Add_Tab_Len.....	75
5.12.16	Coding of the field Number_of_Entries.....	75
5.12.17	Coding of the field Add_Tab_Entry_Header .....	75
5.12.18	Coding of the field I/O_Data_Length .....	75
5.12.19	Coding of the field I/O_Config_Address .....	75
5.12.20	Coding of the field Host_Address.....	75

5.12.21	Coding of the field Slave_User_Data_Len.....	76
5.12.22	Coding of the field Slave_User_Data .....	76
5.12.23	Coding of the field Ext_Prm_Data_Len .....	76
5.12.24	Coding of the field Ext_Prm_Data .....	76
5.13	Coding section related to statistic counters .....	76
5.13.1	Coding of the field DLPDU_sent_count and SD_count .....	76
5.13.2	Coding of the field Error_count and SD_error_count .....	76
5.14	Coding section related to set slave address PDU .....	76
5.14.1	Coding of the field New_Slave_Add .....	76
5.14.2	Coding of the field No_Add_Change .....	76
5.14.3	Coding of the field Rem_Slave_Data .....	76
5.15	Coding section related to initiate/abort PDUs .....	77
5.15.1	Coding of the field Features_Supported_1 .....	77
5.15.2	Coding of the field Features_Supported_2 .....	77
5.15.3	Coding of the field Profile_Features_Supported_1 .....	77
5.15.4	Coding of the field Profile_Features_Supported_2 .....	77
5.15.5	Coding of the field Profile_Ident_Number.....	77
5.15.6	Coding of the field S_Type (source type) .....	77
5.15.7	Coding of the field D_Type (destination type) .....	77
5.15.8	Coding of the field S_Len (source length) .....	78
5.15.9	Coding of the field D_Len (destination length) .....	78
5.15.10	Coding of the field S_API (source application identifier).....	78
5.15.11	Coding of the field D_API (destination application identifier) .....	78
5.15.12	Coding of the field S_SCL (source security level) .....	78
5.15.13	Coding of the field D_SCL (destination security level).....	78
5.15.14	Coding of the field S_Network_Address .....	78
5.15.15	Coding of the field D_Network_Address.....	78
5.15.16	Coding of the field S_MAC_Address .....	78
5.15.17	Coding of the field D_MAC_Address .....	78
5.15.18	Coding of the field Send_Timeout .....	78
5.15.19	Coding of the field Server_SAP .....	78
5.15.20	Coding of the field Subnet .....	79
5.15.21	Coding of the field Instance_Reason_Code .....	79
5.16	Coding section related to read/write/data transport PDUs .....	80
5.16.1	Coding of the field Index.....	80
5.16.2	Coding of the field Length.....	80
5.17	Coding section related to load region and function invocation PDUs .....	80
5.17.1	Coding of the field Extended_Function_Num .....	80
5.17.2	Coding of the field Options .....	80
5.17.3	Coding of the field Sequence_Number.....	81
5.17.4	Coding of the field LR_Data.....	81
5.17.5	Coding of the field Max_Segment_Length.....	81
5.17.6	Coding of the field LR_Index.....	81
5.17.7	Coding of the field LR_Length.....	81
5.17.8	Coding of the field Max_Response_Delay.....	81
5.17.9	Coding of the field Intersegment_Request_Timeout .....	81
5.17.10	Coding of the field User_Specific .....	81
5.17.11	Coding of the field FI_Index.....	81
5.17.12	Coding of the field Entity Number .....	82

5.17.13	Coding of the field Execution_Argument .....	82
5.17.14	Coding of the field Result_Argument.....	82
5.17.15	Coding of the field FI_State .....	82
5.17.16	Coding of the field IMData_Execution_Argument .....	83
5.17.17	Coding of the field IMData_Result_Argument.....	83
5.18	Examples of Diagnosis-RES-PDUs .....	84
5.19	Example of Chk_Cfg-REQ-PDU .....	86
5.20	Examples of Chk_Cfg-REQ-PDUs with DPV1 data types.....	86
5.21	Example structure of the Data_Unit for Data_Exchange .....	88
6	FAL protocol state machines .....	90
6.1	Overall structure .....	90
6.1.1	Fieldbus Service Protocol Machines (FSPM).....	90
6.1.2	Master to Slave cyclic (MS0) .....	90
6.1.3	Master (class 1) to Slave acyclic (MS1) .....	90
6.1.4	Master (class 2) to Slave acyclic (MS2) .....	90
6.1.5	Master to Slave clock synchronisation (MS3).....	90
6.1.6	Master Master acyclic (MM1/MM2).....	91
6.1.7	DLL Mapping Protocol Machines (DMPM).....	91
6.2	Assignment of state machines to devices .....	91
6.3	Overview DP-slave .....	92
6.4	Overview DP-master (class 1).....	93
6.5	Overview DP-master (class 2).....	94
6.6	Cyclic communication between DP-master (class 1) and DP-slave.....	95
6.7	Acyclic communication between DP-master (class 2) and DP-master (class 1).....	97
6.8	Acyclic communication between DP-master (class 1) and DP-slave .....	99
6.9	Application relationship monitoring.....	101
6.9.1	Monitoring of the MS0 – AR .....	101
6.9.2	Monitoring of the MS2 – AR .....	102
7	AP-context state machine .....	106
8	FAL service protocol machines (FSPMs) .....	107
8.1	FSPMS .....	107
8.1.1	Primitive definitions .....	107
8.1.2	State machine description.....	112
8.1.3	FSPMS state table .....	115
8.1.4	Functions.....	141
8.2	FSPMM1 .....	142
8.2.1	Primitive definitions .....	142
8.2.2	State machine description.....	148
8.2.3	FSPMM1 state table .....	151
8.2.4	Functions.....	177
8.3	FSPMM2.....	177
8.3.1	Primitive definitions .....	177
8.3.2	State machine description.....	182
8.3.3	FSPMM2 state table .....	182
8.3.4	Functions.....	194
9	Application relationship protocol machines (ARPMs) .....	195
9.1	MSCY1S .....	195
9.1.1	Primitive definitions .....	195

9.1.2	State machine description.....	196
9.1.3	MSCY1S state table .....	202
9.1.4	Functions.....	222
9.2	MSAC1S .....	225
9.2.1	Primitive definitions .....	225
9.2.2	State machine description.....	227
9.2.3	MSAC1S state table .....	228
9.2.4	Functions.....	237
9.3	SSCY1S .....	238
9.3.1	Primitive definitions .....	238
9.3.2	State machine description.....	239
9.3.3	SSCY1S state table .....	239
9.3.4	Functions.....	241
9.4	MSRM2S .....	241
9.4.1	Primitive definitions .....	241
9.4.2	State machine description.....	242
9.4.3	MSRM2S state table .....	245
9.5	MSAC2S .....	247
9.5.1	Primitive definitions .....	247
9.5.2	State machine description.....	250
9.5.3	MSAC2S state table .....	252
9.6	MSCS1S .....	264
9.6.1	Primitive definitions .....	264
9.6.2	State machine description.....	264
9.6.3	MSCS1S state table .....	265
9.7	MSCY1M .....	266
9.7.1	Primitive definitions .....	266
9.7.2	State machine description.....	268
9.7.3	MSCY1M state table .....	270
9.8	MSAL1M .....	284
9.8.1	Primitive definitions .....	284
9.8.2	State machine description.....	286
9.8.3	MSAL1M state table .....	289
9.9	MSAC1M .....	294
9.9.1	Primitive definitions .....	294
9.9.2	State machine description.....	295
9.9.3	MSAC1M state table .....	301
9.10	MMAC1.....	306
9.10.1	Primitive definitions .....	306
9.10.2	State machine description.....	308
9.10.3	MMAC1 state table .....	308
9.11	MSCS1M .....	313
9.11.1	Primitive definitions .....	313
9.11.2	State machine description.....	314
9.11.3	MSCS1M state table .....	315
9.12	MSAC2M .....	318
9.12.1	Primitive definitions .....	318
9.12.2	State machine description.....	320
9.12.3	MSAC2M state table .....	323



9.13	MMAC2.....	333
9.13.1	Primitive definitions .....	333
9.13.2	State machine description.....	334
9.13.3	MMAC2 state table .....	335
10	DLL mapping protocol machines (DMPMs) .....	340
10.1	DMPMS .....	340
10.1.1	Primitive definitions .....	340
10.1.2	State machine description.....	346
10.1.3	DMPMS state table .....	346
10.1.4	Functions.....	352
10.2	DMPMM1 .....	353
10.2.1	Primitive definitions .....	353
10.2.2	State machine description.....	360
10.2.3	DMPMM1 state table .....	361
10.2.4	Functions.....	368
10.3	DMPMM2 .....	369
10.3.1	Primitive definitions .....	369
10.3.2	State machine description.....	373
10.3.3	DMPMM2 state table .....	373
10.3.4	Functions.....	376
11	Parameters for a DP-slave.....	377
	Bibliography.....	378
	Figure 1 – Common structure of specific fields.....	26
	Figure 2 – Example Modul_Status_Array .....	44
	Figure 3 – Example of Ext_Diag_Data in case of DPV1 diagnosis format with alarm and status PDU.....	84
	Figure 4 – Example of Ext_Diag_Data in case of the basic diagnosis format .....	86
	Figure 5 – Example of a special identifier format.....	86
	Figure 6 – Example of a special identifier format with data types .....	87
	Figure 7 – Example of a special identifier format with data types .....	87
	Figure 8 – Example of an empty slot with data types.....	88
	Figure 9 – Example for multi-variable device with AI and DO function blocks .....	88
	Figure 10 – Identifiers (ID).....	89
	Figure 11 – Identifier list .....	89
	Figure 12 – Structure of the Data_Unit for the request- and response-DLPPDU .....	89
	Figure 13 – Structuring of the protocol machines and adjacent layers in a DP-slave .....	93
	Figure 14 – Structuring of the protocol machines and adjacent layers in a DP-master (class 1).....	94
	Figure 15 – Structuring of the protocol machines and adjacent layers in a DP-master (class 2).....	95
	Figure 16 – Sequence of the communication between DP-master and DP-slave .....	97
	Figure 17 – Sequence of communication between DP-master (class 2) and DP-master (class 1).....	99
	Figure 18 – Sequence of acyclic communication between DP-master (class 1) and DP-slave.....	101
	Figure 19 – Example for connection establishment on MS2.....	104

Figure 20 – Idle at master-side on MS2.....	105
Figure 21 – Idle at slave-side on MS2 .....	106
Figure 22 – Example for connection establishment on MS2(server-side).....	243
Figure 23 – Structure of RM entries in the RM_Registry.....	244
Table 1 – State machine description elements .....	27
Table 2 – Description of state machine elements .....	27
Table 3 – Conventions used in state machines .....	28
Table 4 – APDU syntax.....	30
Table 5 – Substitutions .....	32
Table 6 – Block_Length for Selection:= 0 .....	39
Table 7 – Block_Length for Selection:= 1 .....	40
Table 8 – Block_Length for Selection:= 2 .....	40
Table 9 – Block_Length for Selection:= 3.....	40
Table 10 – Selection range .....	40
Table 11 – Alarm_Type range .....	41
Table 12 – Status_Type value range .....	41
Table 13 – Alarm_Specifier .....	42
Table 14 – Additional_Acknowledge.....	42
Table 15 – Status_Specifier .....	42
Table 16 – Range of Modul_Status_Entry (1-4).....	44
Table 17 – Input_Output_Selection .....	46
Table 18 – Error type .....	46
Table 19 – Channel_Type .....	46
Table 20 – Specification of the bits Lock_Req and Unlock_Req .....	50
Table 21 – Range of Length_of_Manufacturer_Specific_Data if used in Chk_Cfg-REQ-PDU.....	57
Table 22 – Range of Length_of_Manufacturer_Specific_Data if used in Get_Cfg-RES-PDU .....	58
Table 23 – Input_Output_Selection .....	58
Table 24 – Data types.....	59
Table 25 – Specification of the bits for Un-/Freeze.....	60
Table 26 – Specification of the bits for Un-/Sync.....	60
Table 27 – Coding of the Function_Code/ Function_Num.....	62
Table 28 – Coding of the Error_Code / Function_Num .....	63
Table 29 – Values of Error_Decode .....	64
Table 30 – Coding of Error_Code_1 at DPV1.....	65
Table 31 – Values of MDiag_Identifier .....	66
Table 32 – Values for Area_Code_UpDownload.....	68
Table 33 – Values for Area_CodeActBrct.....	69
Table 34 – Values for Area_CodeAct .....	69
Table 35 – Values for Activate .....	70
Table 36 – Values for Data_rate .....	70
Table 37 – DPV1_Data_Types .....	73

Table 38 – Values for Slave_Type .....	73
Table 39 – Values for Alarm_Mode .....	74
Table 40 – Values for Subnet.....	79
Table 41 – Values of reason code if instance is DLL .....	79
Table 42 – Values of reason code if instance is MS2 .....	79
Table 43 – Values of Extended_Function_Num .....	80
Table 44 – Values of FI_Index .....	82
Table 45 – Values of FI_State.....	82
Table 46 – IMData_Execution_Argument .....	83
Table 47 – IMData_Result_Argument.....	83
Table 48 – Assignment of state machines .....	92
Table 49 – Primitives issued by AP-Context to FSPMS .....	107
Table 50 – Primitives issued by FSPMS to AP-Context .....	109
Table 51 – FSPMS state table .....	116
Table 52 – Functions used by the FSPMS.....	141
Table 53 – Primitives issued by AP-Context to FSPMM1.....	142
Table 54 – Primitives issued by FSPMM1 to AP-Context.....	145
Table 55 – FSPMM1 state table .....	151
Table 56 – Functions used by the FSPMM1 .....	177
Table 57 – Primitives issued by AP-Context to FSPMM2.....	177
Table 58 – Primitives issued by FSPMM2 to AP-Context.....	179
Table 59 – FSPMM2 state table .....	182
Table 60 – Functions used by the FSPMM2 .....	194
Table 61 – Primitives issued by FSPMS to MSCY1S.....	195
Table 62 – Primitives issued by MSCY1S to FSPMS.....	195
Table 63 – Rules for DPV1_Status_1, DPV1_Status_2 and DPV1_Status_3 check .....	197
Table 64 – MSCY1S state table .....	202
Table 65 – Functions used by the MSCY1S .....	223
Table 66 – Primitives issued by FSPMS to MSAC1S.....	225
Table 67 – Primitives issued by MSAC1S to FSPMS.....	226
Table 68 – Primitives issued by MSCY1S to MSAC1S.....	226
Table 69 – Primitives issued by MSAC1S to MSCY1S.....	226
Table 70 – Parameter used with primitives exchanged between MSAC1S and MSCY1S .....	227
Table 71 – MSAC1S state table .....	228
Table 72 – Functions used by the MSAC1S .....	238
Table 73 – Primitives issued by FSPMS to SSCY1S .....	238
Table 74 – Primitives issued by SSCY1S to FSPMS .....	238
Table 75 – SSCY1S state table.....	240
Table 76 – Functions used by the SSCY1S.....	241
Table 77 – Primitives issued by FSPMS to MSRM2S .....	241
Table 78 – Primitives issued by MSRM2S to FSPMS .....	242
Table 79 – MSRM2S state table.....	245
Table 80 – Primitives issued by FSPMS to MSAC2S.....	248

Table 81 – Primitives issued by MSAC2S to FSPMS .....	249
Table 82 – Primitives issued by MSRM2S to MSAC2S .....	249
Table 83 – Primitives issued by MSAC2S to MSRM2S .....	250
Table 84 – Parameter used with primitives exchanged with MSAC2S.....	250
Table 85 – MSAC2S state table .....	253
Table 86 – Primitives issued by MSCS1S to FSPMS .....	264
Table 87 – MSCS1S state table .....	265
Table 88 – Primitives issued by FSPMM1 to MSCY1M .....	266
Table 89 – Primitives issued by MSCY1M to FSPMM1 .....	267
Table 90 – Parameters used with primitives exchanged between FSPMM1 and MSCY1M .....	267
Table 91 – MSCY1M state table.....	270
Table 92 – Primitives issued by FSPMM1 to MSAL1M .....	285
Table 93 – Primitives issued by MSAL1M to FSPMM1 .....	285
Table 94 – Primitives issued by MSCY1M to MSAL1M .....	285
Table 95 – Primitives issued by MSAL1M to MSCY1M .....	285
Table 96 – Parameter used with primitives exchanged between MSAL1M and MSCY1M.....	286
Table 97 – Possible values in the Alarm_State_Table .....	287
Table 98 – MSAL1M state table .....	289
Table 99 – Primitives issued by FSPMM1 to MSAC1M .....	294
Table 100 – Primitives issued by MSAC1M to FSPMM1 .....	294
Table 101 – Primitives issued by MSAL1M to MSAC1M .....	295
Table 102 – Primitives issued by MSAC1M to MSAL1M .....	295
Table 103 – Parameter used with primitives exchanged between MSAL1M and MSCY1M .....	295
Table 104 – MSAC1M state table.....	301
Table 105 – Primitives issued by FSPMM1 to MMAC1 .....	307
Table 106 – Primitives issued by MMAC1 to FSPMM1 .....	307
Table 107 – MMAC1 state table .....	309
Table 108 – Primitives issued by FSPMM1 to MSCS1M .....	314
Table 109 – Primitives issued by MSCS1M to FSPMM1 .....	314
Table 110 – MSCS1M state table.....	316
Table 111 – Primitives issued by FSPMM2 to MSAC2M .....	318
Table 112 – Primitives issued by MSAC2M to FSPMM2 .....	319
Table 113 – Parameters used with primitives exchanged with MSAC2M .....	319
Table 114 – MSAC2M state table.....	323
Table 115 – Primitives issued by FSPMM2 to MMAC2 .....	333
Table 116 – Primitives issued by MMAC2 to FSPMM2 .....	334
Table 117 – Parameters used with primitives exchanged with MMAC2.....	334
Table 118 – MMAC2 state table .....	336
Table 119 – Primitives issued by FSPMS to DMPMS .....	341
Table 120 – Primitives issued by DMPMS to FSPMS .....	341
Table 121 – Primitives issued by MSCY1S to DMPMS .....	341
Table 122 – Primitives issued by DMPMS to MSCY1S .....	342

Table 123 – Primitives issued by DMPMS to SSCY1S.....	342
Table 124 – Primitives issued by MSAC1S, MSRM2S, MSAC2S to DMPMS.....	343
Table 125 – Primitives issued by DMPMS to MSAC1S, MSRM2S, MSAC2S.....	343
Table 126 – Primitives issued by DMPMS to MSCS1S .....	343
Table 127 – Primitives issued by DMPMS to DL.....	344
Table 128 – Primitives issued by DL to DMPMS.....	344
Table 129 – Parameters used with primitives exchanged with DMPMS .....	345
Table 130 – DMPMS state table.....	347
Table 131 – Functions used by the DMPMS.....	352
Table 132 – Primitives issued by FSPMM1 to DMPMM1 .....	354
Table 133 – Primitives issued by DMPMM1 to FSPMM1 .....	354
Table 134 – Primitives issued by MSCY1M to DMPMM1 .....	355
Table 135 – Primitives issued by DMPMM1 to MSCY1M .....	355
Table 136 – Primitives issued by MSAL1M, MSAC1M to DMPMM1 .....	356
Table 137 – Primitives issued by DMPMM1 to MSAL1M, MSAC1M .....	356
Table 138 – Primitives issued by MMAC1 to DMPMM1 .....	356
Table 139 – Primitives issued by DMPMM1 to MMAC1 .....	356
Table 140 – Primitives issued by MSCS1M to DMPMM1 .....	357
Table 141 – Primitives issued by DMPMM1 to MSCS1M .....	357
Table 142 – Primitives issued by DMPMM1 to DL .....	357
Table 143 – Primitives issued by DL to DMPMM1 .....	358
Table 144 – Parameters used with primitives exchanged with DMPMM1 .....	359
Table 145 – Possible values of status .....	360
Table 146 – DMPMM1 state table .....	361
Table 147 – Functions used by the DMPMM1 .....	369
Table 148 – Primitives issued by FSPMM2 to DMPMM2 .....	370
Table 149 – Primitives issued by DMPMM2 to FSPMM2 .....	370
Table 150 – Primitives issued by MSAC2M to DMPMM2 .....	371
Table 151 – Primitives issued by DMPMM2 to MSAC2M .....	371
Table 152 – Primitives issued by MMAC2 to DMPMM2 .....	371
Table 153 – Primitives issued by DMPMM2 to MMAC2 .....	371
Table 154 – Primitives issued by DMPMM2 to DL .....	372
Table 155 – Primitives issued by DL to DMPMM2 .....	372
Table 156 – Parameters used with primitives exchanged with DMPMM2.....	373
Table 157 – DMPMM2 state Table .....	373
Table 158 – Functions used by DMPMM2 .....	377
Table 159 – Bus parameter/reaction times for a DP-slave.....	377

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

#### Part 6-3: Application layer protocol specification – Type 3 elements

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-6-3 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This fourth edition cancels and replaces the third edition published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- corrected substitutions in Table 4;
- corrections in 5.3.14;
- corrections in 5.5.6;
- corrections in 5.17.15;
- corrections in 5.17.16.2;
- spelling and grammar.

The text of this International standard is based on the following documents:

FDIS	Report on voting
65C/948/FDIS	65C/956/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under <<http://webstore.iec.ch>> in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

## INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application protocol provides the application service by making use of the services available from the data-link or other immediately lower layer. The primary aim of this document is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer application entities (AEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- as a guide for implementors and designers;
- for use in the testing and procurement of equipment;
- as part of an agreement for the admittance of systems into the open systems environment;
- as a refinement to the understanding of time-critical communications within OSI.

This document is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this document together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.



## **INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –**

### **Part 6-3: Application layer protocol specification – Type 3 elements**

## **1 Scope**

### **1.1 General**

The Fieldbus Application Layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This part of IEC 61158 provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 3 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This International Standard defines in an abstract way the externally visible behavior provided by the Type 3 fieldbus application layer in terms of

- a) the abstract syntax defining the application layer protocol data units conveyed between communicating application entities,
- b) the transfer syntax defining the application layer protocol data units conveyed between communicating application entities,
- c) the application context state machine defining the application service behavior visible between communicating application entities; and
- d) the application relationship state machines defining the communication behavior visible between communicating application entities.

The purpose of this document is to define the protocol provided to

- a) define the wire-representation of the service primitives specified in IEC 61158-5-3, and
- b) define the externally visible behavior associated with their transfer.

This document specifies the protocol of the Type 3 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI Application Layer Structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented Application Service Elements (ASEs) and a Layer Management Entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can

send/receive is specified. This permits greater flexibility to the FAL users in standardizing such object behavior. In addition to these services, some supporting services are also defined in this document to provide access to the FAL to control certain aspects of its operation.

## 1.2 Specifications

The principal objective of this document is to specify the syntax and behavior of the application layer protocol that conveys the application layer services defined in IEC 61158-5-3.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of protocols standardized in parts of the IEC 61158-6 subparts.

## 1.3 Conformance

This does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

There is no conformance of equipment to the application layer service definition standard. Instead, conformance is achieved through implementation of this application layer protocol specification.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as IEC 61784-1 and IEC 61784-2 are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

IEC 61158-3-3:2014, *Industrial communication networks – Fieldbus specifications – Part 3-3: Data-link layer service definition – Type 3 elements*

IEC 61158-4-3:2019, *Industrial communication networks – Fieldbus specifications – Part 4-3: Data-link layer protocol specification – Type 3 elements*

IEC 61158-5-3:2014, *Industrial communication networks – Fieldbus specifications – Part 5-3: Application layer service definition – Type 3 elements*

IEC 61158-5-10:2019, *Industrial communication networks – Fieldbus specifications – Part 5-10: Application layer service definition – Type 10 elements*

IEC 61158-6-10:2019, *Industrial communication networks – Fieldbus specifications – Part 6-10: Application layer protocol specification – Type 10 elements*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 8822, *Information technology – Open Systems Interconnection – Presentation service definition*

ISO/IEC 8824-1, *Information technology – Abstract Syntax Notation One (ASN.1): Specification of basic notation*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

IEEE 754, *IEEE Standard for Floating-Point Arithmetic*, available at <<http://www.ieee.org>> [viewed 2018-09-10]