

This is a preview - click here to buy the full publication



IEC 61280-1-4

Edition 3.0 2023-01
REDLINE VERSION

INTERNATIONAL STANDARD



**Fibre optic communication subsystem test procedures –
Part 1-4: General communication subsystems – Light source encircled flux
measurement method**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.180.01

ISBN 978-2-8322-6399-0

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	2
0.1 — General.....
0.2 — Changes from previous edition.....
0.3 — Assumptions applicable to the characterization of data sources.....
0.4 — Assumptions applicable to the characterization of measurement sources.....
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
4 Symbols	9
5 Assumptions.....	10
5.1 Assumptions applicable to the characterization of data sources.....	10
5.2 Assumptions applicable to the characterization of measurement sources.....	10
6 Apparatus.....	10
6.1 Common apparatus.....	10
6.1.1 General	10
6.1.2 Computer.....	11
6.1.3 Image digitizer.....	11
6.1.4 Detector	11
6.1.5 Magnifying optics.....	12
6.1.6 Attenuation Attenuator	12
6.1.7 Micro positioner (optional)	13
6.1.8 Input port.....	13
6.1.9 Calibration light source.....	13
6.2 Transmission source apparatus	13
6.2.1 General	13
6.2.2 Test jumper assembly.....	14
6.2.3 Fibre shaker	14
6.3 Measurement source apparatus	15
7 Sampling and specimens.....	15
8 Geometric calibration.....	16
9 Measurement procedure	16
9.1 Safety	16
9.2 Image acquisition.....	16
9.2.1 Raw image acquisition.....	16
9.2.2 Dark image acquisition	17
9.2.3 Corrected image.....	17
9.3 Optical centre determination	17
9.3.1 General	17
9.3.2 Centroid image	17
9.3.3 Centroid computation.....	18
9.4 Test source image acquisition.....	18
10 Computation of encircled flux	19
10.1 Computation of radial data functions.....	19
10.2 Integration limit and baseline determination	21
10.2.1 Integration limit.....	21

10.2.2	Baseline determination	21
10.2.3	Baseline subtraction	21
10.3	Computation of encircled flux	21
11	Results	22
11.1	Information available with each measurement	22
11.2	Information available upon request	22
12	Specification information	22
Annex A (informative)	Measurement sensitivity considerations	24
A.1	Baseline averaging considerations	24
A.2	Pixel sensitivity variation calibration	26
A.3	Correlated double sampling	26
A.4	Imperfections of practical detectors and optics	27
Annex B (informative) Theory of geometric calibration using the micropositioner		
Annex C (normative) Procedure for geometric calibration using the micropositioner		
	Bibliography	37
	Figure 1 – Apparatus block diagram	11
	Figure 2 – Typical set-up for transmission source measurement	14
	Figure 3 – Fibre shaker example	15
	Figure 4 – Pixel and ring illustration	19
	Figure A.1 – Core images from instrument A and instrument B	24
	Figure A.2 – Compressed core images from instrument A and instrument B	25
	Figure A.3 – Intensity versus radius for instruments A and B	25

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FIBRE OPTIC COMMUNICATION SUBSYSTEM TEST PROCEDURES –

Part 1-4: General communication subsystems – Light source encircled flux measurement method

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 61280-1-4:2009. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 61280-1-4 has been prepared by subcommittee 86C: Fibre optic systems and active devices, of IEC technical committee 86: Fibre optics. It is an International Standard.

This third edition cancels and replaces the second edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) improvement of calibration procedure and calibration traceability;
- b) improvement of fibre shaker description and requirements;
- c) addition of pulsed light sources;
- d) removal of a poorly traceable calibration process using a micro positioner.

The text of this International Standard is based on the following documents:

Draft	Report on voting
86C/1806/CDV	86C/1828/RVC

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 61280 series can be found, under the general title *Fibre optic communication subsystem test procedures*, on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

0.1 — General

This part of IEC 61280 ~~is used~~ specifies how to measure the encircled flux of a multimode light source. Encircled flux is ~~a measure, as a function of radius, of the~~ fraction of the cumulative output power to the total output power ~~radiating from~~ as a function of radial distance from the centre of the multimode optical fibre's core.

The basic approach is to collect two-dimensional (2D) nearfield data, using a calibrated camera, and to mathematically convert the 2D data into three normalized functions of radial distance from the fibre's optical centre. The three functions are intensity, incremental flux, and encircled flux. ~~Intensity has dimension optical power per area; incremental flux has dimension power per differential of radius; and encircled flux has dimension total optical power, all three being functions of radius.~~ The intensity represents optical power per surface area (in watts per square meter). The incremental flux represents optical power per radius differential (in watts per meter), and the encircled flux represents a fraction of the cumulative output power to the total output power.

These three radial functions are intended to characterize fibre optic laser sources either for use in mathematical models predicting the minimum guaranteed length of a communications link, or to qualify a light source to measure insertion loss in multimode links.

0.2 — Changes from previous edition

~~This edition of the standard differs from its predecessor in both scope and content. Many of the content changes improve the measurement precision. Several changes have been made to the computation procedure:~~

- ~~• the integration methodology of the radial functions was simple summation, and is now specified to use trapezoidal integration or other higher-order techniques (see 9.3);~~
- ~~• a baseline subtraction step is specified to improve immunity to DC drifts (see 9.2.2 and 9.2.3);~~
- ~~• the ring width parameter is explicitly specified (see 9.2.1);~~
- ~~• the integration limit is specified (see 9.3).~~

~~The geometric calibration of the apparatus microscope now specifies either (depending on the application) the methodology of IEC 61745 or the original technique using the micropositioning stage (see Clause 7). Pixel sensitivity uniformity correction is now optional.~~

0.3 — Assumptions applicable to the characterization of data sources

~~The 50- μm or 62,5- μm core near-parabolic graded-index multimode fibre used as the "test jumper assembly" is treated as if it possessed perfect circular symmetry about its optical centre, as asymmetries in the launched optical flux distributions will dominate any lopsidedness of the test jumper assembly. It is further assumed that all cladding modes will be stripped by passage through the specified ten metres or more of fibre. The modes of a mode group need not carry equal flux. (In fact, with such short fibres, one thousand metres or less, unequal distribution of flux in the modes of a group is the norm, not the exception.)~~

0.4 — Assumptions applicable to the characterization of measurement sources

~~Measurement sources are assumed to be sufficiently broadband and incoherent that speckle is not a problem, and to have a sufficiently symmetrical nearfield distribution that the truncated centroid of that nearfield indicates the location of the optical centre of the fibre with sufficient accuracy for the purposes of this standard.~~

FIBRE OPTIC COMMUNICATION SUBSYSTEM TEST PROCEDURES –

Part 1-4: General communication subsystems – Light source encircled flux measurement method

1 Scope

~~This part of IEC 61280 is intended to characterize the encircled flux of two types of light sources: transmission light sources, which are usually coherent and substantially under excite the mode volume of a multimode fibre, and measurement light sources, which are incoherent and excite most of the mode volume of a multimode fibre.~~

This part of IEC 61280 establishes the characterization process of the encircled flux measurement method of light sources intended to be used with multimode fibre.

This document sets forth a **standard** procedure for the collection of two-dimensional fibre optic nearfield greyscale data and subsequent reduction to one-dimensional data expressed as a set of three sampled parametric functions of radius from the fibre's optical centre. ~~This revision of IEC 61280-1-4 continues to fulfil its original purpose, characterization of transmission light sources, which enables the accurate mathematical prediction of minimum guaranteed link length in 1 gigabit per second or greater fibre optic data communication systems. New to this revision is support for improved measurement precision of insertion loss in multimode fibre optic links through the characterization of measurement light sources.~~

Estimation of the fibre core diameter is not an objective of this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60793-2-10, *Optical fibres – Part 2-10: Product specifications – Sectional specification for category A1 multimode fibres*

IEC 60825-1, *Safety of laser products – Part 1: Equipment classification and requirements*

~~IEC 61745:1988, *End-face image analysis procedure for the calibration of optical fibre geometry test sets*~~

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Fibre optic communication subsystem test procedures –
Part 1-4: General communication subsystems – Light source encircled flux
measurement method**

**Procédures d'essai des sous-systèmes de télécommunication fibroniques –
Partie 1-4: Sous-systèmes généraux de télécommunication – Méthode de
mesure du flux inscrit de la source optique**



CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
4 Symbols	8
5 Assumptions.....	10
5.1 Assumptions applicable to the characterization of data sources	10
5.2 Assumptions applicable to the characterization of measurement sources	10
6 Apparatus.....	10
6.1 Common apparatus.....	10
6.1.1 General	10
6.1.2 Computer.....	10
6.1.3 Image digitizer.....	11
6.1.4 Detector	11
6.1.5 Magnifying optics.....	11
6.1.6 Attenuator.....	12
6.1.7 Micro positioner (optional)	12
6.1.8 Input port.....	12
6.1.9 Calibration light source	12
6.2 Transmission source apparatus	13
6.2.1 General	13
6.2.2 Test jumper assembly.....	13
6.2.3 Fibre shaker	13
6.3 Measurement source apparatus	15
7 Sampling and specimens.....	15
8 Geometric calibration.....	15
9 Measurement procedure	15
9.1 Safety	15
9.2 Image acquisition.....	15
9.2.1 Raw image acquisition	15
9.2.2 Dark image acquisition	16
9.2.3 Corrected image	16
9.3 Optical centre determination	16
9.3.1 General	16
9.3.2 Centroid image	17
9.3.3 Centroid computation.....	17
9.4 Test source image acquisition.....	18
10 Computation of encircled flux	18
10.1 Computation of radial data functions	18
10.2 Integration limit and baseline determination	20
10.2.1 Integration limit.....	20
10.2.2 Baseline determination	20
10.2.3 Baseline subtraction	20
10.3 Computation of encircled flux.....	21
11 Results	21

11.1	Information available with each measurement.....	21
11.2	Information available upon request	21
12	Specification information	22
Annex A (informative)	Measurement sensitivity considerations	23
A.1	Baseline averaging considerations.....	23
A.2	Pixel sensitivity variation calibration.....	25
A.3	Correlated double sampling	25
A.4	Imperfections of practical detectors and optics.....	26
Bibliography	28
Figure 1	– Apparatus block diagram.....	10
Figure 2	– Typical set-up for transmission source measurement	13
Figure 3	– Fibre shaker example.....	14
Figure 4	– Pixel and ring illustration	18
Figure A.1	– Core images from instrument A and instrument B	23
Figure A.2	– Compressed core images from instrument A and instrument B.....	24
Figure A.3	– Intensity versus radius for instruments A and B.....	24

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FIBRE OPTIC COMMUNICATION SUBSYSTEM TEST PROCEDURES –

Part 1-4: General communication subsystems – Light source encircled flux measurement method

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61280-1-4 has been prepared by subcommittee 86C: Fibre optic systems and active devices, of IEC technical committee 86: Fibre optics. It is an International Standard.

This third edition cancels and replaces the second edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) improvement of calibration procedure and calibration traceability;
- b) improvement of fibre shaker description and requirements;
- c) addition of pulsed light sources;
- d) removal of a poorly traceable calibration process using a micro positioner.

The text of this International Standard is based on the following documents:

Draft	Report on voting
86C/1806/CDV	86C/1828/RVC

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 61280 series can be found, under the general title *Fibre optic communication subsystem test procedures*, on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This part of IEC 61280 specifies how to measure the encircled flux of a multimode light source. Encircled flux is a fraction of the cumulative output power to the total output power as a function of radial distance from the centre of the multimode optical fibre's core.

The basic approach is to collect two-dimensional (2D) nearfield data, using a calibrated camera, and to mathematically convert the 2D data into three normalized functions of radial distance from the fibre's optical centre. The three functions are intensity, incremental flux, and encircled flux. The intensity represents optical power per surface area (in watts per square meter). The incremental flux represents optical power per radius differential (in watts per meter), and the encircled flux represents a fraction of the cumulative output power to the total output power.

These three radial functions are intended to characterize fibre optic laser sources either for use in mathematical models predicting the minimum guaranteed length of a communications link, or to qualify a light source to measure insertion loss in multimode links.

FIBRE OPTIC COMMUNICATION SUBSYSTEM TEST PROCEDURES –

Part 1-4: General communication subsystems – Light source encircled flux measurement method

1 Scope

This part of IEC 61280 establishes the characterization process of the encircled flux measurement method of light sources intended to be used with multimode fibre.

This document sets forth a procedure for the collection of two-dimensional fibre optic nearfield greyscale data and subsequent reduction to one-dimensional data expressed as a set of three sampled parametric functions of radius from the fibre's optical centre.

Estimation of the fibre core diameter is not an objective of this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60793-2-10, *Optical fibres – Part 2-10: Product specifications – Sectional specification for category A1 multimode fibres*

IEC 60825-1, *Safety of laser products – Part 1: Equipment classification and requirements*

SOMMAIRE

AVANT-PROPOS	32
INTRODUCTION.....	34
1 Domaine d'application	35
2 Références normatives	35
3 Termes et définitions	35
4 Symboles	37
5 Hypothèses	38
5.1 Hypothèses applicables à la caractérisation des sources de données	38
5.2 Hypothèses applicables à la caractérisation des sources de mesure	38
6 Appareillage	38
6.1 Appareillage commun	38
6.1.1 Généralités	38
6.1.2 Ordinateur	39
6.1.3 Numériseur d'image.....	39
6.1.4 Détecteur.....	39
6.1.5 Optiques de grossissement.....	40
6.1.6 Atténuateur.....	40
6.1.7 Micropositionneur (facultatif).....	41
6.1.8 Port d'entrée.....	41
6.1.9 Source optique d'étalonnage	41
6.2 Appareillage pour les sources de transmission.....	42
6.2.1 Généralités	42
6.2.2 Ensemble jarretière d'essai	42
6.2.3 Agitateur de fibre	42
6.3 Appareillage pour les sources de mesure.....	44
7 Echantillonnage et spécimens	44
8 Etalonnage géométrique	44
9 Procédure de mesure	44
9.1 Sécurité	44
9.2 Acquisition d'images	44
9.2.1 Acquisition d'images brutes	44
9.2.2 Acquisition d'images d'obscurité	45
9.2.3 Image corrigée	46
9.3 Détermination du centre optique	46
9.3.1 Généralités	46
9.3.2 Image du centroïde.....	46
9.3.3 Calcul du centroïde.....	46
9.4 Acquisition d'images d'une source d'essai	47
10 Calcul du flux inscrit	47
10.1 Calcul des fonctions des données radiales.....	47
10.2 Limite d'intégration et détermination de la ligne de base	50
10.2.1 Limite d'intégration	50
10.2.2 Détermination de la ligne de base.....	50
10.2.3 Soustraction de la ligne de base	50
10.3 Calcul du flux inscrit.....	50
11 Résultats	51

11.1	Informations disponibles pour chaque mesure.....	51
11.2	Informations disponibles sur demande	51
12	Informations à spécifier	51
Annex A (informative)	Considérations sur la sensibilité des mesures	53
A.1	Considérations sur le moyennage d'une ligne de base	53
A.2	Etalonnage de la variation de la sensibilité des pixels	55
A.3	Double échantillonnage corrélé	56
A.4	Imperfections des détecteurs et des optiques pratiques	56
Bibliographie.....		59
Figure 1	– Schéma fonctionnel de l'appareillage	39
Figure 2	– Montage type pour la mesure de sources de transmission.....	42
Figure 3	– Exemple d'agitateur de fibre.....	43
Figure 4	– Représentation des pixels et des anneaux	48
Figure A.1	– Images d'un cœur à partir d'un instrument A et d'un instrument B.....	53
Figure A.2	– Images compressées d'un cœur à partir d'un instrument A et d'un instrument B	54
Figure A.3	– Intensité en fonction du rayon pour les instruments A et B.....	55

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

PROCÉDURES D'ESSAI DES SOUS-SYSTÈMES DE TÉLÉCOMMUNICATION FIBRONIQUES –

Partie 1-4: Sous-systèmes généraux de télécommunication – Méthode de mesure du flux inscrit de la source optique

AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (IEC) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de l'IEC). L'IEC a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, l'IEC – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de l'IEC"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec l'IEC, participent également aux travaux. L'IEC collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de l'IEC concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de l'IEC intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de l'IEC se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de l'IEC. Tous les efforts raisonnables sont entrepris afin que l'IEC s'assure de l'exactitude du contenu technique de ses Publications; l'IEC ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de l'IEC s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de l'IEC dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de l'IEC et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) L'IEC elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de l'IEC. L'IEC n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à l'IEC, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de l'IEC, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de l'IEC ou de toute autre Publication de l'IEC, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de l'IEC peuvent faire l'objet de droits de brevet. L'IEC ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets.

L'IEC 61280-1-4 a été établie par le sous-comité 86C: Systèmes et dispositifs actifs à fibres optiques, du comité d'études 86 de l'IEC: Fibres optiques. Il s'agit d'une Norme internationale.

Cette troisième édition annule et remplace la deuxième édition parue en 2009. Cette édition constitue une révision technique.

Cette édition inclut les modifications techniques majeures suivantes par rapport à l'édition précédente:

- a) amélioration de la procédure et de la traçabilité de l'étalonnage;
- b) amélioration de la description et des exigences relatives à l'agitateur de fibre;
- c) ajout des sources optiques pulsées;

d) suppression d'un processus d'étalonnage utilisant un micropositionneur, en raison de sa faible traçabilité.

Le texte de cette Norme internationale est issu des documents suivants:

Projet	Rapport de vote
86C/1806/CDV	86C/1828/RVC

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à son approbation.

La langue employée pour l'élaboration de cette Norme internationale est l'anglais.

Ce document a été rédigé selon les Directives ISO/IEC, Partie 2, il a été développé selon les Directives ISO/IEC, Partie 1 et les Directives ISO/IEC, Supplément IEC, disponibles sous www.iec.ch/members_experts/refdocs. Les principaux types de documents développés par l'IEC sont décrits plus en détail sous www.iec.ch/publications.

Une liste de toutes les parties de la série IEC 61280, publiées sous le titre général *Procédures d'essai des sous-systèmes de télécommunication fibroniques*, se trouve sur le site web de l'IEC.

Le comité a décidé que le contenu de ce document ne sera pas modifié avant la date de stabilité indiquée sur le site web de l'IEC sous webstore.iec.ch dans les données relatives au document recherché. A cette date, le document sera

- reconduit,
- supprimé,
- remplacé par une édition révisée, ou
- amendé.

IMPORTANT – Le logo "colour inside" qui se trouve sur la page de couverture de ce document indique qu'elle contient des couleurs qui sont considérées comme utiles à une bonne compréhension de son contenu. Les utilisateurs devraient, par conséquent, imprimer cette publication en utilisant une imprimante couleur.

INTRODUCTION

La présente partie de l'IEC 61280 spécifie comment mesurer le flux inscrit d'une source optique multimodale. Le flux inscrit est une fraction de la puissance de sortie cumulée sur la puissance de sortie totale, en fonction de la distance radiale depuis le centre du cœur de la fibre optique multimodale.

L'approche de base consiste à rassembler des données de champ proche bidimensionnelles (2D) en utilisant une caméra étalonnée, et à convertir mathématiquement ces données en 2D en trois fonctions normalisées de la distance radiale par rapport au centre optique de la fibre. Les trois fonctions sont l'intensité, le flux incrémental et le flux inscrit. L'intensité représente la puissance optique par zone (exprimée en watts par mètre carré). Le flux incrémental représente la puissance optique par différentiel de rayon (exprimée en watts par mètre), et le flux inscrit représente une fraction de la puissance de sortie cumulée sur la puissance de sortie totale.

Ces trois fonctions radiales sont destinées à caractériser des sources laser fibroniques utilisées dans des modèles mathématiques prévoyant la longueur garantie minimale d'une liaison de communication, ou pour qualifier une source optique afin de mesurer la perte d'insertion dans des liaisons multimodales.

PROCÉDURES D'ESSAI DES SOUS-SYSTÈMES DE TÉLÉCOMMUNICATION FIBRONIQUES –

Partie 1-4: Sous-systèmes généraux de télécommunication – Méthode de mesure du flux inscrit de la source optique

1 Domaine d'application

La présente partie de l'IEC 61280 stipule le processus de caractérisation de la méthode de mesure du flux inscrit de sources optiques destinées à être utilisées avec des fibres multimodales.

Le présent document définit une procédure consistant à collecter des données fibroniques de champ proche, bidimensionnelles et en niveaux de gris, puis à les réduire en données unidimensionnelles exprimées sous la forme d'un ensemble de trois fonctions paramétriques échantillonnées du rayon par rapport au centre optique de la fibre.

L'évaluation du diamètre du cœur des fibres ne constitue pas un objectif du présent document.

2 Références normatives

Les documents suivants sont cités dans le texte de sorte qu'ils constituent, pour tout ou partie de leur contenu, des exigences du présent document. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

IEC 60793-2-10, *Fibres optiques – Partie 2-10: Spécifications de produits – Spécification intermédiaire pour les fibres multimodales de catégorie A1*

IEC 60825-1, *Sécurité des appareils à laser – Partie 1: Classification des matériels et exigences*