

This is a preview - click here to buy the full publication



IEC TS 61463

Edition 2.0 2016-07

# TECHNICAL SPECIFICATION

---

## Bushings – Seismic qualification

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 29.080.20

ISBN 978-2-8322-3518-8

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD .....	4
INTRODUCTION .....	6
1 Scope .....	7
2 Normative references .....	7
3 Terms and definitions .....	7
4 Symbols and abbreviated terms .....	8
5 Methods of seismic qualification .....	9
6 Severities .....	10
6.1 At the ground .....	10
6.2 At the bushing flange .....	10
7 Qualification by static calculation .....	11
8 Qualification by dynamic analysis .....	13
8.1 General .....	13
8.2 Modal analysis using the time-history method .....	14
8.3 Modal analysis using the RRS .....	14
9 Qualification by vibration test .....	14
9.1 General .....	14
9.1.1 General .....	14
9.1.2 Mounting .....	15
9.1.3 External load .....	15
9.1.4 Measurements .....	15
9.1.5 Standard frequency range .....	15
9.1.6 Test methods .....	15
9.1.7 Testing .....	17
9.2 Test on complete apparatus .....	18
9.3 Test on the bushing mounted on a simulating support .....	18
9.4 Test on the bushing alone .....	18
10 Evaluation of the seismic qualification .....	18
10.1 Combination of stresses .....	18
10.2 Cantilever test .....	19
10.3 Acceptance criteria .....	19
11 Necessary exchange of information .....	20
11.1 Information supplied by the apparatus manufacturer .....	20
11.2 Information supplied by the bushing manufacturer .....	20
Annex A (informative) Flow chart for seismic qualification .....	23
Annex B (informative) Natural frequency and damping determination: Free oscillation test .....	24
B.1 Free oscillation test .....	24
B.2 Sine sweep frequency search .....	25
Annex C (informative) Static calculation method – Additional considerations .....	26
C.1 General .....	26
C.2 Effect of the first bending mode .....	26
C.3 Determination of $S_C$ .....	26
C.4 Value of $a_{bg}$ .....	26
C.5 Typical seismic response of cantilever type structures .....	27

C.6	Superelevation factor $K$ .....	29
Annex D (informative)	Qualification by static calculation – Example on transformer bushing .....	33
D.1	Seismic ground motion .....	33
D.2	Critical part of the bushing .....	33
D.3	Static calculation.....	33
D.3.1	General .....	33
D.3.2	Seismic load .....	34
D.3.3	Wind load .....	35
D.3.4	Terminal load.....	35
D.4	Guaranteed bending strength .....	36
Annex E (informative)	Center clamped bushings .....	37
Bibliography	.....	40
Figure 1	– Example of model of the transformer system .....	14
Figure 2	– RRS for ground mounted equipment – ZPA = 0,5 g [1] [2] .....	17
Figure 3	– Response factor $R$ .....	21
Figure 4	– Test with simulating support according to 9.3 .....	22
Figure 5	– Determination of the severity .....	22
Figure A.1	– Flow chart for seismic qualification.....	23
Figure B.1	– Typical case of free oscillations.....	24
Figure B.2	– Case of free oscillations with beats .....	25
Figure C.1	– Single degree of freedom system .....	27
Figure C.2	– Structure at the flange of a bushing with cemented porcelain [5] [7].....	28
Figure C.3	– Spring stiffness $C$ in function of cemented part geometry [5] [7].....	29
Figure C.4	– Superelevation factor due to the existence of transformer body and foundation [5] .....	30
Figure D.1	– Critical part of the bushing .....	33
Figure D.2	– Forces affecting the bushing .....	34
Figure D.3	– Porcelain diameters .....	35
Figure E.1	– Failure process [6] .....	37
Figure E.2	– Failure process, flow chart [5] [6] .....	38
Figure E.3	– Stress profile during the opening process [6].....	38
Figure E.4	– Relation between compression and tensile stress in the bottom edge of the porcelain due to the opening process [6] .....	39
Table 1	– Ground acceleration levels .....	10
Table 2	– Dynamic parameters obtained from experience on bushings with porcelain insulators ( $f_0$ = natural frequency, $d$ = damping).....	12
Table 3	– Dynamic parameters obtained from experience on bushings with composite insulators ( $f_0$ = natural frequency, $d$ = damping).....	12
Table 4	– Example of qualification level: AG5: ZPA = 0,5 g.....	17
Table 5	– Response factor $R$ .....	21
Table C.1	– Examples of typical seismic responses.....	31

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### BUSHINGS – SEISMIC QUALIFICATION

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a Technical Specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- The subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC 61463, which is a Technical Specification, has been prepared by subcommittee 36A: Insulated bushings, of IEC technical committee 36: Insulators.

This second edition cancels and replaces the first edition published in 1996 and Amendment 1:2000. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the seismic spectrum profile has been substituted with the one of IEEE Std 693-2005, worldwide used as a reference;
- b) the acceptance criteria have been reviewed and the maximum permissible stress for each main material has been harmonized with the relevant IEC Standard for that material;
- c) a load on the head has been prescribed when the bushing is subject to the vibration test;
- d) the sine sweep test has been added as a method of search of resonance frequency, worldwide used.

The text of this document is based on the following documents:

Enquiry draft	Report on voting
36A/178/DTS	36A/179/RVC

Full information on the voting for the approval of this document can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

As it is not always possible to define accurately the seismic severity at the bushing flange level, IEC TS 61463, which is a Technical Specification, presents three alternative methods of qualification. The three methods are equally acceptable. If the required response spectrum (RRS) at the bushing flange is not known, a severity (in terms of acceleration values) based on standard response spectra at the ground level may be used to carry out qualification through one of the three methods described in this document.

When the environmental characteristics are not sufficiently known, qualification by static calculation is acceptable. Where high safety reliability of equipment is required for a specific environment, precise data are used, therefore qualification by dynamic analysis or vibration test is recommended. The choice between vibration testing and dynamic analysis depends mainly on the capacity of the test facility for the mass and volume of the specimen, and, also if non-linearities are expected.

When qualification by dynamic analysis is foreseen, it is recommended that the numerical model be adjusted by using vibration data (see Clause 5).

This document was prepared with the intention of being applicable to bushings whatever their construction material and their internal configuration. The information contained, originally directed to porcelain bushings, has been partially updated to include also composite bushings.

## BUSHINGS – SEISMIC QUALIFICATION

### 1 Scope

IEC TS 61463, which is a Technical Specification, is applicable to alternating current and direct current bushings for highest voltages above 52 kV (or with resonance frequencies placed inside the seismic response spectrum), mounted on transformers, other apparatus or buildings. For bushings with highest voltages less than or equal to 52 kV (or with resonance frequencies placed outside from the seismic response spectrum), due to their characteristics, seismic qualification is not used as far as construction practice and seismic construction practice comply with the state of the art.

This document presents acceptable seismic qualification methods and requirements to demonstrate that a bushing can maintain its mechanical properties, insulate and carry current during and after an earthquake.

The seismic qualification of a bushing is only performed upon request.

### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-47, *Environmental testing – Part 2-47: Test – Mounting of specimens for vibration, impact and similar dynamic tests*

IEC 60068-2-57, *Environmental testing – Part 2-57: Tests – Test Ff: Vibration – Time-history and sine-beat method*

IEC 60068-3-3:1991, *Environmental testing – Part 3-3: Guidance – Seismic test methods for equipments*

IEC 60137, *Insulated bushings for alternating voltages above 1 000 V*

IEC 61462, *Composite hollow insulators – Pressurized and unpressurized insulators for use in electrical equipment with rated voltage greater than 1 000 V – Definitions, test methods, acceptance criteria and design recommendations*

IEC 62155, *Hollow pressurized and unpressurized ceramic and glass insulators for use in electrical equipment with rated voltages greater than 1 000 V*

IEC 62217, *Polymeric insulators for indoor and outdoor use – General definitions, test methods and acceptance criteria*

ISO 2041, *Mechanical vibration, shock and condition monitoring – Vocabulary*