



CONSOLIDATED VERSION



**Communication networks and systems for power utility automation –
Part 6: Configuration description language for communication in power utility
automation systems related to IEDs**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.200

ISBN 978-2-8322-5802-6

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	7
INTRODUCTION.....	12
1 Scope.....	13
1.1 General.....	13
1.2 Namespace name and version	13
1.3 Code Component distribution	14
2 Normative references	15
3 Terms and definitions	16
4 Abbreviations	17
5 Intended engineering process with SCL	18
5.1 General.....	18
5.2 Scope of SCL.....	18
5.3 Use of SCL in the engineering process	19
5.4 IED modifications.....	22
5.5 Data exchange between projects	23
6 The SCL object model	26
6.1 General.....	26
6.2 The process model	29
6.3 The product (IED) model.....	30
6.4 The communication system model	31
6.5 Modelling of redundancy	32
6.6 Data flow modelling	33
7 SCL description file types	33
8 SCL language.....	35
8.1 Specification method.....	35
8.2 Language versions and compatibility.....	38
8.2.1 MustUnderstand rules.....	39
8.2.2 SCL name space and versions.....	40
8.2.3 Incompatibilities to earlier versions	41
8.3 SCL language extensions	41
8.3.1 General	41
8.3.2 Data model extensions	42
8.3.3 Additional semantics to existing syntax elements.....	42
8.3.4 Data type constraints.....	42
8.3.5 XML name spaces	42
8.3.6 Private data.....	43
8.3.7 Another XML syntax	44
8.3.8 Summary: Standard conformance for extension handling.....	44
8.3.9 Extension example	44
8.4 General structure	44
8.5 Object and signal designation	45
8.5.1 General	45
8.5.2 Object designations in an object hierarchy.....	45
8.5.3 Signal identifications to be used in the communication system.....	46
8.5.4 Signal identifications usable by applications	48

8.5.5	Naming example	49
9	The SCL syntax elements	49
9.1	Header	49
9.2	Process description	52
9.2.1	General	52
9.2.2	Voltage level	57
9.2.3	Bay level	58
9.2.4	Power equipment	59
9.2.5	SubEquipment level	66
9.2.6	Process function logical nodes	67
9.2.7	Non power equipment	68
9.2.8	Substation section example	69
9.3	IED description	71
9.3.1	General	71
9.3.2	The IED, Services and Access Point	75
9.3.3	The IED server	87
9.3.4	The logical device	88
9.3.5	LN0 and other Logical Nodes	89
9.3.6	Data object (DOI) definition	91
9.3.7	Data set definition	94
9.3.8	Report control block	96
9.3.9	Log control block	99
9.3.10	GSE control block	100
9.3.11	Sampled value control block	102
9.3.12	Setting control block	104
9.3.13	Binding to external signals	105
9.3.14	Associations	109
9.4	Communication system description	110
9.4.1	General	110
9.4.2	Subnetwork definition	111
9.4.3	Address definition	113
9.4.4	GSE address definition	114
9.4.5	SMV address definition	115
9.4.6	Physical connection parameters	115
9.4.7	Communication section example	116
9.5	Data type templates	117
9.5.1	General	117
9.5.2	LNodeType definitions	119
9.5.3	DO type definition	120
9.5.4	Data attribute (DA) definition	122
9.5.5	Data attribute structure type	126
9.5.6	Enumeration types	128
9.5.7	Data type template examples	129
10	Tool and project engineering rights	129
10.1	IED configurator	129
10.2	System configurator	130
10.3	Right transfer between projects	130
Annex A (normative)	SCL syntax: XML schema definition	133

Annex B (informative) SCL enumerations according to IEC 61850-7-3 and IEC 61850-7-4.....	185
Annex C (informative) Syntax extension examples.....	186
C.1 Extension syntax for drawing layout coordinates.....	186
Annex D (informative) Example.....	188
D.1 Example specification.....	188
D.1.1 General.....	188
D.1.2 Substation configuration.....	188
D.1.3 Communication system configuration.....	189
D.1.4 Transformer IED.....	189
D.2 Example SCL file contents.....	190
Annex E (informative) SCL syntax: General XML schema definition.....	203
E.1 General.....	203
E.2 Base types.....	203
E.3 Substation syntax.....	218
E.4 Data type templates.....	218
E.5 IED capabilities and structure.....	219
E.6 Communication subnetworks.....	232
E.7 Main SCL.....	232
Annex F (informative) XML schema definition of SCL variants.....	234
Annex G (normative) SCL Implementation Conformance Statement (SICS).....	240
Annex H (informative) ExtRef use cases.....	245
Annex I (normative) SCL – mixed version projects.....	249
I.1 General.....	249
I.2 Downgrading rules.....	252
I.2.1 Data Model related downgrading rules.....	252
I.2.2 SCL IED and Substation Model related compatibility rules.....	256
I.2.3 Generic rules.....	259
I.3 Upgrading rules.....	259
I.3.1 Data Model Structure related upgrading rules.....	259
I.3.2 SCL Element related upgrading rules.....	261
I.4 Mixed version projects involving Ed2, Ed2.1 devices / SCTs.....	262
I.4.1 General.....	262
I.4.2 Downgrading rules.....	265
I.4.3 Upgrading rules.....	267
Bibliography.....	269
Figure 1 – Reference model for information flow in the configuration process.....	20
Figure 2 – IED type description to System Configurator.....	21
Figure 3 – IED instance description to System Configurator.....	22
Figure 4 – Modification process.....	23
Figure 5 – Engineering right handling in projects.....	25
Figure 6 – SCL substation object model.....	27
Figure 7 – SA System Configuration example.....	29
Figure 8 – ICD files describing implementable IED types of a general IED class.....	35
Figure 9 – UML diagram overview of SCL schema.....	37
Figure 10 – Elements of the signal identification as defined in IEC 61850-7-2.....	46

Figure 11 – Elements of the signal name using product naming	47
Figure 12 – Possible elements of the signal name using functional naming	48
Figure 13 – Names within different structures of the object model	49
Figure 14 – UML diagram of Header section	50
Figure 15 – UML diagram of Substation section	53
Figure 16 – UML diagrams for equipment type inheritance and relations	60
Figure 17 – Substation section example	70
Figure 18 – IED structure and access points	72
Figure 19 – UML description of IED-related schema part – Base	73
Figure 20 – UML description of IED-related schema part for Control blocks	74
Figure 21 – UML description of IED-related schema part – LN definition	75
Figure 22 – UML diagram overview of the Communication section	111
Figure 23 – UML overview of DataTypeTemplate section	118
Figure 24 – UML diagram of Process and Line elements	56
Figure C.1 – Coordinate example	186
Figure D.1 – T1-1 Substation configuration	188
Figure D.2 – T1-1 Communication configuration	189
Figure D.3 – T1-1 Transformer bay	190
Figure I.1 – Edition 1-Edition 2 – Area of compatibility	249
Figure I.2 – Edition 1-Edition 2 Mixed engineering with different SCL versions	250
Figure I.3 – Edition 1-Edition 2 Mixed engineering with different SCL versions with one SCT managing data flow restriction	251
Figure I.4 – Edition 1-Edition 2 Mixed engineering with same SCL version – restricted to (Ed1∩Ed2)UEd2	252
Figure I.5 – Workflow with SED 2007B4 import following mustUnderstand/mayIgnore rules	263
Figure I.6 – Workflow with ICT A imports SCD 2007B4 following the mustUnderstand rules	264
Figure I.7 – Workflow with SCT exports SCD 2007B following the downgrading rules	265
Table 1 – The files composing the XML schema definition for SCL	37
Table 2 – Attributes of the Private element	43
Table 3 – Attributes of the Header element	51
Table 4 – Attributes of the History item (Hitem) element	52
Table 5 – Primary apparatus device type codes	64
Table 6 – Attributes of the Terminal element	66
Table 7 – Attributes of the SubEquipment element	67
Table 8 – Attributes of the LNode element	68
Table 9 – General Equipment codes from IEC 61850-7-4	69
Table 10 – Attributes of the IED element	76
Table 11 – List of service capabilities and setting elements and attributes	78
Table 12 – Attributes of the Access point element	84
Table 13 – Attributes of the IED server element	88
Table 14 – Attributes of the Authentication element	88

Table 15 – Attributes of the LDevice element.....	89
Table 16 – Attributes of the LN0 element	90
Table 17 – Attributes of the LN element	91
Table 18 – Attributes of the DOI element	92
Table 19 – Attributes of the DAI element.....	93
Table 20 – Attributes of the SDI element.....	93
Table 21 – Attributes of the DataSet element.....	94
Table 22 – Attributes of the FCDA element	95
Table 23 – Attributes of the report control block element.....	96
Table 24 – Attributes of the RptEnabled element	98
Table 25 – Attributes of the ClientLN element	98
Table 26 – Attributes of the log control block element	100
Table 27 – Attributes of the GSE control block element.....	101
Table 28 – Attributes of the IEDName element.....	102
Table 29 – Attributes of the sampled value control block element	103
Table 30 – Attributes of the Smv Options element.....	104
Table 31 – Deprecated Smv options	104
Table 32 – Attributes of the setting control block element	105
Table 33 – Attributes of the Input/ExtRef element	107
Table 34 – Attributes of the association element	110
Table 35 – Attributes of the Subnetwork element	112
Table 36 – Attributes of the ConnectedAP element	113
Table 37 – Attributes of the GSE element	114
Table 38 – Attributes of the SMV element	115
Table 39 – PhysConn P-Type definitions.....	116
Table 40 – Template definition elements.....	119
Table 41 – Attributes of the LNodeType element.....	120
Table 42 – Attributes of the DO element	120
Table 43 – Attributes of the DOType element.....	121
Table 44 – Attributes of the SDO element	121
Table 45 – Data type mapping	122
Table 46 – Attribute value kind (Valkind) meaning.....	123
Table 47 – Attributes of the DA element.....	124
Table 48 – Attributes of the BDA element	127
Table 49 – Attributes of the EnumType element.....	128
Table 50 – Usage of Service element at IED level and Server / ServerAt level	85
Table 51 – Usage of ExtRef attributes in different use cases	108
Table 52 – Allowed SCT engineering actions	132
Table G.1 – IED configurator conformance statement	240
Table G.2 – System configurator conformance statement.....	242

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 6: Configuration description language for communication in power utility automation systems related to IEDs

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

DISCLAIMER

This Consolidated version is not an official IEC Standard and has been prepared for user convenience. Only the current versions of the standard and its amendment(s) are to be considered the official documents.

This Consolidated version of IEC 61850-6 bears the edition number 2.1. It consists of the second edition (2009-12) [documents 57/1025/FDIS and 57/1041/RVD] and its amendment 1 (2018-06) [documents 57/1918/FDIS and 57/1940/RVD]. The technical content is identical to the base edition and its amendment.

International Standard IEC 61850-6 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

This second edition constitutes a technical revision.

The main changes with respect to the previous edition are as follows:

- functional extensions added based on changes in other Parts, especially Parts 7-2 and 7-3;
- functional extensions concerning the engineering process, especially for configuration data exchange between system configuration tools, added;
- provision of clarifications and corrections. Issues that require clarification are published in a database available at <http://tissue.iec61850.com>. Arising incompatibilities are listed in 8.2.3.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 61850 series, under the general title *Communication networks and systems for power utility automation*, can be found on the IEC website.

This IEC standard includes Code Components i.e. components that are intended to be directly processed by a computer. Such content is any text found between the markers <CODE BEGINS> and <CODE ENDS>, or otherwise is clearly labeled in this standard as a Code Component.

The purchase of this IEC standard carries a copyright license for the purchaser to sell software containing Code Components from this standard directly to end users and to end users via distributors, subject to IEC software licensing conditions, which can be found at: <http://www.iec.ch/CCv1>.

If any updates are required to the published code component that needs to apply immediately and can not wait for an amendment (i.e. fixing a major problem), a new release of the Code Component will be issued and distributed through the IEC WebSite. Any new release of the Code Component related to this part will supersede any previously published Code Component including the one published within the current document.

The Code Component(s) included in this IEC standard are a set of .xsd. This Code Component is published through the IEC WebSite; for details see 1.3 of the present IEC standard.

This consolidated edition brings two distinct sets of changes:

- 1) Resolved Interop Issues (covered by the table below) which have already followed the technical issues (Tissues) process as described in IEC 61850-1 and have reached the green “status”.
- 2) Resolved Editorial Tissues which may have lead to interoperability issues.

The resolutions of these issues which lead to these changes are described in greater detail in the Tissue database hosted at <http://tissue.iec61850.com>.

The only new features compared to the original IEC 61850-6:2009 are the inclusion of the Process and Line elements supporting other application areas than substations, and necessary enhancements to fully support the amended communication related parts. Apart from this, this consolidated edition strictly respects the scope of the original edition.

Technical issues summary

N°, Subject, Cat, Clause and Paragraph are as they appear on the Tissue database hosted at <http://tissue.iec61850.com> where all technical issues have been stored from the origin of IEC 61850.

“Subject” defines very briefly the topic under focus.

“Cat” defines whether this has been considered as an Interoperability Issue (IntOp2) or just a need for amending IEC 61850-6:2009.

The Tissues which have been considered are:

N°	Subject	Cat	Clause	Paragraph
658	Tracking related features	IntOp2	Annex A	
660	XML encoding header repeat	Ed2	Annex A.4	
663	FCDA element cannot be a "functionally constrained logical node"	IntOp2	9.3.7	Table 22
668	Modeling of autotransformer	IntOp2	9.2.4	
678, 699	DO type description table	Ed2		Table 43
687	ResvTms attribute at the SGCB	Ed2	9.3.12	
719	ConfDataSet maxAttributes defineds FCDA elements in data set	IntOp2	9.3.2	Table 11
721	Log element name	IntOp2	9.3.5	
731	SCL example inconsistent	Ed2	9.3.4§	
752	Input section naming	Ed2	9.3.13	
768	bType VisString65 is missing	IntOp2	Annex A	
779	Relative object references	IntOp2	9.5.4.1	
787	SICS I45 inconsistency	Ed2	Annex G	
788	SICS S56 from optional to mandatory	IntOp2	Annex G	
789 (822)	ConfLdName for services applies to client and server	IntOp2	9.3.2	Table 11
804	valKind and IED versus system configurator	IntOp2	9.5.4.1	
806	Max length of log name incosnsten to part 7-2	Ed2	Annex A	SCL_BaseSimpleTypes
807	Indicate if 'owner' is present in RCB	Ed2	9.3.2	Table 11
823	valKind for structured data attributes	IntOp2	9.5.4.1	
824	Short addresses at structured data attributes	IntOp2	9.3.6, 9.5.4.1	
825	Floating point values	IntOp2	9.5.4.1	Table 45
845	SGCB ResvTms	IntOp2	9.3.2	Table 11
853	SBO and ProtNs	IntOp2	9.5.5	
855	recursive SubFunction	Ed2	9.2.7	
856	Voltage level frequency and phases	Ed2	9.2.2	
857	Function/SubFunction for primary equipment	Ed2	9.2.4	
873	Examples for "curvpts"	Ed2	9.3.6	end of paragraph
886	Missing 8-1 P-Types	Ed2	Annex A	

N°	Subject	Cat	Clause	Paragraph
901	tServices at Ap and at IED	Ed2	9.3.2	below Table 12
936	SupSubscription parameter usage is difficult	IntOp2	9.3.2	Table 11
948	Enumeration (string) value format	IntOp2	9.5.6	
949	type of LN inst is ambiguous	Ed2	9.3.5	Table 17
1118	RptEnabled definition	Ed2	9.3.8	
1147	Filehandling service capability	Ed2	9.3.2	Table 11
1195	Typographical error	Ed2	9.3.2	
1208	IP V6 address format	IntOp2	A.5	
1284	SCSM mapping may require a communication section in an ICD file	Ed2	7	
1298	How to differentiate preconfigured Report data sets from those generated by the system tool	Ed2	9.3.2	Table 11
1304	Error in SCL object model	Ed2		Figure 6
1318	SSD will not validate against XSD	Ed2	9.2.6	Note 2
1327	SICS: import of SCD by IED tool	Ed2	Annex G	Table G.1
1328	Limitation of the size of identifiers	Ed2	9.5.2, 9.5.3, 9.5.6	
1354	Changes to SICS	Ed2	Annex G	Tables G.1, G.2
1359	Replace "c37_238" with "61850-9-3"	Ed2	9.3.2	
1365	Need to tighten up the XSD in regards to IED name usage	IntOp2	9.2.6	3
1395	Client LN attributes	IntOp2	9.3.8	
1396	The use and configuration flow of LGOS and LSVS is Unclear	Ed2	9.3.2	Table 11
1397	Subscription limitation visible in IxD file	Ed2	Annex G	
1398	originalSciVersion management in SCT	Ed2	9.3.2	
1402	Extref during engineering	Ed2	9.3.13, Annex H(new)	
1415	SICS-S110 IID import mandatory	Ed2	Annex G	Table G.2
1419	Support of IdName on other IEDs	Ed2	Annex G	Table G.1
1434	Add capability to change nofASDU is missing	Ed2	9.3.2	Table 11
1444	Need to support fixed and SCT controlled data sets	Ed2		
1445	ConfReportControl and a fixed reportSettings	Ed2	9.3.2	
1447	Restriction on EnumTypes in SCL	Ed2		
1448	Not possible to determine the restriction on number of BRCBs if rptMod=both	Ed2		
1450	originalSciXxx computation rules	IntOp2	9.3.2	
1457	Multiple DOI nodes with the same name	Ed2		
1458	New ExtRef attributes for later binding	Ed2		

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This part of IEC 61850 specifies a description language for the configuration of power utility IEDs. This language is called System Configuration description Language (SCL). It is used to describe IED configurations and communication systems according to IEC 61850-5 and IEC 61850-7-x. It allows the formal description of the relations between the utility automation system and the process (substation, switch yard). At the application level, the switch yard topology itself and the relation of the switch yard structure to the SAS functions (logical nodes) configured on the IEDs can be described.

While this part describes the language to describe the configuration of IEC 61850 systems, other parts of the standard describe how to configure the system and possible restrictions. Therefore implementations claiming conformance to this standard shall take into account constraints from the other normative references. Some references to the other parts have been included for the purpose of clarification but these references are not all inclusive.

NOTE The process description, which is in this standard restricted to switch yards and general process functions, will be enhanced by appropriate add-ons for wind mills, hydro plants and distributed energy resources (DER).

SCL allows the description of an IED configuration to be passed to a communication and application system engineering tool, and to pass back the whole system configuration description to the IED configuration tool in a compatible way. Its main purpose is to allow the interoperable exchange of communication system configuration data between an IED configuration tool and a system configuration tool from different manufacturers.

IEC 61850-8-x and IEC 61850-9-x, which concern the mapping of IEC 61850-7-x to specific communication stacks, may extend these definitions according to their need with additional parts, or simply by restrictions on the way the values of objects have to be used.

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 6: Configuration description language for communication in power utility automation systems related to IEDs

1 Scope

1.1 General

This part of IEC 61850 specifies a file format for describing communication-related IED (Intelligent Electronic Device) configurations and IED parameters, communication system configurations, switch yard (function) structures, and the relations between them. The main purpose of this format is to exchange IED capability descriptions, and SA system descriptions between IED engineering tools and the system engineering tool(s) of different manufacturers in a compatible way.

The defined language is called System Configuration description Language (SCL). The IED and communication system model in SCL is according to IEC 61850-5 and IEC 61850-7-x. SCSM specific extensions or usage rules may be required in the appropriate parts.

The configuration language is based on the Extensible Markup Language (XML) version 1.0 (see XML references in Clause 2).

This standard does not specify individual implementations or products using the language, nor does it constrain the implementation of entities and interfaces within a computer system. This part of the standard does not specify the download format of configuration data to an IED, although it could be used for part of the configuration data.

1.2 Namespace name and version

This new section is mandatory for any IEC 61850 namespace (as defined by IEC 61850-7-1:2011).

The parameters which are identifying this new release of the SCL namespace `xmlns:scl="http://www.iec.ch/61850/2003/SCL"` are:

- Namespace Version: 2007
- Namespace Revision: B
- Namespace Release: 4
- Namespace release date: 2018/01/22

The table below provides an overview of all published versions of this namespace.

Edition	Publication date	Webstore	Namespace
Edition 1.0	2004-03	IEC 61850-6:2004	IEC 61850-6:2003
Edition 2.0	2009-12	IEC 61850-6:2009	IEC 61850-6:2007B
Amendment 1 of Edition 2.0	2018	IEC 61850-6:2009/AMD1:2018	IEC 61850-6:2007B4
Edition 2.1	2018	IEC 61850-6:2009+AMD1:2018 CSV	IEC 61850-6:2007B4

1.3 Code Component distribution

The Code Components included in this IEC standard are also available as electronic machine readable file at:

http://www.iec.ch/tc57/supportdocuments/IEC_61850-6.2018.SCL.2007B4.full.zip

The Code Component(s) included in this IEC standard are potentially subject to maintenance works and user shall select the latest release in the repository located at:

<http://www.iec.ch/tc57/supportdocuments>

The latest version/release of the document will be found by selecting the file IEC_61850-6.2018.SCL.{VersionStateInfo}.full.zip with the filed VersionStateInfo of the highest value.

Each Code Component is a ZIP package containing the electronic representation of the Code Component itself, with a file describing the content of the package (IECManifest.xml).

The IECManifest contains different sections giving information on:

- The copyright notice
- The identification of the code component
- The publication related to the code component
- The list of the electronic files which compose the code component
- An optional list of history files to track changes during the evolution process of the code component

The IECManifest related to this publication is:

```
<IECManifest xmlns="http://www.iec.ch/CC/2017/IECManifest" xmlns:xsi="http://www.w3.org/2001/XMLSchema-instance" xsi:schemaLocation="http://www.iec.ch/CC/2017/IECManifest IECManifest.xsd">
  <Copyright>
    <Notice>
      COPYRIGHT (c) IEC, 2017. This version of this XSD is part of IEC 61850-6:2009/AMD1:2018; see the IEC 61850-6:2009/AMD1:2018 for full legal notices. In case of any differences between the here-below code and the IEC published content, the here-below definition supersedes the IEC publication; it may contain updates. See history files. The whole document has to be taken into account to have a full description of this code component.
      See www.iec.ch/CCv1 for copyright details.
    </Notice>
    <License uri="www.iec.ch/CCv1">IEC License</License>
  </Copyright>
  <CodeComponent id="IEC_61850-6.2007B4.SCL.XSD" name="IEC 61850-6 SCL schema V2007B4" content="full" date="2018-01-22">
    <Publication name="IEC_61850-6.2018_ed2.1" comment="Configuration description language for communication in power utility automation systems related to IEDs"/>
    <File name="SCL.xsd" category="normative" content="full"/>
    <File name="SCL_Substation.xsd" category="normative" content="full"/>
    <File name="SCL_Communication.xsd" category="normative" content="full"/>
    <File name="SCL_IED.xsd" category="normative" content="full"/>
    <File name="SCL_DataTypeTemplates.xsd" category="normative" content="full"/>
    <File name="SCL_BaseTypes.xsd" category="normative" content="full"/>
    <File name="SCL_BaseSimpleTypes.xsd" category="normative" content="full"/>
    <File name="SCL_Enums.xsd" category="normative" content="full"/>
    <File name="SCL.Doc.HTML.zip" category="normative" content="full" comment="Zip archive containing the HTML documentation of the SCL. Contains the 'SCL.html' file and all related pictures"/>
    <HistoryFile name="history.2007B4.txt" startingDate="2014-06-11" endingDate="2017-07-05" startingVersion="SCL.XSD.v2007B" endingVersion="SCL.XSD.v2007B4"/>
  </CodeComponent>
</IECManifest>
```

The package is identified using the following naming rule:

{RefStandard}.{CodeComponentName}.{VersionRevision}.{LightFull}{PublicationStage}.zip

For current publication, the Code Component package name is:

IEC_61850-6.2018.SCL.2007B4.full.zip

IEC 61850-6:2009+AMD1:2018 CSV – 15 –
© IEC 2018

The life cycle of a code component is not restricted to the life cycle of the related publication. The publication life cycle goes through two stages, Version (corresponding to an edition) and Revision (corresponding to an amendment). A third publication stage (Release) allow publication of Code Component without need to publish an amendment.

This is useful when InterOp Tissues need to be fixed. Then a new release of the Code Component will be released, which supersedes the previous release, and distributed through the IEC TC57 web site.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC TS 61850-2, *Communication networks and systems in substations – Part 2: Glossary*

IEC 61850-4, *Communication networks and systems for power utility automation – Part 4: System and project management*

IEC 61850-5, *Communication networks and systems for power utility automation – Part 5: Communication requirements for functions and device models*

IEC 61850-7-1:2011, *Communication networks and systems for power utility automation – Part 7-1: Basic communication structure – Principles and models*

IEC 61850-7-2, *Communication networks and systems for power utility automation – Part 7-2: Basic information and communication structure – Abstract communication service interface (ACSI)*

IEC 61850-7-3, *Communication networks and systems for power utility automation – Part 7-3: Basic communication structure – Common data classes*

IEC 61850-7-4, *Communication networks and systems for power utility automation – Part 7-4: Basic communication structure – Compatible logical node classes and data object classes*

IEC 61850-8-1, *Communication networks and systems for power utility automation – Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3*

IEC 61850-9-2, *Communication networks and systems for power utility automation – Part 9-2: Specific communication service mapping (SCSM) – Sampled values over ISO/IEC 8802-3*

IEC IEEE 61850-9-3, *Communication networks and systems for power utility automation – Part 9-3: Precision time protocol profile for power utility automation*

IEC 81346-1, *Industrial systems, installations and equipment and industrial products – Structuring principles and reference designations – Part 1: Basic rules*

ISO/IEC 8859-1, *Information technology – 8-bit single-byte coded graphic character sets – Part 1: Latin alphabet No. 1*

RFC 1952, *GZIP file format specification version 4.3*, RFC, available at <<http://www.ietf.org/rfc/rfc1952.txt>>

RFC 2045, *Multipurpose Internet Mail Extensions (MIME) Part One: Format of Internet Message Bodies*, RFC, available at <<http://www.ietf.org/rfc/rfc2045.txt>>

Extensible Markup Language (XML) 1.0, W3C, available at <<http://www.w3.org/TR/2000/REC-xml-20001006>>

XML Schema Part 1: Structures, W3C, available at <<http://www.w3.org/TR/2001/REC-xmlschema-1-20010502>>

XML Schema Part 2: Datatypes, W3C, available at <<http://www.w3.org/TR/2001/REC-xmlschema-2-20010502/>>