

This is a preview - [click here to buy the full publication](#)



IEC 61850-7-2

Edition 2.0 2010-08

# INTERNATIONAL STANDARD



---

**Communication networks and systems for power utility automation –  
Part 7-2: Basic information and communication structure – Abstract  
communication service interface (ACSI)**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 33.200

ISBN 978-2-88912-065-9

## CONTENTS

FOREWORD.....	9
INTRODUCTION.....	11
1 Scope.....	12
2 Normative references.....	12
3 Terms and definitions .....	13
4 Abbreviated terms.....	14
5 ACSI overview and basic concepts.....	15
5.1 Conceptual model of IEC 61850.....	15
5.2 The meta-meta model.....	16
5.3 The meta model.....	16
5.3.1 General .....	16
5.3.2 Information modelling classes .....	17
5.3.3 Information exchange modelling classes .....	18
5.3.4 Relations between classes .....	20
5.4 The domain type model.....	21
5.5 The data instance model.....	21
6 TypeDefinitions.....	22
6.1 General .....	22
6.1.1 BasicTypes .....	22
6.1.2 CommonACSI Types.....	23
7 GenServerClass model .....	29
7.1 GenServerClass definition .....	29
7.1.1 GenServerClass syntax.....	29
7.1.2 GenServerClass attributes .....	30
7.2 Server class services.....	30
7.2.1 Overview of directory and GetDefinition services .....	30
7.2.2 GetServerDirectory .....	31
8 Application association model .....	32
8.1 Introduction .....	32
8.2 Concept of application associations .....	32
8.3 TWO-PARTY-APPLICATION-ASSOCIATION (TPAA) class model.....	32
8.3.1 TWO-PARTY-APPLICATION-ASSOCIATION (TPAA) class definition .....	32
8.3.2 Two-party application association services .....	34
8.4 MULTICAST-APPLICATION-ASSOCIATION (MCAA) class .....	37
8.4.1 MULTICAST-APPLICATION-ASSOCIATION (MCAA) class definition.....	37
8.4.2 MULTICAST-Application-association (MCAA) class attributes.....	37
9 GenLogicalDeviceClass model .....	38
9.1 GenLogicalDeviceClass definition .....	38
9.1.1 GenLogicalDeviceClass syntax .....	38
9.1.2 GenLogicalDeviceClass attributes .....	38
9.2 GenLogicalDeviceClass services.....	38
9.2.1 GetLogicalDeviceDirectory.....	38
10 GenLogicalNodeClass model .....	39
10.1 GenLogicalNodeClass definition.....	39
10.1.1 GenLogicalNodeClass diagram .....	39
10.1.2 GenLogicalNodeClass syntax.....	40

10.1.3	GenLogicalNodeClass attributes .....	41
10.2	GenLogicalNodeClass services .....	42
10.2.1	Overview .....	42
10.2.2	GetLogicalNodeDirectory .....	42
10.2.3	GetAllDataValues .....	43
11	Generic data object class model .....	45
11.1	GenDataObjectClass diagram .....	45
11.2	GenDataObjectClass syntax .....	45
11.3	GenDataObjectClass attributes .....	46
11.3.1	DataObjectName .....	46
11.3.2	DataObjectRef – data object reference .....	46
11.3.3	m/o/c .....	46
11.3.4	DataObjectType .....	46
11.4	GenDataObjectClass services .....	46
11.4.1	General definitions and overview .....	46
11.4.2	GetDataValues .....	47
11.4.3	SetDataValues .....	48
11.4.4	GetDataDirectory .....	49
11.4.5	GetDataDefinition .....	50
12	Generic common data class model .....	50
12.1	General .....	50
12.2	GenCommonDataClass .....	51
12.2.1	GenCommonDataClass diagram .....	51
12.2.2	GenCommonDataClass syntax .....	51
12.2.3	GenCommonDataClass attributes .....	52
12.3	GenDataAttributeClass .....	52
12.3.1	GenDataAttributeClass diagram .....	52
12.3.2	GenDataAttributeClass syntax .....	53
12.3.3	GenDataAttributeClass attributes .....	53
12.4	GenConstructedAttributeClass .....	57
12.4.1	GenConstructedAttributeClass diagram .....	57
12.4.2	GenConstructedAttributeClass syntax .....	57
12.4.3	GenConstructedAttributeClass attributes .....	57
12.5	GenSubDataAttributeClass .....	57
12.5.1	SubDataAttributeClass diagram .....	57
12.5.2	SubDataAttributeClass syntax .....	58
12.5.3	GenSubDataAttributeClass attributes .....	58
12.6	Referencing data objects and their components .....	58
12.6.1	General .....	58
12.6.2	Reference syntax .....	59
12.6.3	Base types and their relation .....	59
12.6.4	Example of using references .....	60
13	DATA-SET class model .....	61
13.1	General .....	61
13.2	DATA-SET class definition .....	62
13.2.1	DATA-SET class syntax .....	62
13.2.2	DATA-SET class attributes .....	63
13.3	DATA-SET class services .....	63
13.3.1	Overview .....	63

13.3.2	GetDataSetValues .....	64
13.3.3	SetDataSetValues.....	65
13.3.4	CreateDataSet.....	66
13.3.5	DeleteDataSet .....	66
13.3.6	GetDataSetDirectory.....	67
14	Service tracking.....	68
14.1	General.....	68
14.2	Common service tracking (CST).....	68
15	Modelling of control block classes.....	70
15.1	General.....	70
15.2	Control block class models.....	70
15.2.1	Control block attributes.....	71
15.2.2	Control block services.....	71
15.2.3	Attribute type.....	71
15.3	Control block tracking services.....	71
15.3.1	General.....	71
15.3.2	Common data classes for control block service tracking.....	72
16	SETTING-GROUP-CONTROL-BLOCK class model.....	82
16.1	General.....	82
16.2	SGCB class definition.....	83
16.2.1	SGCB class syntax.....	83
16.2.2	SGCB class attributes.....	84
16.3	SGCB class services.....	85
16.3.1	Overview.....	85
16.3.2	SelectActiveSG.....	85
16.3.3	SelectEditSG.....	86
16.3.4	SetEditSGValue.....	87
16.3.5	ConfirmEditSGValues.....	88
16.3.6	GetEditSGValue.....	89
16.3.7	GetSGCBValues.....	90
17	REPORT-CONTROL-BLOCK and LOG-CONTROL-BLOCK class models.....	91
17.1	Overview.....	91
17.2	REPORT-CONTROL-BLOCK class model.....	93
17.2.1	Basic concepts.....	93
17.2.2	BUFFERED-REPORT-CONTROL-BLOCK (BRCB) class definition.....	93
17.2.3	BRCB class services.....	103
17.2.4	UNBUFFERED-REPORT-CONTROL-BLOCK (URCB) class definition.....	116
17.2.5	URCB class services.....	117
17.3	LOG-CONTROL-BLOCK class model.....	118
17.3.1	General.....	118
17.3.2	LCB class definition.....	119
17.3.3	LOG class definition.....	124
17.3.4	Reason code for log entries.....	127
17.3.5	LOG services.....	127
18	Generic substation event class model (GSE).....	131
18.1	Overview.....	131
18.2	GOOSE-CONTROL-BLOCK (GoCB) class.....	132
18.2.1	GoCB definition.....	132
18.2.2	GOOSE service definitions.....	134

18.2.3	Generic object oriented substation event (GOOSE) message .....	139
19	Transmission of sampled value class model.....	140
19.1	Overview .....	140
19.2	Transmission of sampled values using multicast .....	142
19.2.1	MSVCB class definition.....	142
19.2.2	Multicast sampled value class services .....	144
19.3	Transmission of sampled values using unicast.....	147
19.3.1	USVCB class definition .....	147
19.3.2	Unicast sampled value services .....	150
19.4	Sampled value format.....	153
19.4.1	MsvID or UsvID .....	154
19.4.2	OptFlds .....	154
19.4.3	DatSet.....	154
19.4.4	Sample [1..n].....	155
19.4.5	SmpCnt.....	155
19.4.6	RefrTm.....	155
19.4.7	ConfRev .....	155
19.4.8	SmpSynch.....	155
19.4.9	SmpRate .....	155
19.4.10	SmpMod.....	155
19.4.11	Simulation .....	155
20	CONTROL class model.....	156
20.1	Introduction .....	156
20.2	Control with normal security.....	158
20.2.1	Direct control with normal security.....	158
20.2.2	SBO control with normal security.....	160
20.3	Control with enhanced security .....	162
20.3.1	Introduction .....	162
20.3.2	Direct control with enhanced security .....	162
20.3.3	SBO control with enhanced security .....	163
20.4	Time-activated operate .....	166
20.5	CONTROL class service definitions .....	167
20.5.1	Overview .....	167
20.5.2	Service parameter definition.....	168
20.5.3	Service specification .....	172
20.6	Tracking of control services .....	178
20.6.1	General .....	178
20.6.2	Control service tracking (CTS) .....	178
21	Time and time-synchronization model .....	179
21.1	General .....	179
21.2	External information.....	180
22	Naming conventions .....	181
22.1	Class naming and class specializations.....	181
22.2	Referencing an instance of a class.....	182
22.3	Scope.....	183
23	File transfer model.....	184
23.1	File class .....	184
23.1.1	FileName.....	184
23.1.2	FileSize .....	184

23.1.3	LastModified .....	184
23.2	File services .....	185
23.2.1	GetFile .....	185
23.2.2	SetFile .....	185
23.2.3	DeleteFile .....	186
23.2.4	GetFileAttributeValues .....	186
Annex A (normative)	ACSI conformance statement.....	188
Annex B (normative)	Formal definition of IEC 61850-7-2 Common Data Classes.....	195
Annex C (informative)	Generic substation state event (GSSE) control block (GsCB) .....	203
Bibliography	.....	212
Index	.....	213
Figure 1	– Excerpt of conceptual model of IEC 61850 .....	16
Figure 2	– Basic conceptual class model of the ACSI.....	17
Figure 3	– Conceptual service model of the ACSI .....	19
Figure 4	– Core of the conceptual meta model and relationship .....	21
Figure 5	– Data instance model (conceptual) .....	22
Figure 6	– Overview about GetDirectory and GetDefinition services .....	30
Figure 7	– Normal operation .....	33
Figure 8	– Aborting association .....	33
Figure 9	– Principle of multicast application association.....	37
Figure 10	– Basic conceptual model of the GenLogicalNodeClass.....	40
Figure 11	– Basic conceptual class model of the GenDataObjectClass .....	45
Figure 12	– Excerpt of GenDataObjectClass services .....	47
Figure 13	– Class diagram of the GenCommonDataClass.....	51
Figure 14	– Conceptual Class diagram of the GenCommonDataClass.....	51
Figure 15	– Class diagram of the GenDataAttributeClass.....	52
Figure 16	– Relation of TrgOp and Reporting.....	56
Figure 17	– Class diagram of the GenConstructedAttributeClass .....	57
Figure 18	– Relation of types (example) .....	60
Figure 19	– Example of a data object .....	61
Figure 20	– Dynamic creation of data set instances .....	62
Figure 21	– Control block service mapping .....	72
Figure 22	– Basic model of the settings model.....	83
Figure 23	– Basic building blocks for reporting and logging .....	92
Figure 24	– BRCB state machine.....	95
Figure 25	– General queue of entries for report handler.....	96
Figure 26	– Buffer time.....	98
Figure 27	– State Machine for Sequence Number Generation .....	99
Figure 28	– Logical state machine for general interrogation .....	101
Figure 29	– Report example on the use of sequence number.....	105
Figure 30	– Entry discard that does not cause indication of loss of information in enabled state .....	106
Figure 31	– Indication of loss of information due to resource constraints in enable state .....	107

Figure 32 – Data set members and reporting .....	108
Figure 33 – Report example .....	109
Figure 34 – Log model overview .....	119
Figure 35 – GoCB model .....	131
Figure 36 – Model for transmission of sampled values .....	141
Figure 37 – Principle of the control model .....	156
Figure 38 – State machine of direct control with normal security .....	159
Figure 39 – Direct control with normal security .....	160
Figure 40 – State machine of SBO control with normal security .....	161
Figure 41 – State machine of direct control with enhanced security .....	163
Figure 42 – State machine SBO control with enhanced security .....	164
Figure 43 – Select before operate with enhanced security – positive case .....	165
Figure 44 – Select before operate with enhanced security – negative case (no status change) .....	165
Figure 45 – Time-activated operate .....	167
Figure 46 – Time model and time synchronization (principle) .....	180
Figure 47 – Specializations .....	181
Figure 48 – Object names and object reference .....	183
Figure C.1 – GsCB model .....	203
Table 1 – ACSI model classes with related services .....	20
Table 2 – BasicTypes .....	23
Table 3 – ObjectName type .....	24
Table 4 – ObjectReference type .....	24
Table 5 – ServiceError type .....	25
Table 6 – PACKED-LIST type .....	26
Table 7 – TimeStamp type .....	26
Table 8 – TimeQuality definition .....	27
Table 9 – TimeAccuracy .....	28
Table 10 – TriggerConditions type .....	28
Table 11 – ReasonForInclusion .....	29
Table 12 – GenServerClass definition .....	29
Table 13 – TWO-PARTY-APPLICATION-ASSOCIATION (TPAA) class definition .....	33
Table 14 – MULTICAST-APPLICATION-ASSOCIATION (MCAA) class definition .....	37
Table 15 – GenLogicalDeviceClass (GenLD) class definition .....	38
Table 16 – GenLogicalNodeClass definition .....	40
Table 17 – GenDataObjectClass definition .....	46
Table 18 – GenCommonDataClass definition .....	52
Table 19 – GenDataAttributeClass definition .....	53
Table 20 – Functional constraint values .....	54
Table 21 – TrgOp .....	56
Table 22 – GenConstructedAttributeClass definition .....	57
Table 23 – GenSubDataAttributeClass definition .....	58

Table 24 – DATA-SET (DS) class definition .....	63
Table 25 – Common service tracking common data class (CST) definition .....	69
Table 26 – ServiceType type .....	70
Table 27 – CB class definition .....	71
Table 28 – Buffered report tracking service (BTS) definition.....	73
Table 29 – Unbuffered report tracking service (UTS) definition .....	74
Table 30 – Log control block tracking service (LTS) definition .....	76
Table 31 – Log tracking service (OTS) definition.....	77
Table 32 – GOOSE Control block tracking service (GTS) definition.....	78
Table 33 – MSVCB tracking service (MTS) definition .....	79
Table 34 – USVCB tracking service (NTS) definition .....	80
Table 35 – SGCB tracking service (STS) definition .....	81
Table 36 – SGCB class definition .....	84
Table 37 – BRCB class definition .....	94
Table 38 – Report format specification .....	104
Table 39 – URCB class definition .....	116
Table 40 – LCB class definition .....	120
Table 41 – LOG class definition.....	125
Table 42 – GOOSE control block class definition .....	132
Table 43 – GOOSE message definition.....	139
Table 44 – MSVCB class definition .....	142
Table 45 – USVCB class definition .....	148
Table 46 – Sampled value (SV) format definition .....	154
Table 47 – Generic behavior and negative responses .....	157
Table 48 – Control services.....	167
Table 49 – T definition.....	168
Table 50 – Test definition .....	169
Table 51 – Check condition definition .....	169
Table 52 – operTm definition.....	169
Table 53 – Additional cause diagnosis definition .....	170
Table 54 – AddCause semantic.....	171
Table 55 – Control service tracking (CTS) definition .....	179
Table 56 – FILE class definition.....	184
Table A.1 – Basic conformance statement.....	189
Table A.2 – ACSI models conformance statement .....	190
Table A.3 – ACSI service conformance statement .....	191
Table C.1 – GSSE control block class definition .....	204
Table C.2 – GSSE message definition .....	210



INTERNATIONAL ELECTROTECHNICAL COMMISSION

**COMMUNICATION NETWORKS AND SYSTEMS  
FOR POWER UTILITY AUTOMATION –**

**Part 7-2: Basic information and communication structure –  
Abstract communication service interface (ACSI)**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61850-7-2 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

The text of this standard is based on the following documents:

FDIS	Report on voting
57/1065/FDIS	57/1083/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This second edition cancels and replaces the first edition published in 2003. It constitutes a technical revision.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The major technical changes with regard to the previous edition are as follows:

- class diagrams have been updated,
- data types not required have been removed,
- errors and typos have been corrected,
- substitution model has been moved to IEC 61850-7-3,
- service tracking for control blocks have been added,
- the view concept will be according to the new work on role bases access (RBA),
- security issues are solved by the IEC 62351 series, and
- several terms have been harmonized with those in the other parts.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

In this document, the following print types are used:

- **bold** is used to highlight defined terms,
- Tahoma is used where the difference between a capital i (I) and a small L (l) is important to see.

A list of all parts of the IEC 61850 series, under the general title: *Communication networks and systems for power utility automation*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

This document is part of a set of definitions which details a layered utility communication architecture. This architecture has been chosen to provide abstract definitions of classes and services such that the definitions are independent of specific protocol stacks, implementations, and operating systems.

The IEC 61850 series is intended to provide interoperability between a variety of devices. Communication between these devices is achieved by the definition of a hierarchical class model (for example, logical device, logical node, data, data set, report control, or log) and services provided by these classes (for example, get, set, report, define, delete) in IEC 61850-7-x.

This part of IEC 61850 defines the abstract communication service interface (ACSI) for use in the utility application domain that requires real-time cooperation of intelligent electronic devices. The ACSI has been defined so as to be independent of the underlying communication systems. Specific communication service mappings<sup>1)</sup> (SCSM) are specified in IEC 61850-8-x and IEC 61850-9-x.

This part of IEC 61850 defines the abstract communication service interface in terms of

- a hierarchical class model of all information that can be accessed via a communication network,
- services that operate on these classes, and
- parameters associated with each service.

The ACSI description technique abstracts away from all the different approaches to implement the cooperation of the various devices.

NOTE 1 Abstraction in ACSI has two meanings. First, only those aspects of a real device (for example, a breaker) or a real function that are visible and accessible over a communication network are modelled. This abstraction leads to the hierarchical class models and their behaviour defined in IEC 61850-7-2, IEC 61850-7-3, and IEC 61850-7-4. Second, the ACSI abstracts from the aspect of concrete definitions on how the devices exchange information; only a conceptual cooperation is defined. The concrete information exchange is defined in the SCSMs.

NOTE 2 This part of IEC 61850 does not provide comprehensive tutorial material. It is recommended that IEC 61850-5 and IEC 61850-7-1 be read first in conjunction with IEC 61850-7-2 and IEC 61850-7-3.

NOTE 3 Examples use names of classes (for example XCBR for a class of a logical node) defined in IEC 61850-7-4 and IEC 61850-7-3. The normative names are defined in IEC 61850-7-4 and IEC 61850-7-3 only.

---

<sup>1)</sup> The ACSI is independent of the specific mapping. Mappings to standard application layers or middle ware technologies are possible.

## COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

### Part 7-2: Basic information and communication structure – Abstract communication service interface (ACSI)

#### 1 Scope

This part of IEC 61850 applies to the ACSI communication for utility automation. The ACSI provides the following abstract communication service interfaces.

- a) Abstract interface describing communications between a client and a remote server for
  - real-time data access and retrieval,
  - device control,
  - event reporting and logging,
  - setting group control,
  - self-description of devices (device data dictionary),
  - data typing and discovery of data types, and
  - file transfer.
- b) Abstract interface for fast and reliable system-wide event distribution between an application in one device and many remote applications in different devices (publisher/subscriber) and for transmission of sampled measured values (publisher/subscriber).

#### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61850-2, *Communication networks and systems in substations – Part 2: Glossary*

IEC 61850-5, *Communication networks and systems in substations – Part 5: Communication requirements for functions and devices models*

IEC 61850-6, *Communication networks and systems for power utility automation – Part 5: Configuration description language for communication in electrical substations related to IEDs*

IEC 61850-7-1, *Communication networks and systems for power utility automation – Part 7-1: Basic communication structure – Principles and models<sup>2)</sup>*

IEC 61850-7-3, *Communication networks and systems for power utility automation – Part 7-3: Basic communication structure – Common data classes<sup>2)</sup>*

IEC 61850-7-4, *Communication networks and systems for power utility automation – Part 7-4: Basic communication structure – Compatible logical node classes and data object classes*

---

<sup>2)</sup> To be published.

IEC 61850-8-1, *Communication networks and systems for power utility automation – Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3<sup>3)</sup>*

IEC 61850-9-2, *Communication networks and systems for power utility automation – Part 9-2: Specific communication service mapping (SCSM) – Sampled values over ISO/IEC 8802-3<sup>3)</sup>*

ISO 4217, *Codes for the representation of currencies and funds*

ISO 9506 (all parts), *Industrial automation systems – Manufacturing Message Specification*

IEEE 754, *Standard for Floating-Point Arithmetic*

---

3) To be published.