

This is a preview - click here to buy the full publication



IEC TR 61869-100

Edition 1.0 2017-01

TECHNICAL REPORT



**Instrument transformers –
Part 100: Guidance for application of current transformers in power system
protection**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 17.220.20

ISBN 978-2-8322-3808-0

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	7
INTRODUCTION.....	9
1 Scope.....	10
2 Normative references	10
3 Terms and definitions and abbreviations.....	10
3.1 Terms and definitions.....	10
3.2 Index of abbreviations.....	12
4 Responsibilities in the current transformer design process.....	14
4.1 History.....	14
4.2 Subdivision of the current transformer design process	14
5 Basic theoretical equations for transient designing	15
5.1 Electrical circuit	15
5.1.1 General	15
5.1.2 Current transformer	18
5.2 Transient behaviour	20
5.2.1 General	20
5.2.2 Fault inception angle	22
5.2.3 Differential equation	23
6 Duty cycles.....	25
6.1 Duty cycle C – O.....	25
6.1.1 General	25
6.1.2 Fault inception angle	27
6.1.3 Transient factor K_{tf} and transient dimensioning factor K_{td}	28
6.1.4 Reduction of asymmetry by definition of the minimum current inception angle	50
6.2 Duty cycle C – O – C – O.....	53
6.2.1 General	53
6.2.2 Case A:No saturation occurs until t'	54
6.2.3 Case B:Saturation occurs between t'_{al} and t'	56
6.3 Summary	58
7 Determination of the transient dimensioning factor K_{td} by numerical calculation.....	61
7.1 General.....	61
7.2 Basic circuit	61
7.3 Algorithm	62
7.4 Calculation method	63
7.5 Reference examples	64
8 Core saturation and remanence.....	69
8.1 Saturation definition for common practice	69
8.1.1 General	69
8.1.2 Definition of the saturation flux in the preceding standard IEC 60044-1	69
8.1.3 Definition of the saturation flux in IEC 61869-2	71
8.1.4 Approach “5 % – Factor 5”	72
8.2 Gapped cores versus non-gapped cores	73
8.3 Possible causes of remanence.....	75
9 Practical recommendations.....	79
9.1 Accuracy hazard in case various PR class definitions for the same core	79

9.2	Limitation of the phase displacement $\Delta\varphi$ and of the secondary loop time constant T_S by the transient dimensioning factor K_{td} for TPY cores	79
10	Relations between the various types of classes	80
10.1	Overview.....	80
10.2	Calculation of e.m.f. at limiting conditions	80
10.3	Calculation of the exciting (or magnetizing) current at limiting conditions	81
10.4	Examples.....	81
10.5	Minimum requirements for class specification	82
10.6	Replacing a non-gapped core by a gapped core.....	82
11	Protection functions and correct CT specification	83
11.1	General.....	83
11.2	General application recommendations	83
11.2.1	Protection functions and appropriate classes	83
11.2.2	Correct CT designing in the past and today	85
11.3	Overcurrent protection: ANSI code: (50/51/50N/51N/67/67N); IEC symbol: I>	87
11.3.1	Exposition.....	87
11.3.2	Recommendation.....	89
11.3.3	Example	89
11.4	Distance protection: ANSI codes: 21/21N, IEC code: Z<	89
11.4.1	Exposition.....	89
11.4.2	Recommendations	91
11.4.3	Examples.....	91
11.5	Differential protection.....	98
11.5.1	Exposition.....	98
11.5.2	General recommendations	99
11.5.3	Transformer differential protection (87T).....	99
11.5.4	Busbar protection: Ansi codes (87B).....	104
11.5.5	Line differential protection: ANSI codes (87L) (Low impedance)	107
11.5.6	High impedance differential protection	109
Annex A (informative)	Duty cycle C – O software code.....	128
Annex B (informative)	Software code for numerical calculation of K_{td}	130
Bibliography	135
Figure 1	– Definition of the fault inception angle γ	12
Figure 2	– Components of protection circuit.....	16
Figure 3	– Entire electrical circuit.....	17
Figure 4	– Primary short circuit current	18
Figure 5	– Non-linear flux of L_{ct}	19
Figure 6	– Linearized magnetizing inductance of a current transformer	20
Figure 7	– Simulated short circuit behaviour with non-linear model	21
Figure 8	– Three-phase short circuit behaviour	23
Figure 9	– Composition of flux	24
Figure 10	– Short circuit current for two different fault inception angles	26
Figure 11	– ψ_{max} as the curve of the highest flux values.....	26
Figure 12	– Primary current curves for the 4 cases for 50 Hz and $\varphi = 70^\circ$	27
Figure 13	– Four significant cases of short circuit currents with impact on magnetic saturation of current transformers	28

Figure 14 – Relevant time ranges for calculation of transient factor	31
Figure 15 – Occurrence of the first flux peak depending on T_p , at 50 Hz	32
Figure 16 – Worst-case angle $\theta_{tf,\psi_{max}}$ as function of T_p and t'_{al}	33
Figure 17 – Worst-case fault inception angle $\gamma_{tf,\psi_{max}}$ as function of T_p and t'_{al}	34
Figure 18 – $K_{tf,\psi_{max}}$ calculated with worst-case fault inception angle $\theta_{\psi_{max}}$	34
Figure 19 – Polar diagram with $K_{tf,\psi_{max}}$ and $\gamma_{tf,\psi_{max}}$	35
Figure 20 – Determination of K_{tf} in time range 1	40
Figure 21 – Primary current curves for 50Hz, $T_p = 1$ ms, $\gamma_{\psi_{max}} = 166^\circ$ for $t'_{al} = 2$ ms	41
Figure 22 – worst-case fault inception angles for 50Hz, $T_p = 50$ ms and $T_s = 61$ ms	42
Figure 23 – transient factor for different time ranges	43
Figure 24 – K_{tf} in all time ranges for $T_s = 61$ ms at 50 Hz with t'_{al} as parameter	44
Figure 25 – Zoom of Figure 24	44
Figure 26 – Primary current for a short primary time constant	45
Figure 27 – K_{tf} values for a short primary time constant	46
Figure 28 – Short circuit currents for various fault inception angles	47
Figure 29 – Transient factors for various fault inception angles (example)	48
Figure 30 – Worst-case fault inception angles for each time step (example for 50 Hz)	48
Figure 31 – Primary current for two different fault inception angles (example for 16,67 Hz)	49
Figure 32 – Transient factors for various fault inception angles (example for 16,67 Hz)	50
Figure 33 – Worst-case fault inception angles for every time step (example for 16,67 Hz)	50
Figure 34 – Fault occurrence according to Warrington	51
Figure 35 – estimated distribution of faults over several years	52
Figure 36 – Transient factor K_{tf} calculated with various fault inception angles γ	53
Figure 37 – Flux course in a C-O-C-O cycle of a non-gapped core	54
Figure 38 – Typical flux curve in a C-O-C-O cycle of a gapped core, with higher flux in the second energization	55
Figure 39 – Flux curve in a C-O-C-O cycle of a gapped core, with higher flux in the first energization	56
Figure 40 – Flux curve in a C-O-C-O cycle with saturation allowed	57
Figure 41 – Core saturation used to reduce the peak flux value	58
Figure 42 – Curves overview for transient designing	59
Figure 43 – Basic circuit diagram for numerical calculation of K_{td}	62
Figure 44 – K_{td} calculation for C-O cycle	64
Figure 45 – K_{td} calculation for C-O-C-O cycle without core saturation in the first cycle	65
Figure 46 – K_{td} calculation for C-O-C-O cycle considering core saturation in the first cycle	66
Figure 47 – K_{td} calculation for C-O-C-O cycle with reduced asymmetry	67
Figure 48 – K_{td} calculation for C-O-C-O cycle with short t'_{al} and t''_{al}	68
Figure 49 – K_{td} calculation for C-O-C-O cycle for a non-gapped core	69
Figure 50 – Comparison of the saturation definitions according to IEC 60044-1 and according to IEC 61869-2	70
Figure 51 – Remanence factor K_r according to the previous definition IEC 60044-1	71

Figure 52 – Determination of saturation and remanence flux using the DC method for a gapped core.....	72
Figure 53 – Determination of saturation and remanence flux using DC method for a non-gapped core.....	72
Figure 54 – CT secondary currents as fault records of arc furnace transformer.....	76
Figure 55 – 4-wire connection.....	77
Figure 56 – CT secondary currents as fault records in the second fault of auto reclosure.....	78
Figure 57 – Application of instantaneous/time-delay overcurrent relay (ANSI codes 50/51) with definite time characteristic.....	88
Figure 58 – Time-delay overcurrent relay, time characteristics.....	88
Figure 59 – CT specification example, time overcurrent.....	89
Figure 60 – Distance protection, principle (time distance diagram).....	90
Figure 61 – Distance protection, principle (R/X diagram).....	91
Figure 62 – CT Designing example, distance protection.....	92
Figure 63 – Primary current with C-O-C-O duty cycle.....	96
Figure 64 – Transient factor K_{tf} with its envelope curve K_{tfp}	96
Figure 65 – Transient factor K_{tf} for CT class TPY with saturation in the first fault.....	97
Figure 66 – Transient factor K_{tf} for CT class TPZ with saturation in the first fault.....	97
Figure 67 – Transient factor K_{tf} for CT class TPX.....	98
Figure 68 – Differential protection, principle.....	99
Figure 69 – Transformer differential protection, faults.....	100
Figure 70 – Transformer differential protection.....	101
Figure 71 – Busbar protection, external fault.....	104
Figure 72 – Simulated currents of a current transformer for bus bar differential protection.....	107
Figure 73 – CT designing for a simple line with two ends.....	108
Figure 74 – Differential protection realized with a simple electromechanical relay.....	110
Figure 75 – High impedance protection principle.....	111
Figure 76 – Phasor diagram for external faults.....	112
Figure 77 – Phasor diagram for internal faults.....	113
Figure 78 – Magnetizing curve of CT.....	114
Figure 79 – Single-line diagram of busbar and high impedance differential protection.....	117
Figure 80 – Currents at the fault location (primary values).....	119
Figure 81 – Primary currents through CTs, scaled to CT secondary side.....	120
Figure 82 – CT secondary currents.....	120
Figure 83 – Differential voltage.....	121
Figure 84 – Differential current and r.m.s. filter signal.....	121
Figure 85 – Currents at the fault location (primary values).....	122
Figure 86 – Primary currents through CTs, scaled to CT secondary side.....	122
Figure 87 – CT secondary currents.....	123
Figure 88 – Differential voltage.....	123
Figure 89 – Differential current and r.m.s. filtered signal.....	124
Figure 90 – Currents at the fault location (primary values).....	124
Figure 91 – Primary currents through CTs, scaled to CT secondary side.....	125

Figure 92 – CT secondary currents	125
Figure 93 – Differential voltage	126
Figure 94 – Differential current and r.m.s. filtered signal	126
Figure 95 – Differential voltage without varistor limitation.....	127
Table 1 – Four significant cases of short circuit current inception angles	27
Table 2 – Equation overview for transient designing	60
Table 3 – Comparison of saturation point definitions	73
Table 4 – Measured remanence factors	74
Table 5 – Various PR class definitions for the same core	79
Table 6 – e.m.f. definitions.....	80
Table 7 – Conversion of e.m.f. values	80
Table 8 – Conversion of dimensioning factors.....	81
Table 9 – Definitions of limiting current	81
Table 10 – Minimum requirements for class specification	82
Table 11 – Effect of gapped and non-gapped cores	83
Table 12 – Application recommendations	84
Table 13 – Calculation results of the overdimensioning of a TPY core	103
Table 14 – Calculation results of overdimensioning as PX core.....	103
Table 15 – Calculation scheme for line differential protection.....	109
Table 16 – Busbar protection scheme with two incoming feeders	117

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INSTRUMENT TRANSFORMERS –

Part 100: Guidance for application of current transformers in power system protection

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 61869-100, which is a technical report, has been prepared by IEC technical committee 38: Instrument transformers.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
38/469/DTR	38/475A/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 61869 series, published under the general title *Instrument transformers*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Since the publication of IEC 60044-6:1992¹, *Requirements for protective current transformers for transient performance*, the area of application of this kind of current transformers has been extended. As a consequence, the theoretical background for the dimensioning according to electrical requirements has become much more complex. For IEC 61869-2 to remain as user-friendly as possible, the explanation of the background information has been transferred to this part of IEC 61869.

¹ Withdrawn and replaced by IEC 61869-2:2012.

INSTRUMENT TRANSFORMERS –

Part 100: Guidance for application of current transformers in power system protection

1 Scope

This part of IEC 61869 is applicable to inductive protective current transformers meeting the requirements of the IEC 61869-2 standard.

It may help relay manufacturers, CT manufacturers and project engineers to understand how a CT responds to simplified or standardized short circuit signals. Therefore, it supplies advanced information to comprehend the definition of inductive current transformers as well as their requirements.

The document aims to provide information for the casual user as well as for the specialist. Where necessary, the level of abstraction is mentioned in the document. It also discusses the question about the responsibilities in the design process for current transformers.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60255 (all parts), *Measuring relays and protection equipment*

IEC 60909-0:2016, *Short circuit currents in three-phase a.c. systems – Calculation of currents*

IEC 61869-1:2007, *Instrument transformers – General requirements*

IEC 61869-2:2012, *Instrument transformers – Additional requirements for current transformers*