

This is a preview - click here to buy the full publication



IEC 62271-106

Edition 2.0 2021-04

# INTERNATIONAL STANDARD

---

**High-voltage switchgear and controlgear –  
Part 106: Alternating current contactors, contactor-based controllers and motor-  
starters**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 29.130.10

ISBN 978-2-8322-9635-6

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD .....	4
1 Scope .....	6
2 Normative references .....	7
3 Terms and definitions .....	8
4 Normal and special service conditions .....	23
5 Ratings .....	24
6 Design and construction .....	38
7 Type tests .....	42
8 Routine tests .....	70
9 Guide to the selection of contactors and motor-starters for service (informative) .....	72
10 Information to be given with enquiries, tenders and orders (informative) .....	76
11 Transport, storage, installation, operating instructions and maintenance .....	78
12 Safety .....	78
13 Influence of the product on the environment .....	78
Annex A (normative) Identification of test objects .....	79
Annex B (informative) Determination of the equivalent RMS value of a short-time current during a short-circuit of a given duration .....	80
Annex C (normative) Method for weatherproofing test for outdoor switchgear and controlgear .....	81
Annex D (informative) References for auxiliary and control circuit components .....	82
Annex E (normative) Tolerances on test quantities during tests .....	83
Annex F (informative) Information and technical requirements to be given with enquires, tenders and orders .....	88
Annex G (informative) List of symbols and abbreviations .....	89
Annex H (informative) Electromagnetic compatibility on site .....	90
Annex I (informative) List of notes concerning certain countries .....	91
Annex J (informative) Extension of validity type tests .....	92
Annex K (informative) Exposure to pollution .....	93
Annex AA (normative) Records and reports of type tests for making, breaking and short-time current performance .....	94
Annex BB (normative) Disconnectors and earthing switches used in controllers .....	98
Bibliography .....	100
Figure 1 – Examples of speed/time curves .....	32
Figure 2 – Representation by two parameters of a prospective TRV of a circuit .....	60
Figure 3 – Representation of the specified TRV by a two-parameter reference line and a delay line .....	60
Figure 4 – Determination of power-frequency recovery voltage .....	61
Figure 5 – Test duties A and B – preferred earth point .....	63
Figure 6 – Test duties A and B – alternative earth point .....	64
Figure 7 – Test duty C – preferred earth point .....	64
Figure 8 – Test duty C – alternative earth point .....	65
Figure 9 – Characteristics for determining take-over current .....	66

Figure BB.1 – Disconnecter and earthing switch locations .....	98
Table 1 – Ratings and characteristics .....	25
Table 2 – Utilization categories .....	31
Table 3 – Characteristics dependent on starter type .....	37
Table 4 – Applicable type tests .....	44
Table 5 – Intermittent duty operating cycles .....	48
Table 6 – Verification of rated making and breaking capacities – Conditions for making and breaking corresponding to the several utilization categories at rated voltage $U_r$ .....	52
Table 7 – Relationship between current broken $I_C$ and OFF time .....	55
Table 8 – Overload current withstand requirements .....	56
Table 9 – Transient recovery voltage characteristics .....	63
Table 10 – Verification of the number of on-load operating cycles – Conditions for making and breaking corresponding to the several utilization categories .....	68
Table E.101 – Tolerances on test quantities for type test .....	83
Table G.101 – Additional list of symbols and abbreviations .....	89

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

#### **Part 106: Alternating current contactors, contactor-based controllers and motor-starters**

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62271-106 has been prepared by subcommittee 17A: Switching devices, of IEC technical committee 17: High-voltage switchgear and controlgear.

This second edition cancels and replaces the first edition published in 2011. It constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- document numbered to correspond to IEC 62271-1 2017.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
17A/1296/FDIS	17A/1301/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

This standard is to be read in conjunction with IEC 62271-1:2017. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1. Modifications to these clauses and subclauses are given under the same numbering, whilst additional subclauses are numbered from 101.

A list of all parts of the IEC 62271 series under the general title, *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

### Part 106: Alternating current contactors, contactor-based controllers and motor-starters

#### 1 Scope

This part of IEC 62271 applies to AC contactors and/or contactor-based controllers and motor-starters designed for indoor installation and operation at frequencies up to and including 60 Hz on systems having voltages above 1 kV and up to and including 24 kV. This document also includes additional requirements for outdoor installations where the equipment is housed in an additional protective enclosure.

It is applicable only to three-pole devices for use in three-phase systems, and single-pole devices for use in single-phase systems. Two-pole contactors and starters for use in single-phase systems are subject to agreement between manufacturer and user.

Contactors and/or starters dealt with in this document typically do not have adequate short-circuit interruption capability. In this context, this document gives requirements for:

- starters associated with separate short-circuit protective devices;
- controllers – contactors combined with short-circuit protective devices (SCPD).

Contactors intended for closing and opening electric circuits and, if combined with suitable relays, for protecting these circuits against operating overloads are covered in this document.

This document is also applicable to the operating devices of contactors and to their auxiliary equipment.

Motor-starters intended to start and accelerate motors to normal speed, to ensure continuous operation of motors, to switch off the supply from the motor and to provide means for the protection of motors and associated circuits against operating overloads are dealt with.

Motor-starter types included are:

- direct-on-line starters;
- reversing starters;
- two-direction starters;
- reduced kVA (voltage) starters;
  - auto-transformer starters;
  - rheostatic starters;
  - reactor starters.

This document does not apply to:

- circuit-breaker-based motor-starters;
- single-pole operation of multi-pole contactors or starters;
- two-step auto-transformer starters designed for continuous operation in the starting position;
- unbalanced rheostatic rotor starters, i.e. where the resistances do not have the same value in all phases;
- equipment designed not only for starting, but also for adjustment of speed;

- liquid starters and those of the "liquid-vapour" type;
- semiconductor contactors and starters making use of semiconductor contactors in the main circuit;
- rheostatic stator starters;
- contactors or starters designed for special applications.

This document does not deal with components contained in contactors and contactor-based motor-starters, for which individual specifications exist.

NOTE 1 Thermal electrical relays are covered by IEC 60255-149.

NOTE 2 High-voltage current-limiting fuses are covered by IEC 60282-1 and IEC 60644.

NOTE 3 Metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV are covered by IEC 62271-200.

NOTE 4 Disconnectors and earthing switches are covered by IEC 62271-102.

NOTE 5 High-voltage switches above 1 kV and less than 52 kV are covered by IEC 62271-103.

The object of this document is to state:

- a) the characteristics of contactors and starters and associated equipment;
- b) the conditions with which contactors or starters comply with reference to:
  - 1) their operation and behaviour,
  - 2) their dielectric properties,
  - 3) the degrees of protection provided by their enclosures, where applicable,
  - 4) their construction,
  - 5) for controllers, interactions between the various components, for example SCPD co-ordination;
- c) the tests intended for confirming that these conditions have been met, and the methods to be adopted for these tests;
- d) the information to be given with the equipment or in the manufacturer's literature.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-1:2010, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60068-2-1:2007, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2:2007, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-30:2005, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60076-2, *Power transformers – Part 2: Temperature rise for liquid-immersed transformers*

IEC 60076-11:2018, *Power transformers – Part 11: Dry-type transformers*

IEC 60255-21-1:1988, *Electrical relays – Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Section One: Vibration tests (sinusoidal)*

IEC 60282-1, *High-voltage fuses – Part 1: Current-limiting fuses*

IEC 60417, *Graphical symbols for use on equipment* (available at <http://www.graphical-symbols.info/equipment>)

IEC 60644, *Specification for high-voltage fuse-links for motor circuit applications*

IEC 60947-5-1, *Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*

IEC 61000-4-18:2019, *Electromagnetic compatibility (EMC) – Part 4-18: Testing and measurement techniques – Damped oscillatory wave immunity test*

IEC 61230, *Live working – Portable equipment for earthing or earthing and short-circuiting*

IEC 61812-1, *Time relays for industrial use and residential use – Part 1: Requirements and tests*

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-100:2021, *High-voltage switchgear and controlgear – Part 100: Alternating current circuit-breakers*

IEC 62271-102:2018, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62271-110:2017, *High-voltage switchgear and controlgear – Part 110: Inductive load switching*

IEC 62271-200:2021, *High-voltage switchgear and controlgear – Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*