

This is a preview - [click here to buy the full publication](#)



IEC 62305-4

Edition 2.0 2010-12

INTERNATIONAL STANDARD

**Protection against lightning –
Part 4: Electrical and electronic systems within structures**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.020; 91.120.40

ISBN 978-2-88912-283-7

CONTENTS

FOREWORD.....	5
INTRODUCTION	7
1 Scope.....	9
2 Normative references.....	9
3 Terms and definitions.....	10
4 Design and installation of SPM.....	13
4.1 General.....	13
4.2 Design of SPM.....	16
4.3 Lightning protection zones (LPZ)	17
4.4 Basic SPM	20
5 Earthing and bonding.....	21
5.1 General.....	21
5.2 Earth-termination system	22
5.3 Bonding network	24
5.4 Bonding bars	28
5.5 Bonding at the boundary of an LPZ	29
5.6 Material and dimensions of bonding components.....	29
6 Magnetic shielding and line routing.....	30
6.1 Spatial shielding	30
6.2 Shielding of internal lines.....	30
6.3 Routing of internal lines	30
6.4 Shielding of external lines	31
6.5 Material and dimensions of magnetic shields	31
7 Coordinated SPD system.....	31
8 Isolating interfaces	32
9 SPM management	32
9.1 General.....	32
9.2 SPM management plan.....	32
9.3 Inspection of SPM.....	33
9.3.1 Inspection procedure	34
9.3.2 Inspection documentation	34
9.4 Maintenance.....	35
Annex A (informative) Basis of electromagnetic environment evaluation in an LPZ	36
Annex B (informative) Implementation of SPM for an existing structure	60
Annex C (informative) Selection and installation of a coordinated SPD system.....	76
Annex D (informative) Factors to be considered in the selection of SPDs	82
Bibliography.....	87
Figure 1 – General principle for the division into different LPZ.....	13
Figure 2 – Examples of possible SPM (LEMP protection measures).....	15
Figure 3 – Examples for interconnected LPZ	19
Figure 4 – Examples for extended lightning protection zones	20
Figure 5 – Example of a three-dimensional earthing system consisting of the bonding network interconnected with the earth-termination system	22
Figure 6 – Meshed earth-termination system of a plant.....	23

Figure 7 – Utilization of reinforcing rods of a structure for equipotential bonding	25
Figure 8 – Equipotential bonding in a structure with steel reinforcement.....	26
Figure 9 – Integration of conductive parts of internal systems into the bonding network	27
Figure 10 – Combinations of integration methods of conductive parts of internal systems into the bonding network	28
Figure A.1 – LEMP situation due to lightning strike	37
Figure A.2 – Simulation of the rise of magnetic field by damped oscillations	40
Figure A.3 – Large volume shield built by metal reinforcement and metal frames	41
Figure A.4 – Volume for electrical and electronic systems inside an inner LPZ n.....	42
Figure A.5 – Reducing induction effects by line routing and shielding measures.....	43
Figure A.6 – Example of SPM for an office building.....	45
Figure A.7 – Evaluation of the magnetic field values in case of a direct lightning strike	46
Figure A.8 – Evaluation of the magnetic field values in case of a nearby lightning strike	48
Figure A.9 – Distance s_a depending on rolling sphere radius and structure dimensions	50
Figure A.10 – Types of grid-like large volume shields	52
Figure A.11 – Magnetic field strength $H_{1/MAX}$ inside a grid-like shield type 1.....	53
Figure A.12 – Magnetic field strength $H_{1/MAX}$ inside a grid-like shield type 1 according to mesh width.....	53
Figure A.13 – Low-level test to evaluate the magnetic field inside a shielded structure	55
Figure A.14 – Voltages and currents induced into a loop formed by lines.....	56
Figure B.1 – SPM design steps for an existing structure	63
Figure B.2 – Possibilities to establish LPZs in existing structures	67
Figure B.3 – Reduction of loop area using shielded cables close to a metal plate.....	69
Figure B.4 – Example of a metal plate for additional shielding.....	70
Figure B.5 – Protection of aerials and other external equipment.....	71
Figure B.6 – Inherent shielding provided by bonded ladders and pipes.....	72
Figure B.7 – Ideal positions for lines on a mast (cross-section of steel lattice mast)	72
Figure B.8 – Upgrading of the SPM in existing structures.....	74
Figure C.1 – Surge voltage between live conductor and bonding bar.....	79
Figure D.1 – Installation example of test Class I, Class II and Class III SPDs	83
Figure D.2 – Basic example for different sources of damage to a structure and lightning current distribution within a system.....	84
Figure D.3 – Basic example of balanced current distribution	85
Table 1 – Minimum cross-sections for bonding components	30
Table 2 – SPM management plan for new buildings and for extensive changes in construction or use of buildings.....	33
Table A.1 – Parameters relevant to source of harm and equipment.....	38
Table A.2 – Examples for $I_{0/MAX} = 100$ kA and $w_m = 2$ m	48
Table A.3 – Magnetic attenuation of grid-like spatial shields for a plane wave.....	49
Table A.4 – Rolling sphere radius corresponding to maximum lightning current.....	51
Table A.5 – Examples for $I_{0/MAX} = 100$ kA and $w_m = 2$ m corresponding to $SF = 12,6$ dB	51
Table B.1 – Structural characteristics and surroundings	60
Table B.2 – Installation characteristics.....	61
Table B.3 – Equipment characteristics	61

Table B.4 – Other questions to be considered for the protection concept.....	61
Table D.1 – Preferred values of I_{imp}	82

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PROTECTION AGAINST LIGHTNING –

Part 4: Electrical and electronic systems within structures

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62305-4 has been prepared by IEC technical committee 81: Lightning protection.

This second edition cancels and replaces the first edition, published in 2006, and constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- 1) Isolating interfaces capable of reducing conducted surges on lines entering the structure are introduced.
- 2) Minimum cross-sections for bonding components are slightly modified.
- 3) First negative impulse current is introduced for calculation purposes as electromagnetic source of harm to the internal systems.
- 4) Selection of SPD with regard to voltage protection level is improved to take into account oscillation and induction phenomena in the circuit downstream of SPD.
- 5) Annex C dealing with SPD coordination is withdrawn and referred back to SC 37A.

- 6) A new informative Annex D is introduced giving information on factors to be considered in the selection of SPDs.

The text of this standard is based on the following documents:

FDIS	Report on voting
81/373/FDIS	81/383/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted, as closely as possible, in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 62305 series, under the general title *Protection against lightning*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this standard may be issued at a later date.

INTRODUCTION

Lightning as a source of harm is a very high energy phenomenon. Lightning flashes release many hundreds of mega-joules of energy. When compared with the milli-joules of energy that may be sufficient to cause damage to sensitive electronic equipment in electrical and electronic systems within a structure, it is clear that additional protection measures will be necessary to protect some of this equipment.

The need for this International Standard has arisen due to the increasing cost of failures of electrical and electronic systems, caused by electromagnetic effects of lightning. Of particular importance are electronic systems used in data processing and storage as well as process control and safety for plants of considerable capital cost, size and complexity (for which plant outages are very undesirable for cost and safety reasons).

Lightning can cause different types of damage in a structure, as defined in IEC 62305-1:

- D1 injury to living beings by electric shock;
- D2 physical damage (fire, explosion, mechanical destruction, chemical release) due to lightning current effects, including sparking;
- D3 failure of internal systems due to LEMP.

IEC 62305-3 deals with the protection measures to reduce the risk of physical damage and life hazard, but does not cover the protection of electrical and electronic systems.

This Part 4 of IEC 62305 therefore provides information on protection measures to reduce the risk of permanent failures of electrical and electronic systems within structures.

Permanent failure of electrical and electronic systems can be caused by the lightning electromagnetic impulse (LEMP) via:

- a) conducted and induced surges transmitted to equipment via connecting wiring;
- b) the effects of radiated electromagnetic fields directly into equipment itself.

Surges to the structure can originate from sources external to the structure or from within the structure itself:

- surges which originate externally from the structure are created by lightning flashes striking incoming lines or the nearby ground, and are transmitted to electrical and electronic systems within the structure via these lines;
- surges which originate internally within the structure are created by lightning flashes striking the structure itself or the nearby ground.

NOTE 1 Surges can also originate internally within the structure, from switching effects, e.g. switching of inductive loads.

The coupling can arise from different mechanisms:

- resistive coupling (e.g. the earth impedance of the earth-termination system or the cable shield resistance);
- magnetic field coupling (e.g. caused by wiring loops in the electrical and electronic system or by inductance of bonding conductors);
- electric field coupling (e.g. caused by rod antenna reception).

NOTE 2 The effects of electric field coupling are generally very small when compared to the magnetic field coupling and can be disregarded.

Radiated electromagnetic fields can be generated via

- the direct lightning current flowing in the lightning channel,
- the partial lightning current flowing in conductors (e.g. in the down-conductors of an external LPS in accordance with IEC 62305-3 or in an external spatial shield in accordance with this standard).

PROTECTION AGAINST LIGHTNING –

Part 4: Electrical and electronic systems within structures

1 Scope

This part of IEC 62305 provides information for the design, installation, inspection, maintenance and testing of electrical and electronic system protection (SPM) to reduce the risk of permanent failures due to lightning electromagnetic impulse (LEMP) within a structure.

This standard does not cover protection against electromagnetic interference due to lightning, which may cause malfunctioning of internal systems. However, the information reported in Annex A can also be used to evaluate such disturbances. Protection measures against electromagnetic interference are covered in IEC 60364-4-44 ^[1] ¹ and in the IEC 61000 series ^[2].

This standard provides guidelines for cooperation between the designer of the electrical and electronic system, and the designer of the protection measures, in an attempt to achieve optimum protection effectiveness.

This standard does not deal with detailed design of the electrical and electronic systems themselves.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60364-5-53:2001, *Electrical installations of buildings – Part 5-53: Selection and erection of electrical equipment – Isolation, switching and control*

IEC 60664-1:2007, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 61000-4-5:2005, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-9:1993, *Electromagnetic compatibility (EMC) – Part 4-9: Testing and measurement techniques – Pulse magnetic field immunity test – Basic EMC Publication*

IEC 61000-4-10:1993, *Electromagnetic compatibility (EMC) – Part 4-10: Testing and measurement techniques – Damped oscillatory magnetic field immunity test – Basic EMC Publication*

IEC 61643-1:2005, *Low-voltage surge protective devices – Part 1: Surge protective devices connected to low-voltage power distribution systems – Requirements and tests*

IEC 61643-12:2008, *Low-voltage surge protective devices – Part 12: Surge protective devices connected to low-voltage power distribution systems – Selection and application principles*

¹ Figures in square brackets refer to the bibliography.

IEC 61643-21, *Low voltage surge protective devices – Part 21: Surge protective devices connected to telecommunications and signalling networks – Performance requirements and testing methods*

IEC 61643-22, *Low voltage surge protective devices – Part 22: Surge protective devices connected to telecommunications and signalling networks – Selection and application principles*

IEC 62305-1:2010, *Protection against lightning – Part 1: General principles*

IEC 62305-2:2010, *Protection against lightning – Part 2: Risk management*

IEC 62305-3:2010, *Protection against lightning – Part 3: Physical damage to structures and life hazard*