

This is a preview - click here to buy the full publication

TECHNICAL REPORT

IEC TR 62331

First edition
2005-02

Pulsed field magnetometry

© IEC 2005 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE

W

For price, see current catalogue

CONTENTS

FOREWORD	4
INTRODUCTION	6
1 Scope and object.....	7
2 Normative references	7
3 Pulsed field magnetometer (PFM).....	7
3.1 General principles	8
3.2 Size of test specimen	10
4 Field generator.....	10
4.1 General.....	10
4.2 Power supply.....	10
4.3 Magnetizing solenoid.....	14
5 Polarization and magnetic field strength sensors (pick-up coils)	14
5.1 General.....	14
5.2 The polarization sensor (<i>J</i> coil).....	15
5.3 The magnetic field strength sensor (<i>H</i> coil).....	16
6 Transient instrumentation and digitizing hardware.....	16
6.1 General.....	16
6.2 Analogue integration and digitization	17
6.3 Digitization and numerical integration	17
6.4 Digitization rate	17
7 Data processing	17
7.1 Data processing elements	18
7.2 Temperature.....	23
7.3 Magnetic viscosity	25
7.4 Calibration.....	25
8 Comparison of measurements	29
8.1 Permeameter, “large magnet“ comparison.....	29
8.2 Extraction method, “small” test specimen comparison	30
8.3 Comparative measurement conclusions	33
9 Conclusion	33
Bibliography	34
Figure 1 – <i>M'</i> and <i>H</i> time traces for a permanent magnet.....	9
Figure 2 – <i>J(H)</i> and <i>B(H)</i> loop for a permanent magnet	9
Figure 3 – Sine wave (decaying) electrical configuration	11
Figure 4 – Unidirectional pulses (1/2 sine wave) electrical configuration	12
Figure 5 – Unidirectional pulses (decaying) electrical configuration	12
Figure 6 –Three arrangements of <i>J</i> coil assembly configurations (drawing with permission of EMAJ [ref. 30]).....	15
Figure 7 – <i>M</i> and <i>H</i> time traces and $\Phi(H)$ plot of a “zero signal”	19
Figure 8 – <i>J(H)</i> loops of a sintered NdFeB permanent magnet.....	23

Figure 9 – $J(H)$ loop including eddy currents of a conductive bulk nickel specimen measurement result from a PFM system	27
Figure 10 – Copper specimen eddy current measurement result.....	27
Figure 11 – $J(H)$ loop for eddy current “corrected” nickel specimen	28
Figure 12 – Results of a permeameter and a PFM measurement of a “large” specimen.....	29
Figure 13 – Detail of the 1 st and 2 nd quadrants of the measurement results shown in Figure 12 “large magnet”	29
Figure 14 – Comparison of a “small magnet” measured in a super-conducting, extraction method magnetometer (EMM) compared with a PFM measurement result of the same magnet [28]	30
Figure 15 – Measurement result of a NEOMAX 32EH NdFeB cylinder of diameter 10 mm length 7 mm on the TPM-2-10 system [34].....	31
Figure 16 – Measurement result of a NEOMAX 32EH NdFeB cube of dimensions 7 mm × 7 mm × 7 mm [34].....	32
Figure 17 – Measurement result of a sintered Sm2Co17 cylinder of diameter 10 mm and length 7 mm [34]	33
Table 1 – Comparison of methods of generating the magnetic field strength	13
Table 2 – Classification of the influences of eddy currents.....	21
Table 3 – A comparison of values taken from the measurement results presented in Figure 11 and Figure 12.....	30
Table 4 – Comparison of values measured in Figure 14 above (see NOTE)	30

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PULSED FIELD MAGNETOMETRY

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC 62331, which is a technical report, has been prepared by IEC technical committee 68: Magnetic alloys and steels.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
68/299/DTR	68/303/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

In order to measure the full magnetic characterization of magnetically hard (permanent magnet) materials, it is necessary to apply a magnetic field sufficient to saturate the test specimen of magnetic material.

The generation of this magnetic field can become a practical limiting factor and can determine the appropriate measurement techniques.

Super-conducting magnets can generate very high static or slowly changing magnetic fields but their complexity, high capital outlay and running costs, requiring cryogenic gases make them far from ideal. It is necessary to change fields slowly to avoid “quenching” the super-conducting magnet.

Conventionally wound electro-magnets with slowly changing magnetic fields have a significant heat generation problem through I^2R loss. This can be alleviated through the use of a high relative permeability “iron yoke”. However, saturation of the iron prevents maximum characterization of the loop of rare earth permanent magnet materials to be determined.

A pulsed field system utilizing conventional conductors minimizes heating effects by limiting field durations and by limiting heat generation to acceptable levels. Fields up to 40 Tesla (T) can be generated in this way.

Careful consideration, however, must be given to the instrumentation and method to take account of dynamic effects due to the short duration of the magnetic field.

While work on pulsed field magnetometry is carried out in many parts of the world, the two main groups are MACCHARETEC [ref. 29]¹ in Europe and EMAJ [ref. 30] in Japan. The approach adopted in Japan is one of supporting a standard with fixed specimen sizes, magnetic field strengths and frequencies in a limited number of configurations.

¹ References in square brackets refer to the bibliography.

PULSED FIELD MAGNETOMETRY

1 Scope and object

This Technical Report reviews methods for measuring magnetically hard materials using pulsed field magnetometers.

The methods of measurement of the magnetic properties of magnetically hard materials have been specified in IEC 60404-5 for closed magnetic circuits and in IEC 60404-7 for open magnetic circuits. The measurement result of the magnetic properties of magnetically hard materials at elevated temperatures is given in IEC 61807.

Pulsed field magnetometers have been developed to provide rapid measurement facilities to match high speed production rates with 100 % quality control.

The object of this report is to describe the principles and practical implications of pulsed field magnetometry in order to enable the full potential of the technique to be considered, including its application using small and large magnets of varying geometries, to various magnetic field strengths and frequencies.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60404-5:1993, *Magnetic materials – Part 5: Permanent magnet (magnetically hard) materials – Methods of measurement of magnetic properties*

IEC 60404-7:1982, *Magnetic materials – Part 7: Method of measurement of coercivity of magnetic materials in an open magnetic circuit*

IEC 61807:1999, *Magnetic properties of magnetically hard materials at elevated temperatures – Methods of measurement*

IEC 60404-14:2002, *Magnetic materials – Part 14: Methods of measurement of the magnetic moment of ferromagnetic material specimen by the withdrawal or rotation method*