

This is a preview - click here to buy the full publication



IEC 60079-25

Edition 3.0 2020-03

# PRE-RELEASE VERSION (FDIS)

---

## Explosive atmospheres – Part 25: Intrinsically safe electrical systems

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 29.260.20

**Warning! Make sure that you obtained this publication from an authorized distributor.**



## FINAL DRAFT INTERNATIONAL STANDARD (FDIS)

PROJECT NUMBER:

**IEC 60079-25 ED3**

DATE OF CIRCULATION:

**2020-03-20**

CLOSING DATE FOR VOTING:

**2020-05-01**

SUPERSEDES DOCUMENTS:

**31G/294/CDV, 31G/305A/RVC**

IEC SC 31G : INTRINSICALLY-SAFE APPARATUS	
SECRETARIAT: United Kingdom	SECRETARY: Mr Nicholas Ludlam
OF INTEREST TO THE FOLLOWING COMMITTEES: TC 18,SC 31J	HORIZONTAL STANDARD: <input type="checkbox"/>
FUNCTIONS CONCERNED: <input type="checkbox"/> EMC <input type="checkbox"/> ENVIRONMENT <input type="checkbox"/> QUALITY ASSURANCE <input type="checkbox"/> SAFETY	
<input checked="" type="checkbox"/> SUBMITTED FOR CENELEC PARALLEL VOTING  <b>Attention IEC-CENELEC parallel voting</b>  The attention of IEC National Committees, members of CENELEC, is drawn to the fact that this Final Draft International Standard (FDIS) is submitted for parallel voting.  The CENELEC members are invited to vote through the CENELEC online voting system.	<input type="checkbox"/> NOT SUBMITTED FOR CENELEC PARALLEL VOTING

This document is a draft distributed for approval. It may not be referred to as an International Standard until published as such.

In addition to their evaluation as being acceptable for industrial, technological, commercial and user purposes, Final Draft International Standards may on occasion have to be considered in the light of their potential to become standards to which reference may be made in national regulations.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

TITLE:

**Explosive atmospheres - Part 25: Intrinsically safe electrical systems**

PROPOSED STABILITY DATE: 2025

NOTE FROM TC/SC OFFICERS:

## CONTENTS

FOREWORD .....	4
1 Scope .....	9
2 Normative references .....	9
3 Terms and definitions .....	9
4 Descriptive system document .....	11
5 Grouping and temperature classification .....	11
6 Levels of Protection .....	11
6.1 General .....	11
6.2 Level of Protection “ia” .....	12
6.3 Level of Protection “ib” .....	12
6.4 Level of Protection “ic” .....	12
7 Non-intrinsically safe circuits .....	12
8 Interconnecting wiring / cables used in an intrinsically safe system .....	12
8.1 General .....	12
8.2 Cables containing a single intrinsically safe circuit .....	12
8.3 Cables containing more than one intrinsically safe circuit .....	12
9 Requirements of single and multi-circuit cables .....	13
9.1 General .....	13
9.2 Dielectric strength .....	13
9.2.1 Cables containing a single intrinsically safe circuit .....	13
9.2.2 Cables containing more than one intrinsically safe circuit .....	13
9.3 Intrinsic safety parameters of cables .....	13
9.4 Conducting screens .....	14
9.5 Types of multi-circuit cables .....	14
9.5.1 General .....	14
9.5.2 Type A cable .....	14
9.5.3 Type B cable .....	14
9.5.4 Type C cable .....	14
10 Enclosures .....	14
11 Earthing and bonding of intrinsically safe systems .....	14
12 Assessment of an intrinsically safe system .....	15
12.1 General .....	15
12.2 Systems containing only apparatus certified to IEC 60079-11 .....	15
12.3 Systems containing apparatus not separately evaluated to IEC 60079-11 .....	15
12.4 Systems containing a single power source .....	15
12.5 Systems containing more than one power source .....	16
12.5.1 General .....	16
12.5.2 Systems containing linear and non-linear sources of power .....	16
12.6 Simple apparatus .....	18
12.7 Assessment of capacitance, inductance and cable L/R .....	18
12.7.1 General .....	18
12.7.2 Unspecified Parameters .....	18
12.7.3 Output Parameter adjustments for Level of Protection .....	18
12.7.4 Effect of combined lumped capacitance and inductance .....	18
12.7.5 Determination of L/R .....	18

12.8	Faults in multi-circuit cables.....	19
12.9	Type verifications and type tests.....	19
13	Predefined systems.....	19
Annex A (informative)	Assessment of a simple intrinsically safe system.....	20
Annex B (informative)	Assessment of circuits with more than one power source.....	22
Annex C (informative)	Interconnection of non-linear and linear intrinsically safe circuits.....	25
C.1	General.....	25
C.2	Assessment of the output characteristics of the power sources.....	25
C.3	Assessment of interconnection possibilities and resultant output characteristics.....	28
C.4	Determination of intrinsic safety and the use of graphs.....	31
C.5	Verification against IEC 60079-11.....	33
C.6	Illustration of the procedure.....	33
C.7	Limit curves for universal source characteristic.....	37
Annex D (informative)	Verification of inductive parameters.....	48
Annex E (informative)	Example format for a descriptive system document.....	50
Annex F (informative)	Use of simple apparatus in systems.....	52
F.1	General.....	52
F.2	Use of apparatus with 'simple apparatus'.....	53
Annex G (normative)	FISCO systems.....	54
G.1	General.....	54
G.2	System requirements.....	54
G.2.1	General.....	54
G.3	Additional requirements of "ic" FISCO systems.....	55
Bibliography	.....	57
Figure 1	– Systems analysis.....	17
Figure B.1	– Power sources connected in series.....	23
Figure B.2	– Power sources connected in parallel.....	24
Figure B.3	– Power sources not deliberately connected.....	24
Figure C.1	– Equivalent circuit and output characteristic of resistive circuits.....	26
Figure C.2	– Output characteristic and equivalent circuit of a source with trapezoidal characteristic.....	28
Figure C.3	– Current and/or voltage addition for interconnections.....	31
Figure C.4	– Example of an interconnection.....	33
Figure C.5	– Sum characteristics for the circuit as given in Figure C.4.....	35
Figure C.6	– Current and/or voltage addition for the example given in Figure C.4.....	36
Figure C.7	– Limit curve diagram for universal source characteristic – Group IIC.....	42
Figure C.8	– Limit curve diagram for universal source characteristic – Group IIB.....	47
Figure D.1	– Typical inductive circuit.....	49
Figure E.1	– Typical block diagram for IS system descriptive system document.....	51
Figure G.1	– Typical system.....	56
Table A.1	– Simple system analysis.....	21
Table C.1	– Parameters necessary to describe the output characteristic.....	26
Table C.2	– Assignment of diagrams to equipment Groups and inductances.....	32

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### EXPLOSIVE ATMOSPHERES –

### Part 25: Intrinsically safe electrical systems

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-25 has been prepared by subcommittee 31G: Intrinsically safe apparatus, of IEC technical committee 31: Equipment for explosive atmospheres.

This third edition cancels and replaces the second edition published in 2010 and constitutes a technical revision.

The significance of the changes between IEC 60079-25, Edition 2 (2010) and IEC 60079-25, Edition 3 (2019) are as listed below:

Changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
References to 'electrical systems' changed to 'systems' and note added that installation requirement for Group I are being considered.	1	X		
Normative references updated to remove references that were outdated or not mentioned in the body of the standard.	2	X		
Reference to IEC Electropedia and ISO Online Browsing platform added, abbreviations dropped from title. Definition of 'system designer' deleted, definitions of 'certified intrinsically safe electrical system', and 'uncertified intrinsically safe electrical system' dropped.	3	X		
'Intrinsically safe electrical system' changed to 'intrinsically safe system'.	3.1	X		
Definition for 'multi-circuit cable' added.	3.2	X		
'Maximum' changed to 'total' on definitions of cable capacitance and cable inductance.	3.4, 3.5	X		
'Maximum' deleted on definition of cable inductance to resistance ratio.	3.6	X		
FISCO changed to definition from abbreviation.	3.9	X		
The requirement for the system designer to sign and date the document dropped, editorial changes for clarity made, and a reference to Annex E made to show typical descriptive system documents.	4	X		
Title of clause changed to 'Grouping and temperature classification', ambient temperature range added to things to be included in the system document and reworded for clarity.	5		X	
Notes moved and reworded among the clauses.	6.1, 6.2, 6.3, 6.4	X		
Changed from 'Ambient temperature rating' which was moved to Clause 5, and new section renamed 'Non-intrinsically safe circuits' added.	7		X	
Clause reorganized into sections and some rewording done for clarity.	8	X		
Title changed to 'Requirements of single and multi-circuit cables'.	9	X		
Requirement for insulation thickness moved into this clause, and it now applies to all cables.	9.1		X	
Title changed to 'Dielectric strength' and consolidation of requirements for single circuit and multi-circuit cables. Requirement for dielectric testing changed to twice the circuit voltage with a minimum of 500VAC.	9.2		X	
Dielectric strength requirements for single circuit cables consolidated here.	9.2.1	X		
Dielectric strength requirements for multi-circuit cables consolidated here.	9.2.2	X		
Multi-circuit cables shall not be used for intrinsically safe circuits with voltages exceeding 90 V.	9.2.2			C1
Title changed to 'Intrinsic safety parameters of cables'	9.3	X		

Changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Title changed to 'Enclosures'	10	X		
Most of the old Clause 12 moved to IEC 60079-14.	11			C2
This clause was Clause 13 in the previous edition, and the entire clause has been re-arranged for clarity and easier reading.	12	X		
This General clause has been re-written in list format to make it easier to understand, and analysis of single and multiple power supplies moved to 12.4 and 12.5 respectively.	12.1		X	
This clause added to clarify fault applications in assemblies of certified equipment.	12.2		X	
This clause added to provide guidance on how to handle non-certified items in larger assemblies.	12.3		X	
Analysis of single power source information consolidated here and amplified.	12.4		X	
Analysis of multiple power sources information consolidated in this clause. Information added for clarity.	12.5		X	
The circuit analysis example dropped in text for simple apparatus, new Annex F added with more information.	12.6	X		
Section added to provide more information on determining capacitance, inductance and L/R that was moved from Annex A.	12.7		X	
Requirements for Type A, B, and C cables reworded for clarity.	12.8	X		
Information on evaluation of capacitance and inductance moved to 12.7.	Annex A	X		
Changed from normative to informative	Annex B	X		
Reordered and rewritten for greater clarity.	Annex C	X		
Annex updated for clarity.	Annex E	X		
The former Annex F on surge protection has been removed.	Annex F			C3
Annex G in the previous edition was on testing of cable parameters and has been removed from this edition. Annex G is now FISCO systems.	Annex G	X		

NOTE The technical changes referred to include the significance of technical changes in the revised IEC Standard, but they do not form an exhaustive list of all modifications from the previous version. More guidance may be found by referring to the Redline Version of the standard.

**Explanations:**

**A) Definitions**

**Minor and editorial changes**

clarification  
decrease of technical requirements  
minor technical change  
editorial corrections

These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

**Extension**

addition of technical options

These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition.

**Major technical changes**

addition of technical requirements  
increase of technical requirements

These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfil the requirements given in the later edition. These changes have to be considered for products in conformity with the preceding edition. For these changes additional information is provided in clause B) below.

NOTE These changes represent current technological knowledge. However, these changes should not normally have an influence on equipment already placed on the market.

**B) Information about the background of ‘Major Technical Changes’**

B1 – A limitation of 90 V for multi-circuit system has been added since for this voltage level a dielectric test of at least 500 V AC or 700 V DC is normally used to validate the insulation.

B2 – Most of the earthing and bonding requirements have been removed and moved to IEC 60079-14, and the surge protection requirements that were in the old Clause 12 were added here in Clause 11. The rest of the old Clause 12 was also removed and moved to IEC 60079-14.

B3 – The former Annex F on surge protection has been removed and will be covered in IEC 60079-14. Annex F is now Simple Apparatus, which was Annex H in the previous edition.

The text of this standard is based on the following documents:

FDIS	Report on voting
31G/XX/FDIS	31G/XX/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.



A list of all parts in the IEC 60079 series, published under the general title *Explosive atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## EXPLOSIVE ATMOSPHERES –

### Part 25: Intrinsically safe electrical systems

#### 1 Scope

This part of IEC 60079 contains the specific requirements for design, construction and assessment of intrinsically safe systems, Type of Protection “i”, intended for use, as a whole or in part, in locations in which the use of Group I, II or III Ex Equipment is required.

NOTE 1 This standard is intended for use by the designer of the system e.g. a person who could be a manufacturer, a specialist consultant or a member of the end-user’s staff.

This document supplements and modifies the general requirements of IEC 60079-0 and the intrinsic safety standard IEC 60079-11. Where a requirement of this standard conflicts with a requirement of IEC 60079-0 or IEC 60079-11, the requirement of this standard takes precedence.

The installation requirements of Group II or Group III systems designed in accordance with this standard are specified in IEC 60079-14.

NOTE 2 Group I installation requirements are presently not provided in IEC 60079-14. Installation requirements for Group I are being considered.

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60079-11, *Explosive atmospheres – Part 11: Equipment protection by intrinsic safety “i”*

IEC 60079-14, *Explosive atmospheres – Part 14: Electrical installations design, selection and erection*

IEC 61158-2, *Industrial communication networks – Fieldbus specifications – Part 2: Physical layer specification and service definition*