

PRE-RELEASE VERSION (FDIS)



Safety in installations for electroheating and electromagnetic processing – Part 4: Particular requirements for arc furnace installations

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 25.180.10

Warning! Make sure that you obtained this publication from an authorized distributor.



FINAL DRAFT INTERNATIONAL STANDARD (FDIS)

PROJECT NUMBER: IEC 60519-4 ED5	
DATE OF CIRCULATION: 2021-10-08	CLOSING DATE FOR VOTING: 2021-11-19
SUPERSEDES DOCUMENTS: 27/1135/CDV, 27/1140/RVC	

IEC TC 27 : INDUSTRIAL ELECTROHEATING AND ELECTROMAGNETIC PROCESSING	
SECRETARIAT: Poland	SECRETARY: Mrs Mariola Nowecka
OF INTEREST TO THE FOLLOWING COMMITTEES:	HORIZONTAL STANDARD: <input type="checkbox"/>
FUNCTIONS CONCERNED: <input type="checkbox"/> EMC <input type="checkbox"/> ENVIRONMENT <input type="checkbox"/> QUALITY ASSURANCE <input checked="" type="checkbox"/> SAFETY	
<input checked="" type="checkbox"/> SUBMITTED FOR CENELEC PARALLEL VOTING Attention IEC-CENELEC parallel voting The attention of IEC National Committees, members of CENELEC, is drawn to the fact that this Final Draft International Standard (FDIS) is submitted for parallel voting. The CENELEC members are invited to vote through the CENELEC online voting system.	<input type="checkbox"/> NOT SUBMITTED FOR CENELEC PARALLEL VOTING

This document is a draft distributed for approval. It may not be referred to as an International Standard until published as such.

In addition to their evaluation as being acceptable for industrial, technological, commercial and user purposes, Final Draft International Standards may on occasion have to be considered in the light of their potential to become standards to which reference may be made in national regulations.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

TITLE:
Safety in electroheating installations - Part 4: Particular requirements for arc furnace installations

PROPOSED STABILITY DATE: 2027

NOTE FROM TC/SC OFFICERS:

CONTENTS

FOREWORD	6
INTRODUCTION	9
1 Scope	10
2 Normative references	10
3 Terms, definitions and abbreviated terms	11
3.1 General concepts	11
3.2 Equipment and state of equipment	11
3.3 Parts and accessories	14
3.4 Safety related concepts	14
3.5 Abbreviated terms	14
4 Classification and subdivision of equipment and installations	14
4.1 Classification by processing frequency	14
4.2 Classification by voltage	14
4.3 Subdivision of installation and equipment	14
4.4 Classification of hazards and risks	14
5 Risk assessment	15
6 General provisions	15
6.1 Basic considerations	15
6.2 Significant hazards	15
6.3 Physical environment and operating conditions for the installation as such and electrical equipment outside the processing equipment	15
6.4 Physical environment and operating conditions for electrical equipment caused by operation of the processing equipment	16
6.5 Power supply	16
6.6 Access	17
6.7 Ergonomic aspects	17
6.8 Transport and storage	17
6.9 Provisions for handling	17
6.10 Consumables and replaceable parts	18
7 Protection against hazards from electric shock	18
7.1 General	18
7.2 Fundamental rule of protection	18
7.3 General provisions	18
7.4 Basic protection	19
7.5 Provisions for protection in electric single fault condition	19
7.6 Protective equipotential bonding	19
7.7 Additional provisions for fault protection for frequencies above 200 Hz	20
7.8 Currents in protective conductors	20
7.9 Touch current and touch voltage	20
7.10 Conductors and insulations at high temperature	20
7.11 Non-electric faults	20
8 Protection against hazards from electric or magnetic fields	20
8.1 General	20
8.2 Magnetic fields	21
8.3 Magnetic fields below 1 Hz	21

8.4	Local electric fields.....	21
8.5	Requirements related to barriers and screens.....	21
8.6	Requirements related to objects worn, carried or held by persons	21
9	Protection against hazards from radiation	21
9.1	General.....	21
9.2	Installation or equipment generating ionizing radiation	21
9.3	Ultraviolet radiation.....	21
9.4	Visible and infrared radiation.....	21
9.5	Laser sources.....	22
10	Protection against hazards from thermal influences.....	22
10.1	General.....	22
10.2	Surface temperature limits for protection against burn.....	22
10.3	Hazards caused by working conditions	22
10.4	Temperature resistance of components	22
10.5	Cooling	23
10.6	Over-temperature protection	23
11	Protection against hazards from fire.....	23
12	Protection against hazards from fluids	23
13	Specific requirements for components and subassemblies	23
13.1	General.....	23
13.2	Electrical equipment and conductors	23
13.3	Connection to the electrical supply network and internal connections	24
13.4	Isolation and switching.....	24
13.5	Sensors and actuators safeguarding moving parts	26
13.6	Motors.....	26
13.7	Non electric-heating means.....	26
13.8	Lighting	26
13.9	Structural parts and stability.....	27
13.10	Doors, windows and other openings	27
13.11	Transformers, inductors, capacitors.....	27
13.12	Handheld applicators	27
13.13	Vacuum systems	27
13.14	Protective and reactive gas generator	27
14	Control of the installation or equipment.....	27
14.1	General.....	27
14.2	Operator control unit.....	27
14.3	Emergency stop.....	28
14.4	Control systems and their safety functions.....	28
14.5	Controlgear	28
14.6	Protective devices	28
14.7	Over-temperature protection devices and systems.....	28
14.8	Overpressure safety device.....	28
15	Protection against mechanical hazards	29
16	Protection against hazards resulting from use	29
16.1	Particular hazards in processing of food, feed, cosmetics and similar intended for human or animal consumption.....	29
16.2	Combination equipment	29
17	EMC	29

17.1	Radio frequency interference	29
17.2	Immunity	29
18	Verification and testing.....	29
18.1	General.....	29
18.2	Performing measurements and tests	31
18.3	Verification of requirements from references.....	31
18.4	Examination of drawings or calculations	31
18.5	Visual inspection	31
18.6	Measurements.....	32
18.6.1	Environment and operating conditions inside the processing equipment	32
18.6.2	Impedance of protective bonding.....	32
18.6.3	Insulation resistance measurement	32
18.6.4	Measurement of electric or magnetic fields.....	34
18.6.5	Touch current measurement	34
18.6.6	Measurement of ionising radiation.....	34
18.6.7	Measurement of non-coherent optical irradiation.....	34
18.6.8	Measurement of coherent optical radiation	34
18.6.9	Surface temperature measurement	34
18.6.10	Temperature of structural components subject to heat	34
18.7	Functional tests	34
18.7.1	Protection by automatic disconnection of supply	34
18.7.2	Voltage test.....	34
18.7.3	Dielectric test	34
18.7.4	Accessibility of live parts.....	35
18.8	Numerical calculations and modelling.....	35
19	Information for use	35
19.1	General requirements	35
19.2	Location and nature of the information for use	35
19.3	Signalling and warning devices	35
19.4	Markings, pictograms, written warnings	35
19.5	Instruction handbook	35
Annex A (normative)	Lists of significant hazards	37
Annex B (normative)	Limits to touch currents	38
Annex C (normative)	Non coherent optical radiation – Limits and risk classes	39
Annex D (normative)	Electric and magnetic fields.....	40
Annex E (normative)	Surface temperature limits.....	41
Annex F (normative)	EH, EMP and fire.....	42
Annex G (normative)	Marking and warning.....	43
Annex H (normative)	Guidelines on using this document.....	44
Annex I (informative)	Connection with ISO 13577 (all parts)	45
Annex J (informative)	Requirements specific to the EU and associated countries	46
Annex AA (normative)	Systems to assure improved safety for personnel working in the vicinity of electrodes and other live parts of secondary circuit.....	47
Annex BB (normative)	Limits to touch currents	53
Bibliography.....		54
Figure AA.1 – AC furnace supply according to design arrangements "a"		49

Figure AA.2 – AC furnace supply according to design arrangements "b"	49
Figure AA.3 – AC furnace supply according to design arrangements "c"	50
Figure AA.4 – DC furnace supply according to design arrangements "d"	51
Figure AA.5 – DC furnace supply according to design arrangements "e"	51
Figure AA.6 – Six electrode AC furnace supply with current converter according to design arrangements "f"	52
Table 1 – Methods for the verification of requirements.....	30
Table 101 – Test voltages of the Insulation measurement.....	33
Table 102 – Installation progress of EAF and LF	33

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SAFETY IN INSTALLATIONS FOR ELECTROHEATING AND ELECTROMAGNETIC PROCESSING –

Part 4: Particular requirements for arc furnace installations

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60519-4 has been prepared by IEC technical committee 27: Industrial electroheating and electromagnetic processing. It is an International Standard.

This fifth edition cancels and replaces the fourth edition published in 2013. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the structure has been redrafted according to IEC 60519-1:2020;
- b) the scope and object have been redrafted;
- c) the terms and definitions, normative references and bibliography have been updated and completed;
- d) the requirements have been redrafted according to IEC 60519-1:2020;
- e) all provisions have been redrafted and the text is more concise with respect to submerged arc furnace installations;

- f) the annexes have been restructured, with respect to details concerning high voltage designs and non-electrical issues, however to be aware of in those installations;
- g) the aspect of noise has been removed from the scope;
- h) the EMC requirements have been clarified;
- i) risk classification of hazards have been based on emission;
- j) the boundaries to ISO 13577 (all parts) and ISO 13578 have been clarified.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
27/XX/FDIS	27/XX/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

A list of all parts in the IEC 60519 series, published under the general title *Safety in installations for electroheating and electromagnetic processing*, can be found on the IEC website.

The clauses of this standard supplement or modify the corresponding clauses of IEC 60519-1:2020 (*General Requirements* hereinafter called "Part 1").

This part of IEC 60519 is to be read in conjunction with Part 1. It supplements or modifies the corresponding clauses of Part 1. Where the text indicates an "addition" to or a "replacement" of the relevant provision of Part 1, these changes are made to the relevant text of Part 1. Where no change is necessary, the words "This clause of Part 1 is applicable" are used. When a particular subclause of Part 1 is not mentioned in this part, that subclause applies as far as is reasonable.

Additional specific provisions to those in Part 1, given as individual clauses or subclauses, are numbered starting from 101.

NOTE The following numbering system is used:

- subclauses, tables and figures that are numbered starting from 101 are additional to those in Part 1;
- unless notes are in a new subclause or involve notes in Part 1, they are numbered starting from 101, including those in a replaced clause or subclause;
- additional annexes are lettered AA, BB, etc.

In this standard, the following print types are used:

- requirements and definitions: in roman type;
- NOTES: in smaller roman type;
- terms used throughout this standard which have been defined in Clause 3: in bold type.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This fifth edition of IEC 60519-4 is a product safety publication and is intended to:

- include all types of installations or equipment that are in the scope of IEC TC 27/MT 21 dealing with **arc furnace** installations;
- give requirements on electrical safety, **touch currents**, electric fields, magnetic fields and radiation;
- give means for verification of the requirements;
- make extensive use of the standards developed by IEC committees with horizontal or group safety functions and of relevant ISO standards, most of them being developed by ISO TC 244;
- include all material, references and requirements suitable for risk assessment and list of significant hazards.

This document addresses mainly **manufacturers** making made-to-order equipment on a single project base. The **manufacturer** is well aware that it is his responsibility to make equipment safe through adequate risk reduction and it is the responsibility of the **user** to assess **exposure** of the **operator** in line with applicable health and safety regulations. Looking at projects providing single pieces of equipment or single installations, this clear division of responsibilities tends to blur, caused by inter alia:

- development of the process (**normal operation**) through the **manufacturer** and **user**,
- shared definition of working procedures for the **operator** by the **manufacturer** and **user**,
- the scope of delivery often including all protective means,
- individual sales contracts where **users** require an assessment of **exposure** through the **manufacturer**.

Thus, this document provides information on electrical hazards and limits where relevant, despite being well aware that this is exceeding the scope of a product standard.

Annexes I and J provide orientation with respect to the application of ISO 13577-1 in combination with this document.

The rated voltage of an **arc furnace** Installation can be in the range of low voltage or high voltage; details are given in 4.2.

This document presumes that the installation or equipment is operated and maintained only by personnel consisting of **skilled** or **instructed persons**.

This document is intended for verifying whether the **arc furnace** installation meets the safety requirements of this document through design, site acceptance tests, routine tests or inspection.

SAFETY IN INSTALLATIONS FOR ELECTROHEATING AND ELECTROMAGNETIC PROCESSING –

Part 4: Particular requirements for arc furnace installations

1 Scope

This clause of Part 1 is replaced by the following.

Replacement:

This part of IEC 60519 provides particular safety requirements for arc furnace installations. This document deals with the significant hazards, hazardous situations or hazardous events relevant to industrial **arc furnace** installations, as listed in Annex A, for **normal operation** and for **single fault condition** as well as under conditions of reasonably foreseeable misuse.

This document specifies the requirements intended to be met by the **manufacturer** to ensure the safety of persons and property during the complete life cycle of the equipment from design through commissioning, operation, maintenance, inspection, to decommissioning, as well as in the event of foreseeable **single fault condition** that can occur in the equipment.

The rated voltage of **arc furnace** installation can be in the range of low voltage or high voltage, details are given in 4.2.

This standard is applicable to **arc furnace** installations such as:

- a) furnaces for direct arc heating, forming arcs between the electrode and metal such as the electric **arc furnace** using alternating current (**EAF AC**) or direct current (**EAF DC**), and the ladle furnace (**LF**);
- b) furnaces for arc-resistance heating forming arcs between the electrode and the charge material or heating the charge material by the Joule effect, such as the **submerged arc-resistance** furnace using alternating current (**SAF AC**), or direct current (**SAF DC**).

NOTE 1 In some documents, the terms "smelter" or "electrical reduction furnace" are used.

Furnace installation for unattended operation is not covered by this document.

This document does not provide requirements for type testing.

NOTE 2 Industrial equipment covered by this document is typically produced as a single unit or a very small number of units; such unit usually has a very high value and can cause severe harm at disintegration.

This document does not address data security and hazards arising from neglect of security.

With respect to noise of electrical an **arc furnace**, ISO 13578:2017, 6.1.23 applies.

EAF DC and **SAF DC** are classified as zero frequency (0 Hz) equipment types. **EAF AC**, **SAF AC** and **LF** are classified as mains frequency (50 Hz or 60 Hz) equipment types. Furnaces being operated at frequencies outside of the above-mentioned equipment types are not covered by this document.

2 Normative references

This clause of Part 1 is applicable except as follows.

Replacement:

IEC 61936-1:2021, *Power installations exceeding 1 kV AC and 1,5 kV DC - Part 1: AC*

Additions:

IEC 60060-3, *High-voltage test techniques – Part 3: Definitions and requirements for on-site testing*

IEC 60519-1:2020, *Safety in installations for electroheating and electromagnetic processing – Part 1: General requirements*

ISO 13577-1:2016, *Industrial furnaces and associated processing equipment – Safety – Part 1: General requirements*

ISO 13578:2017, *Industrial furnaces and associated processing equipment – Safety requirements for machinery and equipment for production of steel by electric arc furnaces*