

PRE-RELEASE VERSION (FDIS)



Switches for household and similar fixed electrical installations – Part 2-1: Particular requirements – Electronic control devices

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.120.40

Warning! Make sure that you obtained this publication from an authorized distributor.



This is a preview - click here to buy the full publication

23B/1326/FDIS

FINAL DRAFT INTERNATIONAL STANDARD (FDIS)

PROJECT NUMBER:

IEC 60669-2-1 ED5

DATE OF CIRCULATION:

2020-09-11

CLOSING DATE FOR VOTING:

2020-10-23

SUPERSEDES DOCUMENTS:

23B/1280/CDV, 23B/1284A/RVC

IEC SC 23B : PLUGS, SOCKET-OUTLETS AND SWITCHES	
SECRETARIAT: Italy	SECRETARY: Mr Cristiano Masini
OF INTEREST TO THE FOLLOWING COMMITTEES: TC 34, TC 72	HORIZONTAL STANDARD: <input type="checkbox"/>
FUNCTIONS CONCERNED: <input checked="" type="checkbox"/> EMC <input type="checkbox"/> ENVIRONMENT <input type="checkbox"/> QUALITY ASSURANCE <input checked="" type="checkbox"/> SAFETY	
<input checked="" type="checkbox"/> SUBMITTED FOR CENELEC PARALLEL VOTING Attention IEC-CENELEC parallel voting The attention of IEC National Committees, members of CENELEC, is drawn to the fact that this Final Draft International Standard (FDIS) is submitted for parallel voting. The CENELEC members are invited to vote through the CENELEC online voting system.	<input type="checkbox"/> NOT SUBMITTED FOR CENELEC PARALLEL VOTING

This document is a draft distributed for approval. It may not be referred to as an International Standard until published as such.

In addition to their evaluation as being acceptable for industrial, technological, commercial and user purposes, Final Draft International Standards may on occasion have to be considered in the light of their potential to become standards to which reference may be made in national regulations.

Recipients of this document are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

TITLE:

Switches for household and similar fixed electrical installations - Part 2-1: Particular requirements - Electronic control devices

PROPOSED STABILITY DATE: 2023

NOTE FROM TC/SC OFFICERS:

This document is not the final version, need further check from IEC Editor

Copyright © 2020 International Electrotechnical Commission, IEC. All rights reserved. It is permitted to download this electronic file, to make a copy and to print out the content for the sole purpose of preparing National Committee positions. You may not copy or "mirror" the file or printed version of the document, or any part of it, for any other purpose without permission in writing from IEC.

CONTENTS

FOREWORD	6
1 Scope	8
2 Normative references	9
3 Terms and definitions	11
4 General requirements	15
5 General remarks on tests	16
6 Ratings	17
7 Classification	18
8 Marking	19
9 Checking of dimensions	23
10 Protection against electrical shock	23
11 Provision for earthing	26
12 Terminals	26
13 Constructional requirements	26
14 Mechanism	29
15 Resistance to ageing, protection provided by enclosures of switches and resistance to humidity	29
16 Insulation resistance and electric strength	29
17 Temperature rise	31
18 Making and breaking capacity	35
19 Normal operation	37
20 Mechanical strength	44
21 Resistance to heat	45
22 Screws, current-carrying parts and connections	45
23 Creepage distances, clearances and distances through sealing compound	45
24 Resistance of insulating material to abnormal heat, to fire and to tracking	52
25 Resistance to rusting	52
26 EMC requirements	52
101 Abnormal conditions	62
102 Components	67
103 Electromagnetic fields (EMF)	71
Annex A (normative) <i>Replacement of title to Annex A as follows: Additional requirements for electronic control devices having facilities for the outlet and retention of flexible cables</i>	75
Annex B (informative) Changes planned for the future in order to align IEC 60669-1 with the requirements of IEC 60998 (all parts), IEC 60999 (all parts) and IEC 60228	76
Annex C (informative) Circuit development (19.3)	77
Annex D (informative) Additional requirements for insulation-piercing terminals	78
Annex E (informative) Additional requirements and tests for switches intended to be used at a temperature lower than –5 °C	79
Annex AA (informative) Examples of types of electronic switches or HBES/BACS switches and their functions	84
Annex BB (informative) Circuit development: 19.106 explained	85

Annex CC (normative) Additional requirements for electronic control devices using DLT-technology in accordance with IEC 62756-1	90
Annex DD (informative) Test set-ups	92
Annex EE (informative) Electrical interface specification for phase-cut dimmer in phase-cut dimmed lighting systems.....	99
Annex FF (normative) Requirements for electronic RCS and electronic TDS that provide the function, markings and connection configuration in accordance with IEC 60669-2-2 and IEC 60669-2-3	130
Bibliography.....	135
Figure 101 – Protective separation between circuits	47
Figure 102 – Current path tested in the looping through circuit	72
Figure 103 – Circuit diagram for testing electronic switches and HBES/BACS switches according to 17.101 and 101.4.....	72
Figure 104 – Minimum creepage and clearances on printed circuit boards	73
Figure 105 – Surge test	74
Figure BB.1 – 120 V 15 W (LT spice model).....	86
Figure BB.2 – 230 V 15 W (LT spice model).....	87
Figure BB.3 – Model for multiple lamp loads	88
Figure BB.4 – I_{peak} and I^2t for multiple lamp loads	89
Figure DD.1 – Test setup for AC mains connection according to IEC 61000-4-4.....	92
Figure DD.2 – Test setup for bus and DC mains connection according to IEC 61000-4-4	93
Figure DD.3 – Test setup for AC mains connection according to IEC 61000-4-5.....	94
Figure DD.4 – Test setup for bus and DC mains connection according to IEC 61000-4-5	95
Figure DD.5 – Test setup for the ESD according to IEC 61000-4-2	96
Figure DD.6 – Test setup for AC mains connection according to IEC 61000-4-6.....	97
Figure DD.7 – Test setup for bus and DC mains connection according to IEC 61000-4-6	98
Figure EE.1 – Example of wiring diagram.....	102
Figure EE.2 – Timing leading edge dimming method.....	105
Figure EE.3 – Timing trailing edge dimming method	110
Figure EE.4 – Circuit to test the properties of the phase-cut dimmer during the non-conducting phase (Method 1).....	116
Figure EE.5 – Circuit to test the properties of the phase-cut dimmer during the non-conducting phase (Method 2).....	117
Figure EE.6 – Circuit to test the properties of the phase-cut dimmer during the transition from the non-conducting to the conducting phase	118
Figure EE.7 – Circuit to test the properties of the phase-cut dimmer during the electronic off-state	120
Figure EE.8 – Waveform of AC voltage source – Leading edge.....	121
Figure EE.9 – Waveform of AC voltage source – Trailing edge	121
Figure EE.10 – Equivalent circuit for controlgear in the on state to be used during dimmer tests	122
Figure EE.11 – Equivalent circuit for controlgear being in off state.....	122
Figure EE.12 – Test enclosure	126

Figure EE.13 – Geometry of microphone placement in regard to device under test	126
Figure EE.14 – Test circuit to test stability of phase angle	127
Figure EE.15 – Possibilities for proper triggering	128
Figure EE.16 – Equivalent circuit EC_CG2	129
Table 1 – Number of specimens needed for the tests	16
Table 15 – Test voltage, points of application and minimum values of insulating resistance for the verification of electric strength	29
Table 101 – Permissible temperature rise values	33
Table 102 – Application of tests for making and breaking capacity and normal operation for electronic switches and HBES/BACS switches according to 7.102.2.....	36
Table 103 – Relationship between rated current and capacitance	40
Table 104 – Values for I_{peak} and I^2t depending on the type of distribution system	42
Table 105 – Calculated circuit parameters	43
Table 106 – Test loads for HBES/BACS switches for heating installations	44
Table 23 – Creepage distances, clearances and distances through insulating sealing compound.....	45
Table 107 – Relation between the rated voltage of the HBES/BACS switch, the rated insulation voltage and the rated impulse voltage	48
Table 108 – Minimum clearances without verification test	49
Table 109 – Test voltages and corresponding altitudes	50
Table 110 – Minimum clearances with verification test	50
Table 111 – Minimum creepage distances of basic, supplementary and reinforced insulation without verification test for clearances	51
Table 112 – Minimum creepage distances of basic, supplementary and reinforced insulation with verification test for clearances	51
Table 113 – Immunity tests (overview).....	54
Table 114 – Voltage dip and short-interruption test values	55
Table 115 – Surge immunity test voltages.....	56
Table 116 – Fast transient test values	57
Table 117 – Values for radiated electromagnetic field test of IEC 61000-4-3 ^a	59
Table 118 – Measurement methods	62
Table 119 – Protection methods and test conditions	64
Table 120 – Capacitors	68
Table A.101 – Maximum current and minimum cross-sectional area.....	75
Table E.101 – Energy for impact tests	82
Table AA.1 – Functions overview	84
Table BB.1 – Lamp	85
Table EE.1 – Nominal mains voltage 100 V – Frequency 50 Hz or 60 Hz	106
Table EE.2 – Nominal mains voltage 120 V – Frequency 50 Hz or 60 Hz	106
Table EE.3 – Nominal mains voltage 200 V – Frequency 50 Hz or 60 Hz	106
Table EE.4 – Nominal mains voltage 230 V – Frequency 50 Hz or 60 Hz	106
Table EE.5 – Nominal mains voltage 277 V – Frequency 50 Hz or 60 Hz	106
Table EE.6 – Slew rate for voltage decrease across the phase-cut dimmer.....	107
Table EE.7 – Nominal mains voltage 100 V – Frequency 50 Hz or 60 Hz	108

Table EE.8 – Nominal mains voltage 120 V – Frequency 50 Hz or 60 Hz	108
Table EE.9 – Nominal mains voltage 200 V – Frequency 50 Hz or 60 Hz	108
Table EE.10 – Nominal mains voltage 230 V – Frequency 50 Hz or 60 Hz	108
Table EE.11 – Nominal mains voltage 277 V – Frequency 50 Hz or 60 Hz	109
Table EE.12 – Nominal mains voltage from 100 V to 277 V – Frequency 50 Hz or 60 Hz	111
Table EE.13 – Nominal mains voltage 100 V – Frequency 50 Hz or 60 Hz	112
Table EE.14 – Nominal mains voltage 120 V – Frequency 50 Hz or 60 Hz	112
Table EE.15 – Nominal mains voltage 200 V – Frequency 50 Hz or 60 Hz	112
Table EE.16 – Nominal mains voltage 230 V – Frequency 50 Hz or 60 Hz	113
Table EE.17 – Nominal mains voltage 277 V – Frequency 50 Hz or 60 Hz	113
Table EE.18 – Currents and voltages for controlgear during the electronic off state	114
Table EE.19 – Parameters for testing purposes	115
Table EE.20 – Parameters for testing purposes	124

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SWITCHES FOR HOUSEHOLD AND SIMILAR FIXED ELECTRICAL INSTALLATIONS –

Part 2-1: Particular requirements – Electronic control devices

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60669-2-1 has been prepared by subcommittee 23B: Plugs, socket-outlets and switches, of IEC technical committee 23: Electrical accessories.

This fifth edition cancels and replaces the fourth edition published in 2002, Amendment 1:2008 and Amendment 2:2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) incorporation of the requirements for HBES switches, previously included in IEC 60669-2-5;
- b) modification of 19.106, test and requirements for switches for LEDs;
- c) general indication to cover electronic control devices;
- d) test for looping through.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
23B/XX/FDIS	23B/XX/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

This part of IEC 60669 is to be used in conjunction with IEC 60669-1:2017, hereinafter referred to as Part 1. It lists the changes necessary to convert that standard into a specific standard for electronic control devices.

In this document, the following print types are used:

- requirements proper: in roman type;
- *test specifications: in italic type;*
- notes: in smaller roman type.

Subclauses, figures, tables or notes which are additional to those in Part 1 are numbered starting from 101.

A list of all the parts in the IEC 60669 series, published under the general title *Switches for household and similar fixed electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

SWITCHES FOR HOUSEHOLD AND SIMILAR FIXED ELECTRICAL INSTALLATIONS –

Part 2-1: Particular requirements – Electronic control devices

1 Scope

This clause of Part 1 is completely replaced by the following:

This part of IEC 60669 applies to electronic control devices, a general term to cover electronic switches, home and building electronic systems (HBES) / building automation and control systems (BACS) switches and electronic extension units.

It applies to electronic switches and to HBES/BACS switches, for alternating current (AC) only with a rated switching voltage not exceeding 250 V and a rated current not exceeding 16 A, intended for household and similar fixed electrical installations, either indoors or outdoors.

It also applies to electronic extension units with a rated supply voltage not exceeding 250 V AC and 120 V DC, such as sensors and push buttons.

This document also applies to electronic remote control switches (RCS) and electronic time delay switches (TDS). Particular requirements are given in Annex FF.

Switches including only passive components such as resistors, capacitors, inductors, positive temperature coefficient (PTC) and negative temperature coefficient (NTC) components, varistors, printed wiring boards and connectors are not considered as electronic control devices.

This document also applies to electronic switches and HBES/BACS switches for the operation of lighting equipment circuits and the control of the brightness of lighting equipment (dimmers) as well as the control of the speed of motors (for example, those used in ventilating fans) and for other purposes (for example, heating controls).

The operation and/or control as mentioned above can be transmitted by an electronic signal via several media, for example, powerline (mains), twisted pair, optical fibre, radio frequency, infrared, etc. and are performed:

- intentionally by a person via an actuating member, a key, a card, etc., via a sensing surface or a sensing unit, by means of touch, proximity, turn, optical, acoustic, thermal;
- by physical means, for example, light, temperature, humidity, time, wind velocity, presence of people;
- by any other influence.

This document also applies to electronic control devices which include integrated radio receivers and transmitters.

This document covers only those requirements for mounting boxes which are necessary for the tests on the electronic control devices.

Requirements for general purpose mounting boxes are given in the relevant part, if any, of IEC 60670.

This document is not intended to cover devices falling within the scope of IEC 60730 (all parts).

Electronic control devices complying with this document are suitable for use at ambient temperature not normally exceeding 25 °C but occasionally reaching 35 °C with a lower limit of the ambient air temperature of –5 °C.

NOTE 1 For lower temperatures, see Annex E.

Functional safety aspects are not covered by this document. Functional safety requirements are covered by the standards of the controlled devices.

In locations where special conditions prevail, such as in ships, vehicles and the like and in hazardous locations, for example where explosions are liable to occur, special construction and/or additional requirements may be required.

This document is not intended to cover devices which are designed to be incorporated in appliances or are intended to be delivered together with a specific appliance and which are within the scope of IEC 60730 (all parts) or IEC 61058-1.

Examples of designs of electronic switches and HBES/BACS switches and functions are shown in Annex AA.

Additional requirements for electronic control devices using DLT-technology in accordance with IEC 62756-1 are given in Annex CC.

Electrical interface specification for phase-cut dimmer used in phase-cut dimmed lighting systems are given for information only in Annex EE.

NOTE 2 Electronic switches and HBES/BACS switches without a mechanical switch in the main circuit do not provide a "full off-state". Therefore, the circuit on the load side are to be considered to be live.

2 Normative references

This clause of Part 1 applies except as follows.

Addition:

IEC 60050-845, *International Electrotechnical Vocabulary (IEV) – Part 845: Lighting* (available at www.electropedia.org)

IEC 60068-2-78, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*

IEC 60127 (all parts), *Miniature fuses*

IEC 60317 (all parts), *Specifications for particular types of winding wires*

IEC 60317-0-1:2013, *Specifications for particular types of winding wires – Part 0-1: General requirements – Enamelled round copper wire*

IEC 60384-14:2013, *Fixed capacitors for use in electronic equipment – Part 14: Sectional specification – Fixed capacitors for electromagnetic interference suppression and connection to the supply mains*

IEC 60384-14:2013/AMD1:2016

IEC 60664-1:2020, *Insulation coordination for equipment within low-voltage supply systems – Part 1: Principles, requirements and tests*

IEC 60669-1:2017, *Switches for household and similar fixed electrical installations – Part 1: General requirements*

IEC 60669-2-2:2006, *Switches for household and similar fixed electrical installations – Part 2-2: Particular requirements – Electromagnetic remote-control switches (RCS)*

IEC 60669-2-3:2006, *Switches for household and similar fixed electrical installations – Part 2-3: Particular requirements – Time-delay switches (TDS)*

IEC 60670 (all parts), *Boxes and enclosures for electrical accessories for household and similar fixed electrical installations*

IEC 60704-1, *Household and similar electrical appliances – Test code for the determination of airborne acoustical noise – Part 1: General requirements*

IEC 60715, *Dimensions of low-voltage switchgear and controlgear – Standardized mounting on rails for mechanical support of switchgear, controlgear and accessories*

IEC 60730 (all parts), *Automatic electrical controls*

IEC 60990, *Methods of measurement of touch current and protective conductor current*

IEC 60999-1, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm² up to 35 mm² (included)*

IEC 61000-2-2, *Electromagnetic compatibility (EMC) – Part 2-2: Environment – Compatibility levels for low-frequency conducted disturbances and signaling in public low-voltage power supply systems*

IEC 61000-3-2:2018, *Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)*

IEC 61000-3-3:2013, *Electromagnetic compatibility (EMC) – Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection*
IEC 61000-3-3:2013/AMD1:2017

IEC 61000-4-2, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*

IEC 61000-4-4, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-6, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61000-4-8, *Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques – Power frequency magnetic field immunity test*

IEC 61000-4-11, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests for equipment with input current up to 16 A per phase*

IEC 61000-4-20:2010, *Electromagnetic compatibility (EMC) – Part 4-20: Testing and measurement techniques – Emission and immunity testing in transverse electromagnetic (TEM) waveguides*

IEC 61558-2-6, *Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers*

IEC 61558-2-16, *Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V – Part 2-16: Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units*

IEC 62504, *General lighting – Light emitting diode (LED) products and related equipment – Terms and definitions*

IEC 62756-1, *Digital load side transmission lighting control (DLT) – Part 1: Basic requirements*

IEC/TR 63037:2019, *Electrical interface specifications for self ballasted lamps and controlgear in phase-cut dimmed lighting systems*

IEC 63044-3:2017, *Home and Building Electronic Systems (HBES) and Building Automation and Control Systems (BACS) – Part 3: Electrical safety requirements*

CISPR 14-1:2016, *Electromagnetic compatibility – Requirements for household appliances, electric tools and similar apparatus – Part 1: Emission*

CISPR 15:2018, *Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment*

CISPR 32:2015, *Electromagnetic compatibility of multimedia equipment – Emission requirements*

CISPR 32:2015/AMD1:2019

ISO 306:2013, *Plastics – Thermoplastic materials – Determination of Vicat softening temperature (VST)*

ISO 3741, *Acoustics – Determination of sound power levels and sound energy levels of noise sources using sound pressure – Precision methods for reverberation test rooms*

ISO 3744, *Acoustics – Determination of sound power levels and sound energy levels of noise sources using sound pressure – Engineering methods for an essentially free field over a reflecting plane*