

This is a preview - [click here to buy the full publication](#)



**IEEE**

**IEC/IEEE 60076-57-129**

Edition 1.0 2017-11

# **INTERNATIONAL STANDARD**

---

**Power transformers –  
Part 57-129: Transformers for HVDC applications**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 29.180

ISBN 978-2-8322-4447-0

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Normative references .....	8
2.1 IEC references.....	8
2.2 IEEE references.....	9
3 Terms, definitions and symbols.....	9
3.1 Terms and definitions.....	9
3.2 Symbols.....	10
4 Use of normative references.....	11
5 General requirements .....	11
5.1 General.....	11
5.2 Service conditions.....	11
5.2.1 General .....	11
5.2.2 Temperature.....	11
5.2.3 Load current .....	11
5.2.4 AC voltage.....	11
5.2.5 Direction of power flow .....	11
5.3 Unusual service conditions .....	12
5.4 Loading of transformer above rating.....	12
6 Rating data.....	12
6.1 General.....	12
6.2 Rated voltage .....	12
6.3 Rated current.....	12
6.4 Rated frequency .....	12
6.5 Rated power .....	12
7 Losses.....	13
7.1 General.....	13
7.2 No-load loss.....	13
7.3 Load loss under rated frequency conditions .....	13
7.4 Load loss under service conditions .....	13
7.5 Determination of hot-spot temperature .....	14
8 Test requirements.....	15
8.1 General.....	15
8.1.1 Routine tests .....	15
8.1.2 Type tests.....	15
8.1.3 Special tests.....	15
8.1.4 Commissioning tests.....	15
8.2 Test applicability.....	16
8.2.1 General .....	16
8.2.2 DC withstand voltage test.....	16
8.2.3 Polarity reversal test.....	16
8.2.4 AC applied withstand test for valve side winding(s).....	16
8.3 Dielectric test voltage levels .....	17
8.3.1 Line windings.....	17
8.3.2 Valve windings .....	17
8.4 Induced voltage level with partial discharge measurement .....	18

9	Tests .....	18
9.1	General.....	18
9.1.1	Applicable tests .....	18
9.1.2	Test sequence .....	18
9.1.3	Ambient temperature .....	18
9.1.4	Assembly.....	18
9.1.5	Converter transformers for connection to gas-insulated equipment .....	19
9.2	Load loss and impedance measurements.....	19
9.2.1	General .....	19
9.2.2	Calculation procedure.....	19
9.3	Switching impulse test .....	20
9.4	Applied switching impulse test on the valve side winding .....	20
9.5	Lightning impulse tests .....	20
9.6	DC withstand voltage test .....	20
9.6.1	Applicability .....	20
9.6.2	Transformer test temperature .....	20
9.6.3	Polarity .....	20
9.6.4	Test procedure .....	21
9.6.5	Acceptance criteria .....	21
9.7	Polarity reversal test.....	21
9.7.1	Applicability .....	21
9.7.2	Transformer test temperature .....	21
9.7.3	Test procedure .....	21
9.7.4	Acceptance criteria .....	22
9.8	Extended polarity-reversal test.....	23
9.8.1	Applicability .....	23
9.8.2	Transformer test temperature .....	23
9.8.3	Test procedure .....	23
9.8.4	Acceptance criteria .....	25
9.9	AC applied voltage test for valve side winding(s) .....	25
9.9.1	Test procedure .....	25
9.9.2	Acceptance criteria .....	25
9.10	AC applied voltage test on line side winding(s) .....	25
9.11	AC induced voltage test with partial discharge measurement .....	26
9.11.1	General .....	26
9.11.2	Acceptance criteria .....	26
9.12	Induced voltage test including running of oil pumps .....	26
9.13	Temperature-rise test.....	26
9.13.1	General .....	26
9.13.2	Test procedure .....	27
9.13.3	Tank surface temperature rise measurement .....	28
9.14	Load current test.....	28
9.15	Sound level measurement.....	28
9.16	Insulation power-factor test.....	29
9.17	Winding insulation resistance test.....	29
9.18	Core insulation resistance test.....	29
9.19	Short-circuit test .....	29
9.20	Frequency Response Analysis (FRA) measurements .....	29
9.21	Over-excitation test.....	29

10	Dielectric tests on transformers that have been in service .....	29
11	Sound levels.....	30
11.1	General.....	30
11.2	Determination of service sound levels .....	30
11.3	Guaranteed sound levels .....	30
12	Bushings .....	30
12.1	General.....	30
12.2	Line side winding bushings .....	31
12.3	Valve side winding bushings .....	31
13	Tap-changer.....	31
13.1	General.....	31
13.2	Current wave shape.....	31
13.3	Consecutive operation of tap-changers .....	31
14	High-frequency modelling .....	31
15	Tolerances .....	32
15.1	General.....	32
15.2	Short-circuit impedance tolerances .....	32
16	Rating plate.....	32
Annex A (informative) In service overloading of HVDC converter transformers used with current commutated valves (either mercury arc valves or thyristors).....		34
A.1	General.....	34
A.2	Overloading in service .....	34
A.3	Temperature rise test for demonstrating normal loading condition.....	36
A.4	Temperature rise test for demonstrating planned overload conditions .....	36
Annex B (informative) HVDC converter transformers for use with voltage source converters .....		38
B.1	General.....	38
B.2	Converter transformer stressed with only fundamental voltage and current .....	38
B.3	Converter transformers stressed with direct voltage, fundamental voltage and fundamental current .....	39
B.4	Converter transformer stressed with the valves connected directly to the converter transformer.....	40
B.5	Summary of stresses .....	41
Annex C (informative) Design review .....		42
C.1	General.....	42
C.2	Topics.....	42
Annex D (informative) Transformer specification content .....		44
D.1	General.....	44
D.2	Data to be provided by the purchaser.....	44
D.3	Data to be provided by the manufacturer.....	45
Annex E (informative) Audible sound of converter transformers .....		47
E.1	General.....	47
E.2	Technical reference .....	47
E.3	Current harmonics .....	47
E.4	Voltage harmonics .....	47
E.5	DC bias current.....	48
E.6	Derivation of service sound power levels .....	48
E.7	Sound level guarantee .....	48

Annex F (informative) Determination of transformer service load loss at rated non-sinusoidal converter current from measurements with rated transformer current of fundamental frequency .....	49
F.1 General.....	49
F.2 Alternative method for calculation of the winding eddy loss enhancement factor .....	50
Bibliography.....	52
Figure 1 – Double reversal test voltage profile .....	22
Figure 2 – Extended polarity reversal test alternative 1 .....	24
Figure 3 – Extended polarity reversal test alternative 2.....	24
Figure A.1 – Example of an overload diagram.....	36
Figure B.1 – Configuration with no additional stresses on the converter transformer .....	39
Figure B.2 – Configuration with multi-level VSC HVDC converter station applied in a monopolar scheme with DC overhead line transmission .....	40
Figure B.3 – Configuration with VSC valves connected directly to the converter transformer .....	41
Figure F.1 – Cross-section of a winding strand .....	51
Table 1 – Routine, type and special tests.....	15
Table A.1 – Example of an overload table .....	35

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### POWER TRANSFORMERS –

### Part 57-129: Transformers for HVDC applications

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation.

IEEE Standards documents are developed within IEEE Societies and Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of IEEE and serve without compensation. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards. Use of IEEE Standards documents is wholly voluntary. *IEEE documents are made available for use subject to important notices and legal disclaimers (see <http://standards.ieee.org/IPR/disclaimers.html> for more information).*

IEC collaborates closely with IEEE in accordance with conditions determined by agreement between the two organizations. This Dual Logo International Standard was jointly developed by the IEC and IEEE under the terms of that agreement.

- 2) The formal decisions of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees. The formal decisions of IEEE on technical matters, once consensus within IEEE Societies and Standards Coordinating Committees has been reached, is determined by a balanced ballot of materially interested parties who indicate interest in reviewing the proposed standard. Final approval of the IEEE standards document is given by the IEEE Standards Association (IEEE-SA) Standards Board.
- 3) IEC/IEEE Publications have the form of recommendations for international use and are accepted by IEC National Committees/IEEE Societies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC/IEEE Publications is accurate, IEC or IEEE cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications (including IEC/IEEE Publications) transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC/IEEE Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC and IEEE do not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC and IEEE are not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or IEEE or their directors, employees, servants or agents including individual experts and members of technical committees and IEC National Committees, or volunteers of IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board, for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC/IEEE Publication or any other IEC or IEEE Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that implementation of this IEC/IEEE Publication may require use of material covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. IEC or IEEE shall not be held responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patent Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

IEC/IEEE 60076-57-129:2017

– 7 –

© IEC/IEEE 2017

International Standard IEC/IEEE 60076-57-129 has been prepared by IEC technical committee 14: Power transformers, in cooperation with the Transformers Committee of the IEEE Power & Energy Society<sup>1</sup>, under the IEC/IEEE Dual Logo Agreement.

This publication cancels and replaces the first edition of IEC 61378-2 published in 2001 and IEEE Std C57.129™ published in 2007.

This publication is published as an IEC/IEEE Dual Logo standard.

The text of this standard is based on the following IEC documents:

FDIS	Report on voting
14/904/FDIS	14/907/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

International standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

A list of parts of the 60076 International Standard, published under the general title *Power transformers*, can be found on the IEC website.

The IEC Technical Committee and IEEE Technical Committee have decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

---

<sup>1</sup> A list of IEEE participants can be found at the following URL: [http://standards.ieee.org/downloads/60076/60076-57-129-2017/60076-57-129-2017\\_wg-participants.pdf](http://standards.ieee.org/downloads/60076/60076-57-129-2017/60076-57-129-2017_wg-participants.pdf)

## POWER TRANSFORMERS –

### Part 57-129: Transformers for HVDC applications

#### 1 Scope

This part of 60076 International Standard specifies requirements of liquid-immersed three-phase and single-phase converter transformers for use in high voltage direct current (HVDC) power transmission systems including back-to-back applications. It applies to transformers having two, three or multiple windings.

This document does not apply to

- converter transformers for industrial applications (see IEC 61378-1 or IEEE Std C57.18.10);
- converter transformers for traction applications (see IEC 60310).

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

##### 2.1 IEC references

IEC 60050-421, *International Electrotechnical Vocabulary – Chapter 421: Power transformers and reactors* (available at <http://www.electropedia.org>)

IEC 60076-1:2011, *Power transformers – Part 1: General*

IEC 60076-2, *Power transformers – Part 2: Temperature rise for liquid-immersed transformers*

IEC 60076-3:2013, *Power transformers – Part 3: Insulation levels, dielectric tests and external clearances in air*

IEC 60076-5, *Power transformers – Part 5: Ability to withstand short-circuit*

IEC 60076-18, *Power transformers – Part 18: Measurement of frequency response*

IEC 60076-10, *Power transformers – Part 10: Determination of sound levels*

IEC 60137, *Insulated bushings for alternating voltages above 1 000 V*

IEC 60214-1, *Tap-changers – Part 1: Performance requirements and test methods*

IEC 60270, *High voltage test techniques – Partial discharge measurements*

IEC/IEEE 65700-19-03, *Bushings for DC application*



## **2.2 IEEE references**

IEEE Std C57.12.00™, *IEEE Standard for General Requirements for Liquid-Immersed Distribution, Power, and Regulating Transformers*

IEEE Std C57.12.10™, *IEEE Standard Requirements for Liquid-Immersed Power Transformers*

IEEE Std C57.12.80™, *IEEE Standard Terminology for Power and Distribution Transformers*

IEEE Std C57.12.90™, *IEEE Standard Test Code for Liquid-Immersed Distribution, Power, and Regulating Transformers*

IEEE Std C57.19.00™, *IEEE Standard General Requirements and Test Procedures for Power Apparatus Bushings*

IEEE Std C57.113™, *IEEE Recommended Practice for Partial Discharge Measurement in Liquid-Filled Power Transformers and Shunt Reactors*

IEEE Std C57.131™, *IEEE Standard Requirements for Tap Changers*

IEEE Std C57.149™, *IEEE Guide for the Application and Interpretation of Frequency Response Analysis for Oil-Immersed Transformers*