



TECHNICAL REPORT



**Communication networks and systems for power utility automation –
Part 90-11: Methodologies for modelling of logics for IEC 61850 based
applications**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.200

ISBN 978-2-8322-8785-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	6
INTRODUCTION	8
1 Scope	9
1.1 General	9
1.2 Published versions of this standard and related namespace name	10
1.3 Namespace name and version	10
1.4 Code Component distribution	11
1.4.1 General	11
1.4.2 Data model namespace code component	11
1.4.3 XML schema namespace code component	12
2 Normative references	12
3 Terms and definitions	12
4 Abbreviated terms	13
5 Use cases	13
5.1 General	13
5.2 Use case 1 – Busbar disconnecter coupled in a double busbar arrangement	14
5.3 Use case 2 – Delayed breaker trip and blocking after 1 st low gas pressure alarm	15
5.4 Use case 3 – Bay connected to a busbar	16
5.5 Use case 4 – Definite trip	17
5.6 Use case 5 – "Direct transfer open operation"	18
5.7 Use case 6 – Line outage detection in a breaker and a half scheme	19
5.8 Use case 7 – Unit trip logic	21
5.9 Use case 8 – Data quality management	22
5.10 Use case 9 – Switchgear control on the example of a busbar change-over sequence	24
5.11 Conclusions	25
6 Functional requirements for logic modelling	25
6.1 Performance requirements	25
6.2 Specific management of Common Data Class (CDC) attributes	26
6.2.1 General	26
6.2.2 Quality	26
6.2.3 Time stamp	27
6.3 Switchgear control	27
6.3.1 Variant A: Control commands using control services on CSWI.Pos	27
6.3.2 Variant B: Control commands using GOOSE messages to XCBR/XSWI	28
6.3.3 Variant C: Control commands using GOOSE messages to CSWI	29
6.3.4 Conclusions on switchgear control issued by logics	30
6.3.5 Functional restrictions	31
7 Intended engineering process of logic	32
7.1 General	32
7.2 Management of logic at IED level	34
7.3 Distributed logic management	34
8 Logic modelling	34
8.1 Functional view for logics	34
8.2 Logical node instantiation hosting logic units	36

8.3	Operational modes.....	36
8.4	Logic unit engine execution state	37
8.5	Change of logics IEC 61131 parameters and schemes.....	37
8.6	Variable types and qualifiers	38
8.7	Variable names and binding conventions	38
8.8	Management of data quality attributes.....	39
8.9	Management of time stamp	40
8.10	Substitution model	41
8.11	Management of switchgear controls	42
8.12	Analogue values	42
8.13	Services.....	42
8.14	Initialisation	43
8.15	Standard language to describe the content of a logic unit	43
8.16	Mapping of IEC 61850 data types and IEC 61131-3 / PLCopen XML data types.....	43
8.16.1	General	43
8.16.2	IEC 61850 basic types mapping to IEC 61131-3	43
8.16.3	IEC 61850 Common ACSI Types mapping to IEC 61131-3.....	44
8.16.4	IEC 61850 constructed attribute classes mapping to IEC 61131-3	44
8.16.5	IEC 61850 CDC mapping to IEC 61131-3	46
8.16.6	IEC 61850 logical node data objects mapping to IEC 61131-3	53
8.17	Operators	53
8.18	Logics monitoring, testing and debugging	53
8.19	IEC TR 61850-90-11 data model namespace definition	53
8.19.1	General	53
8.19.2	Abbreviations.....	53
8.19.3	Logical node classes	54
8.19.4	Enumerated data attribute types	57
8.20	IEC TR 61850-90-11 XML namespace definition	58
8.20.1	General	58
8.20.2	XML element	58
9	Conformance testing.....	59
10	Testing of logic functions.....	60
11	Effects on other parts of IEC 61850	60
11.1	IEC 61850-5	60
11.2	IEC 61850-7-4	60
11.3	IEC 61850-6	60
11.4	IEC 61850-10.....	60
Annex A (informative)	Use of SCL extension facilities for Logic Modelling.....	61
Annex B (informative)	PLD example.....	64
B.1	Overview.....	64
B.2	PLD file.....	64
B.3	Use of a logic unit in a GAPC logical node instance	70
Annex C (informative)	Type compatibility for input/blocking references	73
Annex D (informative)	Semantic of name plate attributes	74
Annex E (informative)	Quality behaviour in user-defined logics	75
Annex F (informative)	Proposal of a solution for quality handling	76
F.1	Two ways of engineering logics	76

F.1.1	General	76
F.1.2	Details of the solution "quality handling" and the extensions needed.....	76
F.1.3	Application example for "processed as invalid"	78
F.1.4	Effects on other parts of IEC 61850	78
F.2	SCD including definitions for quality handling.....	78
F.3	Lessons learnt from this exercise	83
Annex G (informative)	Example of an engineering workflow	84
G.1	Workflow of interfacing the logics part (written in IEC 61131) in the IEC 61850 configuration, starting from SCD file	84
G.2	Lessons learnt from this exercise	86
Annex H (informative)	Proposal of a protection against IEC 61131 engineering changes.....	87
Annex I (informative)	Mapping from IEC 61850 CDC to PLCOpen XML.....	88
Bibliography.....		101
Figure 1 – Performance timing concepts		26
Figure 2 – Scheme of variant A.....		28
Figure 3 – Scheme of variant B.....		29
Figure 4 – Scheme of variant C.....		30
Figure 5 – Engineering process for logic based on IEC 61131-3		33
Figure 6 – Functional view of a logical node.....		35
Figure 7 – Logic unit inside a GAPC logical node.....		35
Figure 8 – GAPC logical node instantiation		36
Figure 9 – Binding.....		39
Figure 10 – Management of quality data attributes		40
Figure 11 – Class diagram LogicalNodes_90_11::LogicalNodes_90_11		54
Figure 12 – Class diagram LNGroupG::LNGroupG		55
Figure 13 – Class diagram DOEnums_90_11::DOEnums_90_11.....		57
Figure 14 – UML representation of the IEC TR 61850-90-11 XML namespace		59
Figure B.1 – PLD file hosted in a GAPC LN instance (on the example of use case 5 – Direct transfer open operation)		64
Figure E.1 – Quality behaviour table		75
Table 1 – Tracking information of (Tr)IEC 61850-90-11:2019A namespace building-up.....		7
Table 2 – Reference between published versions of the standard and related namespace name.....		10
Table 3 – Attributes of data model namespace.....		10
Table 4 – Attributes of xsd namespace		11
Table 5 – Use case 1 definition.....		14
Table 6 – Use case 2 definition.....		15
Table 7 – Use case 3 definition.....		16
Table 8 – Use case 4 definition.....		17
Table 9 – Use case 5 definition.....		18
Table 10 – Use case 6 definition.....		20
Table 11 – Use case 7 definition.....		21

Table 12 – Use case 8 definition	22
Table 13 – Example of a quality definition	23
Table 14 – Use case 9 definition	24
Table 15 – Data object definition for control outputs.....	31
Table 16 – Configurations for the control output conditioner.....	31
Table 17 – Data object definition for operational modes	37
Table 18 – PlcOpModeKind enumeration definition	37
Table 19 – Variable types and qualifiers	38
Table 20 – Allowed IEC 61131-3 qualifiers for data variables	38
Table 21 – Data object definition for time stamp calculation	41
Table 22 – CalcTimeAssignmentMethodKind enumeration definition	41
Table 23 – Data object definition for analogue measured values	42
Table 24 – Mapping of basic data types from IEC 61850-7-2.....	43
Table 25 – Mapping of constructed attribute classes from IEC 61850-7-3	44
Table 26 – Mapping of Common Data Classes from IEC 61850-7-3	47
Table 27 – Normative abbreviations for data object names	53
Table 28 – Data objects of GAPCExt	56
Table 29 – Literals of PlcOpModeKind	58
Table 30 – Literals of CalcTimeAssignmentMethodKind	58
Table 31 – SICS Table G.1 – IED configurator conformance statement.....	60
Table C.1 – CDC types for InRef/BlkRef	73
Table D.1 – Semantics of name plate attributes of GAPC LN with Logic unit instances	74
Table F.1 – New CF attributes of DPC	77
Table F.2 – ComBehaviourKind enumeration definition	78
Table F.3 – Configurations for the example.....	78
Table G.1 – Workflow definition	84

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 90-11: Methodologies for modelling of logics for IEC 61850 based applications

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

Technical report IEC 61850-90-11 has been prepared by Technical Committee 57: Power systems management and associated information exchange.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2. This IEC standard includes Code Components i.e. components that are intended to be directly processed by a computer.

Such content is any text found between the markers <CODE BEGINS> and <CODE ENDS>, or otherwise is clearly labelled in this standard as a Code Component.

The purchase of this IEC standard carries a copyright license for the purchaser to sell software containing Code Components from this standard to end users either directly or via distributors, subject to IEC software licensing conditions, which can be found at: <http://www.iec.ch/CCv1>.

Table 1 shows all tracking information of (Tr)IEC 61850-90-11:2019A namespace building-up.

Table 1 – Tracking information of (Tr)IEC 61850-90-11:2019A namespace building-up

Attribute	Content
Namespace IEC specific information	
Version of the UML model used for generating the document (informative)	WG10built7
Date of the UML model used for generating the document (informative)	2020-05-19
Autogeneration software name and version (informative)	j61850DocBuilder 01v03 based on jCleanCim 02v02-NS beta6

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
57/2129A/DTR	57/2211/RVDTR

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This part of IEC 61850, which is a Technical Report, describes the methodologies for the modelling of logics for IEC 61850 based applications. IEC 61850 defines communication networks and systems for power utility automation, and more specifically the communication architecture for subsystems like power system automation systems. The defined architecture in part IEC 61850-7-x provides both a power utility specific data model and a substation domain specific data model with abstract definitions of data objects classes and services independently from the specific protocol stacks, implementations, and operating systems. The mapping of these abstract classes and services to communication stacks is outside the scope of IEC 61850-7-x and can be found in IEC 61850-8-x and in IEC 61850-9-x.

IEC 61850-7-1 gives an overview of the basic communication architecture to be used for all applications in the power utility domain. IEC 61850-7-3 defines common attribute types and common data classes related to all applications in the power system domain. The attributes of the common data classes can be accessed using services defined in IEC 61850-7-2. These common data classes are used in this part to define the compatible data object classes.

To reach interoperability, all data objects in the data model (IEC 61850-7-3, IEC 61850-7-4) need a strong definition with regard to syntax and semantics. The semantics of the data objects is mainly provided by names assigned to common logical nodes defined and data objects they contain, as defined in part IEC 61850-7-4, and dedicated logical nodes defined in domain specific parts like for hydro power control systems (IEC 61850-7-410).

A data object with full semantics is only one of the elements required to achieve interoperability. The standardised access to the data objects is defined in compatible, power utility and domain specific services (see IEC 61850-7-2). Since data objects and services are hosted by intelligent electronic devices (IED), a proper device model is needed also. To describe both the device capabilities and the interaction of the devices in the related system, also a configuration language is needed as defined in part IEC 61850-6 by the System Configuration description Language (SCL).

Besides the application of functions based on predefined logical nodes as given by IEC 61850-7-4 or other domain standards, there is a need to manage project specific logic schemes. These logic schemes define logic operations across logical nodes implementing a function. An increased benefit of IEC 61850 system engineering is the capability of the IEDs to handle such user programmable logics modelled with IEC 61850 concepts. This document provides a standardised methodology to describe and manage logic which is applicable for both on a local function as well as for distributed function logic.

Logics are not limited to functions represented by GAPC class as described in this document. The modelling principles can be applied to all LN classes containing the needed information. Since GAPC class offers the widest flexibility in application, which goes with the usage of logics, this LN class is taken as an example in this document.

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 90-11: Methodologies for modelling of logics for IEC 61850 based applications

1 Scope

1.1 General

This part of IEC 61850, which is a Technical Report, describes the methodologies for the modelling of logics for IEC 61850 based applications in power utility automation. In particular, it describes the functional view of logic based on existing logical nodes for generic process automation and the operational modes of the logic. Furthermore it includes the specification of the standard language to be applied to specific the logic as well as the related data exchange format between engineering tools and their application as well as the mapping of logic elements to IEC 61850 data types.

The examples or use cases given in this document are based on the class model introduced in IEC 61850-7-1 and defined in IEC 61850-7-3. The logical node and data names used in this document are defined in IEC 61850-7-4, the services applied in IEC 61850-7-2. The naming conventions of IEC 61850-7-2 are applied in this document also.

If extensions are needed in the application examples, the normative naming rules for multiple instances and private, compatible extensions of Logical Node (LN) Classes and Data Object Names defined in IEC 61850-7-1 are considered.

This document describes the use of IEC 61850 extensions for modelling logics, therefore it implies some tutorial material. However it is advisable to read IEC 61850-6 and IEC 61850-7-1 in conjunction with IEC 61850-7-3 and IEC 61850-7-2 first and IEC 61131-3 as reference for the programming language of logic.

The different logics included in any IED in an IEC 61850 based system can be classified into two groups:

- **Fixed Logic:** These logics are predefined mostly for critical and complex functions. They are typically included in the IED's defined application, potentially implemented in software, firmware or hardware, and are not modifiable with IEC 61850 tools and services. These logics are implementation specific. Fixed logic is out of the scope of this document.
- **Editable Logic:** These are user configurable / programmable logics which shall be modelled through IEC 61850 configuration tools and be accessible by IEC 61850 services. These logics can be application specific.

The major goal of this document is to adopt the given functionality of an IED to fit to specific application function demands. This is to provide a definition of the methodology for describing and exchanging logics using an IEC 61850 compatible solution. As a benefit the same logic description will be valid and vendor-independent, so it could be used for different IEDs. It is up to the tools to understand this standard description in order to be able to manipulate the logics and to properly configure the IEDs.

Graphical representation of logic is currently out-of-scope of the IEC 61850 series, even if it is part of the PLCopen XML specification. The representation is subject to the engineering tools.

Modelling logics requires some extension of the currently defined data model and / or an extension of the content in the SCL files which is described and which needs to be considered in later editions of IEC 61850-6 and IEC 61850-7-4.

Some examples are included for guidance in Annex B.

1.2 Published versions of this standard and related namespace name

This technical report defines two namespaces:

- An IEC 61850 data model namespace (NSD)
- An SCL schema namespace (SCL)

Table 2 provides an overview of the references between the published versions of this standard and the related namespace names.

Table 2 – Reference between published versions of the standard and related namespace name

Edition	Publication date	Webstore	Namespace NSD	Namespace http://www.iec.ch/61850/2019/SCL/90-11
Edition 1.0	2020-06	IEC TR 61850-90-11:2020	(Tr)IEC 61850-90-11:2019A	2019A2

1.3 Namespace name and version

Table 3 shows all attributes of the data model namespace.

Table 3 – Attributes of data model namespace

Attribute	Content
Namespace nameplate	
Namespace Identifier	(Tr)IEC 61850-90-11
Version	2019
Revision	A
Release	2
Full Namespace Name	(Tr)IEC 61850-90-11:2019A
Namespace Type	transitional
CodeComponentName	NSD
Namespace dependencies	
extends	IEC 61850-7-4 version:2007 revision:B
Namespace transitional status	
Future handling of namespace content	The name space (Tr)IEC 61850-90-11:2019A is considered as "transitional" since the models are expected to be included in further editions IEC 61850-7-4xx. Potential extensions/modifications may happen if/when the models are moved to the International Standard status

Table 4 shows all the attributes of the XML schema namespace

Table 4 – Attributes of xsd namespace

Attribute	Content
Namespace nameplate	
Namespace Identifier (xmlns)	http://www.iec.ch/61850/2019/SCL/90-11
XSD version header attribute	2019A2
Recommended reference name	eIEC61850-90-11SCL
Version	2019
Revision	A
Release	2
CodeComponentName	SCL

1.4 Code Component distribution

1.4.1 General

Each Code Component is a ZIP package containing at least the electronic representation of the Code Component itself and a file describing the content of the package (IECManifest.xml).

The life cycle of a code component is not restricted to the life cycle of the related publication. The publication life cycle goes through two stages, Version (corresponding to an edition) and Revision (corresponding to an amendment). A third publication stage (Release) allows publication of Code Component in case of urgent fixes of InterOp Tissues, thus without need to publish an amendment.

Consequently, new release(s) of the Code Component may be released, which supersede(s) the previous release, and will be distributed through the IEC TC57 web site at:

<http://www.iec.ch/tc57/supportingdocuments>

The latest version/release of the document will be found by selecting the file for the code component with the highest value for VersionStateInfo, e.g. IEC_TR_61850-90-11.NSD.{VersionStateInfo}.light.zip.

1.4.2 Data model namespace code component

The data model code component is an NSD file as specified in IEC 61850-7-7. It will be available in a light and full version:

- The full version contains definition of the whole data model defined in this standard with the documentation associated and access is restricted to purchaser of this part
- The light version does not contain any documentations but contains the whole data model as per full version

The light version is freely accessible on the IEC website for download at:

http://www.iec.ch/tc57/supportingdocuments/IEC_TR_61850-90-11.NSD.2019A2.light.zip.

but the usage remains under the licensing conditions.

In case of any differences between the downloadable code and the IEC pdf published content, the downloadable code(s) is(are) the valid one; it may be subject to updates. See history files.

1.4.3 XML schema namespace code component

The SCL code component namespace is an XML schema file. It will be available in a full version.

The full version is freely accessible on the IEC website for download at:

http://www.iec.ch/tc57/supportingdocuments/IEC_TR_61850-90-11_SCL_2019A2_full.zip

but the usage remains under the licensing conditions.

In case of any differences between the downloadable code and the IEC pdf published content, the downloadable code(s) is(are) the valid one; it may be subject to updates. See history files.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61131-3, *Programmable controllers – Part 3: Programming languages*

IEC TS 61850-1-2, *Communication networks and systems for power utility automation – Part 1-2: Guideline on extending IEC 61850*

IEC 61850-5, *Communication networks and systems for power utility automation – Part 5: Communication requirements for functions and device models*

IEC 61850-6, *Communication networks and systems for power utility automation – Part 6: Configuration description language for communication in electrical substations related to IEDs*

IEC 61850-7-1, *Communication networks and systems for power utility automation – Part 7-1: Basic communication structure – Principles and models*

IEC 61850-7-2, *Communication networks and systems for power utility automation – Part 7-2: Basic information and communication structure – Abstract communication service interface (ACSI)*

IEC 61850-7-3, *Communication networks and systems for power utility automation – Part 7-3: Basic communication structure – Common data classes*

IEC 61850-7-4:2010, *Communication networks and systems for power utility automation – Part 7-4: Basic communication structure – Compatible logical node classes and data object classes*

Extensible Markup Language (XML) 1.0 (Fifth Edition), W3C Recommendation 26 November 2008 (available at <http://www.w3.org/TR/2008/REC-xml-20081126/>)

PLCopen XML, XML formats for IEC 61131-3 (available at <http://www.plcopen.org>)