

This is a preview - click here to buy the full publication



IEC TR 61850-90-13

Edition 1.0 2021-02

TECHNICAL REPORT



**Communication networks and systems for power utility automation –
Part 90-13: Deterministic networking technologies**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.200

ISBN 978-2-8322-9283-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	8
3 Terms and definitions, abbreviated terms and acronyms.....	9
3.1 Terms and definitions.....	9
3.2 Abbreviated terms and acronyms	11
4 Characteristics of determinism.....	13
4.1 Deterministic latency.....	13
4.2 Deterministic jitter	14
5 Problem Statement.....	15
5.1 Overview.....	15
5.2 Problems with existing technologies.....	16
5.3 Improvements in networking communication from using the capabilities of deterministic communication technologies	17
5.4 Drawbacks of deterministic networking	17
5.4.1 General	17
5.4.2 Change in network design	18
5.4.3 Changes to the network infrastructure	18
5.4.4 Change to the network tools	18
5.4.5 Hardware changes to the IEDs	18
5.4.6 Change to the IED applications.....	18
5.4.7 Change to the standard	18
5.4.8 Backward compatibility and transition phase.....	19
5.5 Survey about problem statement.....	19
6 Deterministic networking – support and improvements for existing use cases	19
6.1 Use cases for the LAN	19
6.1.1 Requirements	19
6.1.2 Substation automation	20
6.1.3 WAN-based use cases.....	23
6.1.4 Protection and control for Distributed Energy Resources (DER).....	26
6.1.5 Use cases in which determinism supports non-functional requirements	28
6.2 New use cases (in substation automation and over the WAN)	29
6.2.1 Large control loops	29
6.2.2 Multi-service networks	30
7 Deterministic networking.....	31
7.1 Capabilities and improvements	31
7.1.1 General	31
7.1.2 Time synchronization	31
7.1.3 Quality of service (QoS).....	31
7.1.4 Network configuration and management	32
7.2 Deterministic networking technologies	32
7.2.1 Deterministic HSR	32
7.2.2 IEEE 802.1 Time-sensitive networking (TSN).....	34
7.2.3 IETF DetNet	41
7.2.4 Other technologies	42

8	Co-existence and interoperability with existing and emerging technologies (and how to address technology changes)	47
8.1	Relation of TSN to technologies such as SDN (Software Defined Networking) and NFV (Network Function Virtualization)	47
8.2	Relation and interoperability to existing architectures for high-availability and redundancy based on PRP/HSR	48
8.3	Relation and interoperability to existing WAN-architectures based on MPLS (IP/MPLS, MPLS-TP)	48
8.4	Brownfield deployment options.....	48
8.5	Migration path.....	49
9	Design consideration for a future utility profile using deterministic networking technologies	50
9.1	IEC 61850 traffic patterns and protocols	50
9.2	Non-IEC 61850 traffic patterns and protocols	52
9.3	High-availability and reliability.....	53
9.4	Deterministic traffic classification	53
9.5	Conceptual model	53
9.5.1	General	53
9.5.2	Utility profile considerations using 802.1 TSN technologies	54
9.5.3	Specific IEEE 802.1Q-2018 clauses and related amendments	54
9.5.4	Time synchronization.....	54
10	Harmonization of deterministic networking requirements.....	54
10.1	IEC 61850-5	54
10.2	IEC 61850-9-2	54
10.3	IEC/IEEE 61850-9-3.....	54
10.4	IEC TR 61850-90-1	55
10.5	IEC/TR 61850-90-2.....	55
10.6	IEC TR 61850-90-4	55
10.7	IEC TR 61850-90-12.....	55
11	Impact on application operation	55
11.1	Scope and dependencies	55
11.2	Impact on existing applications	56
11.3	Impact for new applications and application evolution	56
Annex A	(informative) Related work and liaisons.....	57
A.1	IEC/IEEE 60802 TSN-Profile for industrial automation	57
A.2	IEEE 802.24.1 Smart Grid TG	58
A.3	IEC SEG8	58
A.4	Power utility automation and control applications using 5G technology	58
	Bibliography.....	59
	Figure 1 – Delay probability for hard- and soft-real-time system.....	14
	Figure 2 – Low jitter – jitter deterministic delay	15
	Figure 3 – Substation station bus, process bus and traffic example (IEC TR 61850-90-4, Figure 11).....	20
	Figure 4 – Substation with Deterministic Ethernet	21
	Figure 5 – Current differential tele-protection system (IEC TR 61850-90-12:2015)	24
	Figure 6 – Microgrid with renewable generation, storage and grid infeed	26
	Figure 7 – Multi-Service Networks.....	30

Figure 8 – Precise sending in HSR	33
Figure 9 – TSN Components	34
Figure 10 – Fully Distributed Model.....	38
Figure 11 – Hybrid Model.....	39
Figure 12 – Central Model.....	40
Figure 13 – Topology of a WAN network using VSN.....	44
Figure 14 – Frame Structure	45
Figure 15 – Mapping data in a single EtherCAT DLPDU.....	46
Figure 16 – Brownfield configuration options.....	49
Figure 17 – GOOSE protocol time/space chart (Source IEC TR 61850-90-4)	52
Table 1 – Transfer time requirements of IEC 61850-5	19
Table 2 – Station bus communication specifics in today's substations and possible benefits / improvements with TSN	23
Table 3 – Process bus communication specifics in today's substations and possible benefits / improvements with TSN	23
Table 4 – Latency requirements for protection schemes.....	25
Table 5 – IEEE 802.1 Qcc Configuration Models.....	36
Table 6 – DetNet documents.....	42
Table 7 – Traffic type characteristics of IEC 61850 protocols	51
Table 8 – Traffic type characteristics of non-IEC 61850 protocols	53

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 90-13: Deterministic networking technologies

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a Technical Report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 61850-90-13, which is a technical report, has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

The text of this Technical Report is based on the following documents:

Draft TR	Report on voting
57/2236/DTR	57/2301/RVDTR

Full information on the voting for the approval of this Technical Report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61850 series, published under the general title *Communication networks and systems for power utility automation*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Deterministic networking technologies enable applications that require bounded communication delays regardless of network load or reconfiguration. They allow traffic of different time-criticality to share the same physical medium. Deterministic network technologies are based on the pre-allocation of resources using for example scheduling, traffic shaping and the pre-emption of low priority messages to guarantee the timely delivery of high-priority traffic.

Power automation and control is an industry domain where deterministic networking is needed to support existing use cases and applications (requiring real-time communication), and to enable new developments. This networking is currently being provided by SDH networks or dedicated (for protection communications) Ethernet networks; however significant drives (economic and political) are now emerging to use "converged" Ethernet networks.

In this document the term WAN is used for the inter-substation communication networks, with the driving force usually being the desire of a utility to use the same network infrastructure for IT as well as for operational tasks such as inter-substation protection communications.

The term LAN is used for the intra-substation communication networks. Converged networks are those supporting mixed traffic (e.g. process data, configuration management, voice and video surveillance data) in the same network being used for critical power automation applications. In the same way that using public transportation to get from A to B in a timely (deterministic) manner requires the ability to be guaranteed a seat at a particular time, using a communication network for the deterministic delivery of data also requires the guarantee of access at a particular time. This document identifies, describes, and discusses the known technologies to address this determinism issue.

Summary:

Clause 5 describes the problem (with non-deterministic networks);

Clause 6 provides use cases;

Clause 7 lists deterministic networking technologies;

Clause 8 discusses interoperability issues;

Clause 9 suggests changes to the IEC 61850 standards needed to support determinism;

Annex A lists some related works and liaisons.

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 90-13: Deterministic Networking Technologies

1 Scope

This part of IEC 61850, which is a Technical Report, provides information, use cases, and guidance on whether and how to use deterministic networking technologies. Furthermore, this document comprises technology descriptions, provides guidance how to achieve compatibility and interoperability with existing technologies, and lays out migration paths. It will separate the problem statement from the possible solutions.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60834-1:1999, *Teleprotection equipment of power systems – Performance and testing – Part 1: Command systems*

IEC 60870-5-104:2006, *Telecontrol equipment and systems – Part 5-104: Transmission protocols – Network access for IEC 60870-5-101 using standard transport profiles*

IEC/IEEE 61588:2009, *Precision clock synchronization protocol for networked measurement and control systems*

IEC 61850 (all parts), *Communication networks and systems for power utility automation*

IEC 61850-5:2013, *Communication networks and systems for power utility automation – Part 5: Communication requirements for functions and device models*

IEC 61850-6:2009, *Communication networks and systems for power utility automation – Part 6: Configuration description language for communication in electrical substations related to IEDs*

IEC 61850-8-1:2011, *Communication networks and systems for power utility automation – Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3*

IEC 61850-9-2, *Communication networks and systems for power utility automation – Part 9-2: Specific communication service mapping (SCSM) – Sampled values over ISO/IEC 8802-3*

IEC/IEEE 60802, *Time-sensitive networking profile for industrial automation*

IEC/IEEE 61850-9-3-2016, *IEC/IEEE International Standard – Communication networks and systems for power utility automation – Part 9-3: Precision time protocol profile for power utility automation*

IEC TR 61850-90-1:2010, *Communication networks and systems for power utility automation – Part 90-1: Use of IEC 61850 for the communication between substations*

IEC TR 61850-90-2:2016, *Communication networks and systems for power utility automation – Part 90-2: Using IEC 61850 for communication between substations and control centres*

IEC TR 61850-90-4:2020, *Communication networks and systems for power utility automation – Part 90-4: Network engineering guidelines*

IEC TR 61850-90-5:2012, *Communication networks and systems for power utility automation – Part 90-5: Use of IEC 61850 to transmit synchrophasor information according to IEEE C37.118*

IEC TR 61850-90-12:2020, *Communication networks and systems for power utility automation – Part 90-12: Wide area network engineering guidelines*

IEC 62351-7:2017, *Power systems management and associated information exchange – Data and communications security – Part 7: Network and System Management (NSM) data object models*

IEC 62439-3:2016, *Industrial communication networks – High availability automation networks – Part 3: Parallel Redundancy Protocol (PRP) and High-availability Seamless Redundancy (HSR)*

IEEE 802.1AS, *IEEE Standard for Local and Metropolitan Area Networks – Timing and Synchronization for Time-Sensitive Applications*, available at <http://www.ieee.org>

IEEE 802.1Q, *IEEE Standard for Local and metropolitan area networks – Bridges and Bridged Networks*; available at <http://www.ieee.org>

IEEE 802.1Qcc-2018, *IEEE Standard for Local and Metropolitan Area Networks – Bridges and Bridged Networks – Amendment 31: Stream Reservation Protocol (SRP) Enhancements and Performance Improvements*

IEEE 802.3-2018, *IEEE Standard for Ethernet*

IEEE C37.94-2017, *IEEE Standard for N times 64 kbps Optical Fiber Interfaces between Teleprotection and Multiplexer Equipment*

IEEE C37.118.1-2011, *IEEE Standard for Synchrophasor Measurements for Power Systems*