

This is a preview - click here to buy the full publication



IEC TR 63176

Edition 1.0 2019-01

TECHNICAL REPORT

Process analysis technology systems as part of safety instrumented systems

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 13.110; 25.040.40

ISBN 978-2-8322-6407-2

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms, definitions and abbreviated terms	7
3.1 Terms and definitions.....	7
3.2 Abbreviated terms.....	9
4 Qualification process	10
4.1 Overview.....	10
4.2 Recommendation for constructor requirements	12
4.3 Recommendation for plant operator requirements	13
4.4 Basic testing (analyser only)	14
4.5 Engineering	14
4.5.1 General	14
4.5.2 Design data	15
4.5.3 Analyser including application.....	15
4.5.4 Sample conditioning	15
4.5.5 HFT	15
4.5.6 Failure Mode Effects and Diagnosis Analysis of the PAT system (FMEDA)	16
4.5.7 Estimation of the PFD _{PAT} value.....	16
4.5.8 Proven performance – from case to case following prior in-service testing of the PAT system.....	17
4.5.9 Safety logic in the PAT system	17
4.5.10 Sample switching.....	18
4.5.11 Compilation of a plan for periodic inspections during the runtime.....	18
4.6 Commissioning of the safety system	18
4.7 Documentation of the qualification process	18
5 Regular operation	19
5.1 General.....	19
5.2 Periodic testing during runtime.....	19
5.3 Documents and records in operation	19
5.3.1 General	19
5.3.2 Maintenance schedule	19
5.3.3 Working instructions	19
5.3.4 Record of work realised	19
5.3.5 Fault data recording.....	20
5.4 Evaluation of fault data and handling of deviations.....	20
5.5 Modifications.....	20
5.5.1 Modifications to the PAT system	20
5.5.2 Modifications of the process engineering process	20
5.6 Decommissioning and recommissioning	21
5.6.1 Decommissioning	21
5.6.2 Recommissioning	21
5.7 Grandfathering.....	21
Annex A (informative) Basic testing of analysers.....	22
Annex B (informative) FMEDA – documentation of safety assessment (example).....	25

Annex C (informative) PFD – numerical time-discrete determination	26
Bibliography.....	29
Figure 1 – Qualification process levels for a PAT measuring system	12
Figure A.1 – Basic testing process for analysers in SIS	24
Figure B.1 – FMEDA – documentation of safety assessment (example)	25
Table 1 – Minimum HFT requirements according to SIL	16

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PROCESS ANALYSIS TECHNOLOGY SYSTEMS AS PART OF SAFETY INSTRUMENTED SYSTEMS

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 63176, which is a Technical Report, has been prepared by subcommittee 65B: Measurement and control devices, of IEC technical committee 65: Industrial-process measurement, control and automation.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
65B/1111/DTR	65B/1131/RVDTR

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

This Technical Report is designed as a recommendation to aid users of process analyzer technology that measures installations as part of safety instrumented systems and should be treated exclusively as a recommendation. Formulations of a binding character encountered in the recommendation are due to the safety-related content. However, the advisory character of this document is maintained as a whole. Process analyzer technology measuring equipment is used, for example, in the process industry as sensor components of safety instrumented systems. In many cases, they represent the only or most efficient method for monitoring a process variable, which, for its part, enables a reliable evaluation of designated use of the system to be protected. Owing to the direct material interaction with the process medium, process analyzer technology measuring equipment is in general more susceptible to failure and requires more maintenance than the sensors widely used for pressure, temperature, filling level and flow measurement. A consequence of this interaction is the inability to avoid systematic failure completely. This problem is usually countered by checking the measuring equipment at short, regular intervals.

The variety of process analytical measurement variables and methods and, consequently, the comparatively limited number of process analyzer technology measuring devices used in each case for a single, precisely limited, application makes a quantitative evaluation of functional safety in accordance with IEC 61511 difficult in most cases. Beside the often-inadequate specifications of manufacturers for evaluating components as safety instrumented systems, there are an insufficient number of comparable applications. However, several hundred safety instrumented systems have been successfully realized in the last 30 years among the process analyser community using process analyzer technology measuring equipment.

Measures are proposed in areas where normative requirements cannot be fulfilled, or only inadequately. These measures lead to an equivalent level of safety when applied carefully.

Requirements concerning functional safety of electrical and electronic systems are described in IEC 61508, specified for “Safety instrumented systems for the process industry sector” in the sector standard IEC 61511. The aim of this document is to describe a procedure for the use of process analyzer technology measuring devices as part of safety instrumented systems in a guideline.

PROCESS ANALYSIS TECHNOLOGY SYSTEMS AS PART OF SAFETY INSTRUMENTED SYSTEMS

1 Scope

This document encompasses recommendations for planning, installation and operation (incl. maintenance) of process analyzer technology measuring equipment in process industry safety instrumented systems. It covers all necessary steps for the qualification of safety equipment and supplements the safety management of safety instrumented system equipment through the addition of special requirements for process analyzer technology equipment. This document does not encompass the entire safety management of safety instrumented system equipment.

The term “qualification” used in this recommendation refers exclusively to the testing of the suitability of the process analyzer technology system for use in a safety instrumented system device. It is different from the term "qualification" used in the pharmaceutical environment.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61508 (all parts), *Functional safety of electrical/electronic/programmable electronic safety-related systems*

IEC 61508-6:2010, *Functional safety of electrical/electronic/programmable electronic safety-related systems – Part 6: Guidelines on the application of IEC 61508-2 and IEC 61508-3*

IEC 61511 (all parts), *Functional safety – Safety instrumented systems for the process industry sector*

IEC 61511-1:2016, *Functional safety – Safety instrumented systems for the process industry sector – Part 1: Framework, definitions, system, hardware and application programming requirements*

IEC 61326-3-1:2017, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 3-1: Immunity requirements for safety-related systems and for equipment intended to perform safety-related functions (functional safety) – General industrial applications*

IEC 61326-3-2:2017, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 3-2: Immunity requirements for safety-related systems and for equipment intended to perform safety-related functions (functional safety) – Industrial applications with specified electromagnetic environment*