



TECHNICAL SPECIFICATION

**Recommendations for renewable energy and hybrid systems for rural
electrification –
Part 7-3: Generator set – Selection of generator sets for rural electrification
systems**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 27.160

ISBN 978-2-8322-5455-4

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	5
INTRODUCTION	7
1 Scope.....	8
2 Normative references.....	10
3 Terms and definitions.....	11
4 Introduction to generator sets	14
4.1 Generator set system.....	14
4.2 Generator set application in rural electrification systems.....	14
4.2.1 General.....	14
4.2.2 Single generator set (micropower plant Type A).....	14
4.2.3 Multiple generator sets (micropower plant Type B).....	14
4.2.4 Single generator set with a power conditioning sub-system (micropower plant Type C).....	15
4.2.5 Multiple generator sets with multiple power conditioning sub-systems (micropower plant Type D).....	15
4.3 Resource assessment.....	16
5 Selection and erection.....	16
5.1 General	16
5.2 Selection requirements.....	17
5.2.1 Power quality.....	17
5.2.2 Generator set sizing.....	17
5.2.3 Generator set type	18
5.2.4 Derating factors	19
5.2.5 Starting system.....	19
5.2.6 Control systems.....	20
5.2.7 Noise issues.....	20
5.2.8 Environmental issues	20
5.3 Erection.....	21
5.3.1 Shipping	21
5.3.2 Design of the erection site	21
5.3.3 Installation requirements.....	23
6 Safety.....	25
6.1 General	25
6.2 Electrical issues	25
6.2.1 General requirements.....	25
6.2.2 Connection system to the application.....	25
6.2.3 Power cables.....	26
6.2.4 Neutral system	26
6.2.5 Earthing.....	26
6.2.6 Overcurrent protection.....	27
6.2.7 Residual Current Protection Device (RCD)	27
6.2.8 Isolating devices	27
6.3 Mechanical issues	27
6.3.1 Vibration	27
6.3.2 Protection from mechanical damage	27
6.3.3 Protection from moving parts.....	28
6.4 Thermal issues.....	28

6.5	Fire risk	28
7	Acceptance	28
7.1	General	28
7.2	Conformity of the generator set to the identification file	28
7.3	Conformity of the generator set system to the generator set specification (GS).....	28
7.4	Acceptance process.....	28
7.4.1	Preparation of the generator set for commissioning	28
7.4.2	Commissioning inspection of the generator set system	29
7.4.3	Commissioning tests of the generator set system	29
7.4.4	Test file	30
8	Operation and maintenance	30
8.1	Access to the generator set	30
8.2	Operation process	30
8.3	Monitoring.....	31
8.4	Maintenance schedule.....	31
9	Replacement.....	31
10	Marking	32
10.1	General	32
10.2	Generator set.....	32
10.3	Engine.....	32
10.4	Alternator.....	33
10.5	Shutdown apparatus	33
11	Documentation	33
11.1	General	33
11.2	Installation	33
11.3	Operation.....	34
11.4	Inspection and maintenance	34
Annex A	(informative) Generator set classification criteria	35
A.1	General	35
A.2	Functioning mode	35
A.3	Services provided	35
A.4	Application classes	35
A.5	Lifespan	36
A.6	Generator set components design	36
A.6.1	Engine	36
A.6.2	Alternator.....	37
A.6.3	Starting systems	37
A.7	Configuration types.....	37
A.8	Installation modes.....	38
Annex B	(informative) Identification file.....	39
B.1	General	39
B.2	Electrical construction characteristics	39
B.3	Mechanical construction characteristics	39
Annex C	(informative) Maintenance schedule	40
Annex D	(informative) Example of commissioning records sheet.....	41

Figure 2 – Micropower plant Type A: single generator set.....	14
Figure 3 – Micropower plant Type B: multiple generator sets in micropower plant.....	15
Figure 4 – Micropower plant Type C: single generator set with a power conditioning sub-system in micropower plant.....	15
Figure 5 – Micropower plant Type D: Multiple generator sets with multiple power conditioning sub-systems micropower plant.....	16
Table 1 – Examples of derating factors for generator sets.....	19
Table 2 – Generator set permitted noise levels.....	20
Table 3 – Cross-section of power cables.....	26
Table A.1 – Classification of generator set services	35
Table A.2 – Common lifespan values.....	36
Table C.1 – Example of maintenance schedule.....	40

INTERNATIONAL ELECTROTECHNICAL COMMISSION

RECOMMENDATIONS FOR RENEWABLE ENERGY AND HYBRID SYSTEMS FOR RURAL ELECTRIFICATION –

Part 7-3: Generator set – Selection of generator sets for rural electrification systems

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC 62257-7-3, which is a technical specification, has been prepared by IEC technical committee 82: Solar photovoltaic energy systems.

This second edition cancels and replaces the first edition, issued in 2008. It constitutes a technical revision.

The main technical changes with regard to the previous edition are as follows:

- Increased the voltage and power levels to which this TS applies.
- Added descriptions of four different types of micropower systems and their relevant requirements.

This technical specification is to be used in conjunction with other parts of this series or future parts as and when they are published.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
82/1329/DTS	82/1383A/RVDTS

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62257 series, published under the general title: *Recommendations for renewable energy and hybrid systems for rural electrification*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

The IEC 62257 series of documents intends to provide to different players involved in rural electrification projects (such as project implementers, project contractors, project supervisors, installers, etc.) documents for the setting up of renewable energy and hybrid systems with AC voltage below 1 000 V, and DC voltage below 1 500 V.

These documents are recommendations:

- to choose the right system for the right place;
- to design the system;
- to operate and maintain the system.

These documents are focused only on off-grid rural electrification concentrating on, but not specific to, developing countries. They are not considered as all-inclusive to rural electrification. The documents try to promote the use of renewable energies in rural electrification; they do not deal with clean development mechanisms at this time (CO₂ emission, carbon credit, etc.). Further developments in this field could be introduced in future steps.

This consistent set of documents is best considered as a whole with different parts corresponding to items for safety, sustainability of systems and at the lowest life-cycle cost possible. One of the main objectives is to provide the minimum sufficient requirements, relevant to the field of application, that is, renewable energy and hybrid off-grid systems.

RECOMMENDATIONS FOR RENEWABLE ENERGY AND HYBRID SYSTEMS FOR RURAL ELECTRIFICATION –

Part 7-3: Generator set – Selection of generator sets for rural electrification systems

1 Scope

This part of IEC 62257 specifies the general requirements for the selection, sizing, erection and operation of generator sets in decentralized rural electrification systems.

It applies to all low voltage combustion engine electricity generator sets energized by renewable energy such as biomass gasifier or biogas, or fossil fuel such as gasoline or diesel fuel, and designed for supplying electrical power to isolated sites used in systems as described in IEC TS 62257-2.

This document is not an exhaustive resource for the design, installation, operation or maintenance of generator sets, but is more focused on recommendations to provide strategies on selection and criteria which may affect the use of such generation systems in a rural electrification project.

Four cases of micropower plant will be considered as illustrated by Figure 1 to power a collective electrification system (microgrid) or an individual electrification system.

- the micropower plant is composed of one generator set;
- the micropower plant is composed of multiple generator sets, which may have a single energy source or multiple energy sources;
- the micropower plant which is a hybrid energy system between one generator set and a Power Conditioning Sub-system (PCS) which is powered by other energy source including renewable energy source or energy storage;
- the micropower plant which is a hybrid energy system between multiple generator sets and multiple Power Conditioning Sub-systems (PCSs) which are powered by other energy sources including renewable energy sources or energy storage systems.




Figure 1 – General functional configuration of micropower plant in micropower system

The aim of this document is to provide users with the appropriate guide to select generator sets for using in micropower plant with different configurations and levels of reliability and safety of the equipment during its estimated service lifespan.

It describes the minimum requirement of generator set functionality and safety requirements and does not claim to be an exhaustive instruction manual or design specification.

Compliance with this document does not exempt any person, organization or corporation from the responsibility to comply with all other relevant requirements including what is indicated in maker user manuals and local electrical regulations.

This document gives recommendations for the following types of generator sets:

- a) single phase;
- b) three phase;
- c) LV range up to 500 V – 50/60 Hz (see IEC TS 62257-9-2).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60034-1, *Rotating electrical machines – Part 1: Rating and performance*

IEC 60034-9, *Rotating electrical machines – Part 9: Noise limits*

IEC 60034-22, *Rotating electrical machines – Part 22: AC generators for reciprocating internal combustion (RIC) engine driven generating sets*

IEC 60364 (all parts), *Low-voltage electrical installations*

IEC 60529, *Degrees of protection provided by enclosures (IP code)*

IEC 61009-1, *Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs) – Part 1: General rules*

IEC TS 62257-2:2015, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 2: From requirements to a range of electrification systems*

IEC TS 62257-5, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 5: Protection against electrical hazards*

IEC TS 62257-6, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 6: Acceptance, operation, maintenance and replacement*

IEC TS 62257-9-2, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 9-2: Microgrid*

IEC TS 62257-9-4, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 9-4: Integrated systems – User installation*

ISO 8528-1, *Reciprocating internal combustion engine driven alternating current generating sets – Part 1: Application, ratings and performance*

ISO 8528-5, *Reciprocating internal combustion engine driven alternating current generating sets – Part 5: Generating sets*

ISO 8528-7, *Reciprocating internal combustion engine driven alternating current generating sets – Part 7: Technical declarations for specification and design*