

This is a preview - click here to buy the full publication



IEC TS 63042-201

Edition 1.0 2018-12

# TECHNICAL SPECIFICATION



---

**UHV AC transmission systems –  
Part 201: UHV AC substation design**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 29.240.01; 29.240.10

ISBN 978-2-8322-6330-3

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Normative references .....	8
3 Terms and definitions .....	9
4 UHV AC substation requirement .....	10
4.1 General requirement.....	10
4.2 System demands .....	10
4.3 Operation and maintenance requirements.....	11
4.4 Construction requirements .....	11
4.5 Site condition.....	11
4.6 Environmental impact.....	12
4.7 Economy.....	12
5 Bus scheme and feeder connection .....	12
5.1 General.....	12
5.2 Scheme at high-voltage side of main transformer.....	13
5.3 Scheme at intermedium-voltage side of main transformer .....	14
5.4 Scheme at low-voltage side of main transformer .....	14
5.5 System neutral earthing mode of a UHV AC substation.....	15
6 Selection of equipment and conductors .....	16
6.1 General.....	16
6.1.1 Voltage.....	16
6.1.2 Rated current.....	16
6.1.3 Rated frequency .....	16
6.2 Basic requirements .....	16
6.2.1 Electrical requirements .....	16
6.2.2 Mechanical requirements.....	17
6.2.3 Environmental conditions.....	17
6.3 Transformer .....	18
6.4 UHV shunt reactor and neutral-earthing reactor .....	19
6.5 UHV switchgear .....	19
6.6 UHV circuit breaker.....	20
6.7 UHV disconnecter .....	20
6.8 UHV earthing switch for maintenance .....	21
6.9 High-speed earthing switch .....	22
6.10 UHV current transformer .....	22
6.11 UHV voltage transformer.....	22
6.12 UHV surge arrester.....	23
6.13 Reactive power compensation device for low voltage side of UHV transformer .....	23
6.14 UHV bushing.....	23
6.15 UHV insulator .....	24
6.16 UHV conductor.....	24
6.16.1 General .....	24
6.16.2 Conductor type .....	24
6.16.3 Selection of current-carrying capacity (cross-section).....	25
6.16.4 Corona and radio interference .....	25
6.16.5 Mechanical strength.....	26

7	Equipment layout.....	26
7.1	General requirement of equipment layout.....	26
7.1.1	General .....	26
7.1.2	Optimization of substation layout .....	26
7.1.3	Seismic performance .....	26
7.1.4	Construction, serviceability and reliability and failure response ability.....	26
7.2	Minimum clearances .....	27
7.2.1	Normal environmental conditions .....	27
7.2.2	Minimum clearances in air-voltage range .....	27
7.3	Electromagnetic environment.....	27
7.3.1	Electrostatic induction mitigation design .....	27
7.3.2	Magnetic induction mitigation design .....	28
7.3.3	Audible noise mitigation design .....	28
7.4	Selection of switchgear equipment.....	29
7.5	Switchgear Installations layout.....	29
7.5.1	General .....	29
7.5.2	Location arrangement of switchgear .....	29
7.5.3	Basic arrangement of surge arresters .....	30
7.5.4	Optimal gas-insulated busbar (GIB) layout and length .....	30
7.5.5	Utilization of working space for substations .....	30
7.6	Protection against direct lightning strike.....	31
7.7	Earthing systems .....	31
7.7.1	General considerations .....	31
7.7.2	Multiple point earthing method for GIS .....	32
7.8	Seismic design.....	33
7.8.1	General .....	33
7.8.2	Basic seismic design .....	33
7.8.3	Special seismic performance for UHV AC substation equipment .....	34
8	Control, protection and communication.....	35
8.1	General.....	35
8.2	Control system.....	35
8.3	Relay protection.....	36
8.3.1	General .....	36
8.3.2	Duplicated configuration of UHV AC equipment relay protection .....	36
8.3.3	UHV transformer protection .....	36
8.4	Communication .....	37
8.5	Electromagnetic compatibility requirements for control and protection equipment.....	37
9	DC and AC auxiliary power supply system.....	38
9.1	General.....	38
9.2	DC power supply system.....	38
9.3	AC auxiliary power supply system.....	38
9.4	AC uninterruptible power supply (UPS) system .....	39
10	UHV gantry, support and foundation design.....	39
10.1	UHV gantry and support design .....	39
10.1.1	General .....	39
10.1.2	Load and combination of loads .....	39
10.1.3	Detailing requirements.....	40
10.2	GIS or MTS foundation design .....	41

Annex A (informative) Load combination of UHV AC equipment .....	43
Annex B (informative) Specification of UHV AC equipment and conductor .....	44
Annex C (informative) 1 000 kV outdoor overhead flexible conductor for UHV AC substations in China .....	46
C.1 General.....	46
C.2 Environmental conditions .....	46
C.3 Current-carrying capacity and thermal stability check.....	46
C.3.1 Current-carrying capacity check.....	46
C.3.2 Thermal stability check .....	47
C.4 Determination of bundle spacing .....	48
C.4.1 General .....	48
C.4.2 Calculation of maximum electric field strength around conductor .....	48
C.5 Corona inception voltage .....	49
C.6 Electric field strength on ground caused by electrostatic induction .....	50
Annex D (informative) Corona noise reduction measures of a UHV AC substation conductor under the rainy condition in Japan .....	52
D.1 Basic concept of corona noise reduction .....	52
D.2 Structure design of UHV AC substation conductor .....	52
D.3 Design criteria of partial discharge on UHV AC substation conductor .....	54
D.4 Corona noise measurement of the entrance in UHV AC test station .....	54
Annex E (informative) Typical examples of items to be considered to select switchgear type .....	56
Annex F (informative) Standards related to seismic design .....	58
F.1 Typical seismic guide and standards.....	58
F.2 Comparison of main items among the seismic standards .....	58
Bibliography.....	59
Figure 1 – Birds eye view of a typical UHV AC substation .....	10
Figure 2 – Double busbar (DB) with or without bus section connection.....	13
Figure 3 – One-and-a-half circuit breaker (OHCB) .....	14
Figure 4 – Two-circuit breaker (2CB) .....	14
Figure 5 – Example diagram of a bus scheme and feeder connection .....	15
Figure 6 – Typical configuration of UHV gas-insulated switchgear and crane location .....	31
Figure 7 – Earthing methods .....	33
Figure 8 – Flow chart for seismic qualification.....	34
Figure 9 – Example of continuous UHV gantry and independent gantry.....	41
Figure 10 – GIS foundation forms .....	42
Figure C.1 – Relationship between maximum electric field strength and bundle spacing .....	49
Figure C.1 – Layout plan of main transformer incoming lines .....	51
Figure D.1 – Conductor design of UHV AC substation.....	53
Table 1 – Comparison of a four-legged reactor and HSES .....	22
Table 2 – Comparison of conductors.....	25
Table A.1 – Example of load combination for UHV AC equipment .....	43
Table B.1 – UHV voltage specification .....	44
Table B.2 – Specification of UHV short-circuit current.....	44

Table B.3 – Noise specification .....	44
Table B.4 – Surge arrester specification applied in different countries .....	45
Table C.1 – Current-carrying capacity of bundle conductor .....	47
Table C.2 – Corona inception voltage of conductor .....	50
Table D.1 – Estimated values of corona noise of UHV AC transmission line.....	53
Table D.2 – Design criteria of partial discharge on UHV AC substation conductor .....	54
Table D.3 – Results of corona noise measurements and average value of corona noise .....	55
Table E.1 – The principal technology designs for substations (CIGRE TB 570) .....	56
Table E.2 – Typical examples of items to be considered to select switchgear type .....	57
Table F.1 – Typical seismic guide and standards .....	58
Table F.2 – Comparison of main items among seismic standards.....	58

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### UHV AC TRANSMISSION SYSTEMS –

### Part 201: UHV AC substation design

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC TS 63042-201, which is a technical specification, has been prepared by IEC technical committee 122: UHV AC transmission systems.

The text of this Technical Specification is based on the following documents:

Enquiry draft	Report on voting
122/64/DTS	122/71A/RVDTS

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 63042 series, published under the general title *UHV AC transmission systems*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## UHV AC TRANSMISSION SYSTEMS –

### Part 201: UHV AC substation design

#### 1 Scope

This part of 63042, which is a Technical Specification, provides common rules for the design of substations with the highest voltages of AC transmission systems exceeding 800 kV, so as to provide safety and proper functioning for the intended use.

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2009, *IEC standard voltages*

IEC 60044 (all parts), *Instrument transformers*

IEC 60059:1999, *IEC standard current ratings*  
IEC 60059:1999/AMD1:2009

IEC 60071-1:2006, *Insulation co-ordination – Part 1: Definitions, principles and rules*  
IEC 60071-1:2006/AMD1:2010

IEC 60071-2, *Insulation co-ordination – Part 2: Application guide*

IEC 60076 (all parts), *Power transformers*

IEC 60068-3-3, *Environmental testing – Part 3: Guidance – Seismic test methods for equipments*

IEC 60137, *Insulated bushings for alternating voltages above 1000 V*

IEC 60168, *Tests on indoor and outdoor post insulators of ceramic material or glass for systems with nominal voltages greater than 1000 V*

IEC 60196:2009, *IEC standard frequencies*

IEC 60255-26, *Measuring relays and protection equipment – Part 26: Electromagnetic compatibility requirements*

IEC TS 60479-1, *Effects of current on human beings and livestock – Part 1: General aspects*

IEC 60721-2-4, *Classification of environmental conditions – Part 2-4: Environmental conditions appearing in nature – Solar radiation and temperature*

IEC TS 60815 (all parts), *Selection and dimensioning of high-voltage insulators intended for use in polluted conditions*

IEC 60865 (all parts), *Short-circuit currents*



IEC TS 63042-201:2018 © IEC 2018 – 9 –

IEC 60871 (all parts), *Shunt capacitors for a.c. power systems having a rated voltage above 1 000 V*

IEC 60909 (all parts), *Short-circuit currents in three-phase a.c. systems*

IEC TS 61463, *Bushings – Seismic qualification*

IEC 61850 (all parts), *Communication networks and systems for power utility automation*

IEC 61936-1:2010, *Power installations exceeding 1 kV a.c. – Part 1: Common rules*  
IEC 61936-1:2010/AMD1:2014

IEC 62231, *Composite station post insulators for substations with AC voltages greater than 1 000 V up to 245 kV – Definitions, test methods and acceptance criteria*

IEC 62271-100, *High-voltage switchgear and controlgear – Part 100: Alternating current circuit-breakers*

IEC 62271-102, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62271-207, *High-voltage switchgear and controlgear – Part 207: Seismic qualification for gas-insulated switchgear assemblies for rated voltages above 52 kV*

IEC TR 62271-300, *High-voltage switchgear and controlgear – Part 300: Seismic qualification of alternating current circuit-breakers*