

TECHNICAL REPORT – TYPE 2

ISO/IEC TR 14543-4

First edition
2002-05

**Information technology –
Home electronic system (HES) architecture –**

**Part 4:
Home and building automation in a mixed-use
building**

© ISO/IEC 2002

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

ISO/IEC Copyright Office • Case postale 56 • CH-1211 Genève 20 • Switzerland



PRICE CODE

G

For price, see current catalogue

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Definitions.....	6
3 Relationship between home and building control.....	7
3.1 Control systems for a mixed-use building.....	7
3.2 Application interaction.....	8
3.2.1 Physical architecture.....	8
3.2.2 Logical architecture.....	10
3.2.3 Messages among application domains.....	15
4 Interconnected building and home systems.....	16
4.1 Linking building and home control.....	16
4.2 Network interface capabilities.....	16
4.3 An integrated control system.....	16
Figure 1 – Automation network spanning multiple media.....	9
Figure 2 – Physical components comprising application domains.....	10
Figure 3 – An application domain with application control.....	11
Figure 4 – Logical architecture of an HES application domain.....	11
Figure 5 – Interconnecting application domains as peers.....	12
Figure 6 – Interconnecting applications via an application co-ordinator.....	13
Figure 7 – Example of a distributed application domain.....	13
Figure 8 – Logical Representation of Example in Figure 7.....	14
Figure 9 – Multiple application domains with distributed control.....	15
Figure 10 – Physical integration of building services control as a controller based system.....	17
Figure 11 – Physical Integration of building services control as a fully distributed system.....	18

INFORMATION TECHNOLOGY – HOME ELECTRONIC SYSTEM (HES) ARCHITECTURE

Part 4: Home and building automation in a mixed-use building

FOREWORD

- 1) ISO (International Organization for Standardization) and IEC (International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards through technical committees established by the respective organization to deal with particular fields of technical activity. ISO and IEC technical committees collaborate in fields of mutual interest. Other international organizations, governmental and non-governmental, in liaison with ISO and IEC, also take part in the work.
- 2) In the field of information technology, ISO and IEC have established a joint technical committee, ISO/IEC JTC 1. Draft International Standards adopted by the joint technical committee are circulated to national bodies for voting. Publication as an International Standard requires approval by at least 75 % of the national bodies casting a vote.
- 3) Attention is drawn to the possibility that some of the elements of this Technical Report may be the subject of patent rights. ISO and IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC and ISO technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical report of one of the following types:

- type 1, when the required support cannot be obtained for the publication of an International Standard, despite repeated efforts;
- type 2, when the subject is still under technical development or where, for any other reason, there is the future but not immediate possibility of an agreement on an International Standard;
- type 3, when the technical committee has collected data of a different kind from that which is normally published as an International Standard, for example 'state of the art'.

Technical reports of types 1 and 2 are subject to review within three years of publication to decide whether they can be transformed into International Standards. Technical reports of type 3 do not necessarily have to be reviewed until the data they provide are considered to be no longer valid or useful.

ISO/IEC TR 14543-4, which is a technical report of type 2, was prepared by subcommittee 25: Interconnection of information technology equipment, of ISO/IEC joint technical committee 1: Information technology.

This publication was drafted in accordance with the ISO/IEC Directives, Part 2.

This document is issued in the type 2 technical report series of publications (according to 15.2.2 of the Procedures for the technical work of ISO/IEC JTC 1 (1998)) as a prospective standard for provisional application in the field of the Home Electronic System (HES), because there is an urgent requirement for guidance on how standards in this field should be used.

This document is not to be regarded as an International Standard. It is proposed for provisional application so that information and experience of its use in practice may be gathered. Comments on the content of this document should be sent to IEC Central Office.

A review of this type 2 technical report will be carried out not later than three years after its publication with the option of extension for a further three years of either conversion into an International Standard or withdrawal.

ISO/IEC TR 14543, *Information technology – Home Electronic system (HES) architecture* consists of four parts:

Part 1: Introduction

Part 2: Device modularity

Part 3: Communication layers

Part 4: Home and building automation in a mixed-use building

INTRODUCTION

This technical report explores the similarities and differences between home and building control systems in an environment where both home and building control interact, namely, a mixed-use residential/commercial building.

A logical model for linking building and home control systems is specified. Models showing the organization of application domains, such as energy management and lighting, are included. The option of managing an application domain with a single application controller versus a Fully Distributed System is considered.

Methods for overall building management are presented. The interaction of building and home control systems requires a demarcation between building manager versus tenant responsibilities, as explained in this document. A method for implementing agreements between building managers and tenants regarding user access to and control of applications via a firewall is specified.

INFORMATION TECHNOLOGY – HOME ELECTRONIC SYSTEM (HES) ARCHITECTURE

Part 4: Home and building automation in a mixed-use building

1 Scope

This part of ISO/IEC 14543 presents methods for overall building management of the home electronic system (HES) architecture. The interaction of building and home control systems requires a demarcation between building manager versus tenant responsibilities. A method for implementing agreements between building managers and tenants regarding user access to and control of applications via a firewall is specified.

This technical report augments series ISO/IEC 14543, the architecture of HES (Home Electronic System), in order to accommodate both home and building automation in a mixed-use building. Both systems may coexist in a building with shops, offices and apartments. Some systems are applicable to the whole building versus the systems which are applicable to individual apartments and offices only. In some cases these systems need to interact.

This technical report proposes a logical model for linking building and home control systems even if the two use different physical arrangements of components. The basic recommendations are:

- allow for distinct and separate building and home automation control systems, possibly supplied by different manufacturers;
- define clear points of connection between building and home control systems;
- limit the number of points of connection between building and home control systems, preferably to one per home system;
- accommodate systems that provide building tenants with user control of local systems. This favors an architecture where products can be designed for the user to override control decisions within parameters agreed with building management. Such actions are exercised by the building automation system and affect local systems. This enhances user safety and user privacy;
- provide seamless links between systems that are based on different architectures, that incorporate different communications protocols, and that may be purchased from different manufacturers.