



# INTERNATIONAL STANDARD

---

**Explosive atmospheres –  
Part 49: Flame arresters – Performance requirements, test methods and limits  
for use**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 13.220.10

ISBN 978-2-8322-8716-3

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references .....	9
3 Terms and definitions .....	9
4 Abbreviated terms and symbols .....	13
5 Hazards and flame arrester classifications.....	14
5.1 Flame transmission classification: deflagration, stable and unstable detonation.....	14
5.2 Flame transmission classification: stabilized burning.....	15
5.3 Index of tests .....	15
6 General requirements .....	16
6.1 Measuring instruments.....	16
6.2 Flow measurement (air) .....	17
6.3 Flame transmission test .....	17
6.3.1 General .....	17
6.3.2 Test mixtures.....	17
7 Specific requirements for static flame arresters .....	19
7.1 Construction requirements for prototype arresters.....	19
7.2 Design series.....	19
7.3 Flame transmission tests .....	20
7.3.1 General .....	20
7.3.2 Deflagration test .....	21
7.3.3 Tests for detonation flame arresters .....	24
7.3.4 Short time burning test .....	30
7.3.5 Endurance burning test.....	33
8 Specific requirements for liquid product detonation flame arresters .....	34
8.1 Liquid seals .....	34
8.2 Foot valves .....	35
8.3 Flame transmission test .....	36
9 Specific requirements for dynamic flame arresters (high velocity vent valves).....	37
9.1 General.....	37
9.2 Flame transmission tests .....	37
9.2.1 Low flow flame transmission test .....	37
9.2.2 Flame transmission test by opening and closing .....	39
9.2.3 Deflagration test .....	40
9.2.4 Endurance burning test.....	40
10 Specific requirements for hydraulic flame arresters.....	41
10.1 Equipment .....	41
10.2 Flame transmission tests .....	41
10.2.1 General .....	41
10.2.2 Short time burning test .....	41
10.2.3 Deflagration test .....	41
10.2.4 Detonation test .....	42
11 Test of flame arresters installed on or within gas conveying equipment .....	44
11.1 General.....	44

11.2	Flame transmission tests .....	44
11.2.1	General .....	44
11.2.2	Test procedure for gas conveying equipment with inlet pressure > 600 hPa .....	46
11.2.3	Test procedure for gas conveying equipment with inlet pressure ≤ 600 hPa .....	47
12	Instructions .....	47
13	Marking .....	48
13.1	Location .....	48
13.2	Flame arrester housing .....	49
13.2.1	General information .....	49
13.2.2	Warning markings .....	49
13.2.3	Examples of marking .....	50
13.3	Flame arrester element .....	51
14	Manufacturing and production .....	51
14.1	Construction .....	51
14.2	Housing .....	51
14.3	Joints .....	51
14.4	Pressure test .....	51
14.5	Leak test .....	52
Annex A (normative)	Flow measurement .....	53
A.1	General .....	53
A.2	In-line flame arresters .....	54
A.3	End-of-line flame arrester .....	54
A.3.1	General .....	54
A.3.2	Special flow measurement for dynamic flame arresters .....	55
A.4	Undamped oscillation tests of dynamic flame arrester (High velocity vent valves) .....	56
Annex B (informative)	Information for selecting flame arresters .....	58
Annex C (informative)	Recommended practice .....	59
Annex D (informative)	Evaluation of test results .....	60
Annex E (normative)	Application .....	62
E.1	General .....	62
E.2	Limits for use for static flame arresters .....	63
E.2.1	In-line flame arrester .....	63
E.2.2	Pre-volume flame arrester .....	63
E.2.3	Detonation flame arrester .....	63
E.2.4	Short time burn flame arrester .....	63
E.3	Limits for use for liquid detonation flame arresters .....	64
E.4	Limits for use for dynamic flame arresters (high velocity vent valves) .....	64
E.5	Limits for use for hydraulic flame arresters .....	64
Annex F (informative)	Significant changes between this document and EN ISO 16852:2016 .....	67
Bibliography	.....	69
Figure 1	– Test apparatus for end-of-line flame arrester for deflagration test .....	21
Figure 2	– Test apparatus for in-line flame arrester for deflagration test .....	22
Figure 3	– Test apparatus for pre-volume flame arrester for deflagration test .....	24

Figure 4 – Test apparatus for detonation flame arrester for detonation without restriction.....	26
Figure 5 – Test apparatus for detonation flame arrester for detonation with restriction .....	28
Figure 6 – Test apparatus for short time burning test .....	31
Figure 7 – Test apparatus for endurance burning test .....	33
Figure 8 – Liquid product detonation flame arrester .....	35
Figure 9 – End-of-line flame arrester incorporating a non-return valve (foot valve).....	35
Figure 10 – Test apparatus for liquid product detonation flame arresters .....	36
Figure 11 – Test apparatus for determining the non-hammering conditions for dynamic flame arresters.....	39
Figure 12 – Test apparatus for hydraulic flame arresters.....	43
Figure 13 – Test apparatus for the flame transmission test of flame arresters installed on or within gas conveying equipment.....	45
Figure 14 – Example of marking plate, burn rating "a".....	50
Figure 15 – Example of marking plate, burn rating "b".....	50
Figure A.1 – Test apparatus for recording the pressure drop/flow rate curve for in-line flame arresters.....	54
Figure A.2 – Test apparatus for recording the pressure drop/flow rate curve for end-of-line flame arresters with or without integrated pressure/vacuum valve .....	56
Figure A.3 – Test apparatus for determining the non-oscillating conditions for dynamic flame arresters.....	57
Figure D.1 – Decision process for stable detonation arrester (DET3 and DET4).....	60
Figure D.2 – Decision process for unstable detonation arrester (DET1 and DET2).....	61
Figure E.1 – Test apparatus for hydraulic flame arresters .....	66
Table 1 – Flame arrester classification for deflagration, stable and unstable detonation.....	15
Table 2 – Summary of tests to be conducted.....	16
Table 3 – Specification of gas-air mixtures for deflagration and detonation tests.....	18
Table 4 – Specification of gas-air mixtures for short time burning tests and burning tests of dynamic flame arresters .....	18
Table 5 – Specification of gas-air or vapour-air mixtures for endurance burning tests of static flame arresters .....	19
Table 6 – Design series .....	20
Table 7 – Ratio $p_{md}/p_{TB}$ .....	27
Table 8 – Number of the individual tests and test parameters for the flame transmission test of flame arresters installed on or within gas conveying equipment with inlet pressures > 600 hPa .....	46
Table 9 – Number of the individual tests and test parameters for the flame transmission test of flame arresters installed on or within gas conveying equipment with inlet pressures ≤ 600 hPa .....	47
Table B.1 – Information for selecting flame arresters .....	58
Table F.1 – Significant changes with respect to EN ISO 16852:2016 .....	67

## EXPLOSIVE ATMOSPHERES –

### Part 49: Flame arresters – Performance requirements, test methods and limits for use

#### FOREWORD

- 1) ISO (the International Organization for Standardization) and IEC (the International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards through technical committees established by the respective organization to deal with particular fields of technical activity. ISO and IEC technical committees collaborate in fields of mutual interest. Other international organizations, governmental and non-governmental, in liaison with ISO and IEC, also take part in the work.
- 2) The formal decisions or agreements of IEC and ISO on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC and ISO National bodies.
- 3) IEC and ISO documents have the form of recommendations for international use and are accepted by IEC and ISO National bodies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC and ISO documents is accurate, IEC and ISO cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC and ISO National bodies undertake to apply IEC and ISO documents transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC and ISO document and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC and ISO do not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC and ISO marks of conformity. IEC and ISO are not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this document.
- 7) No liability shall attach to IEC and ISO or their directors, employees, servants or agents including individual experts and members of its technical committees and IEC and ISO National bodies for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this ISO/IEC document or any other IEC and ISO documents.
- 8) Attention is drawn to the Normative references cited in this document. Use of the referenced publications is indispensable for the correct application of this document.
- 9) IEC and ISO draw attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC and ISO take no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC and ISO had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch> and [www.iso.org/patents](http://www.iso.org/patents). IEC and ISO shall not be held responsible for identifying any or all such patent rights.

ISO/IEC 80079-49 has been prepared by subcommittee 31M: Non-electrical equipment and protective systems for explosive atmospheres, of ISO/IEC joint technical committee 1: Information technology.

This edition cancels and replaces ISO 16852:2016, which has been technically revised. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to ISO 16852:2016:

- a) adaptation of the relevant IEC TC 31 requirements on standards;
- b) modification of the upper limit of the temperature range from 150 °C to 200 °C under the condition that  $T_0$  shall be not larger than 80 % of the auto ignition temperature of the gas-air-mixture;
- c) change of the term "explosion group" to "equipment group" due to editorial requirements in IEC/TC 31;
- d) clarification of the conditions and requirements for flame arresters whose intended operating conditions are outside the atmospheric conditions in 7.3.4 and 7.3.5;

- e) clarification of the requirements on the information for use in Clause 12 f) concerning the burn time;
- f) addition of a permission to the construction requirements both in 7.1 and 14.1 to substitute visual inspection by performing a flow test;
- g) addition of a flow chart for the evaluation of test results as Annex D.

The text of this International Standard is based on the following documents:

Draft	Report on voting
31M/212/FDIS	31M/223/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

A list of all parts in the ISO/IEC 80079 series, published under the general title *Explosive atmospheres*, can be found on the IEC website.

NOTE The following print types are used:

- Words in *italic* font in the text are defined in Clause 3.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs) and [www.iso.org/directives](http://www.iso.org/directives).

## INTRODUCTION

Flame arresters are protective systems fitted to openings of enclosures or to pipe work and are intended to allow fluid flow but prevent flame transmission if a flammable mixture is ignited. They have widely been used for decades in the chemical and oil industry, and a variety of national standards is available. This document was prepared with an aim to establish an international basis by harmonizing and incorporating recent national developments and standards as far as reasonable.

This document addresses performance requirements and test methods, as well as limits for use for flame arresters.

Only the minimum safety requirements for flame arresters to prevent flame transmission are specified.

The hazard identification of common applications found in industry leads to the specification of the test methods. These test methods reflect standard practical situations and, as such, form the heart of this document because they also allow classification of the various types of flame arresters and then determination of the limits of use.

A considerable number of test methods and test conditions had to be taken into account for two main reasons.

- a) Different types of flame arresters are covered with respect to the operating principle (static, hydraulic, liquid, dynamic) and each type clearly needs its specific test set-up and test procedure.
- b) It is necessary to adapt flame arresters to the special conditions of application (gas, installation) because of the conflicting demands of high flame quenching capability and low pressure loss. This situation is completely different from the otherwise similar principle of protection by flameproof enclosure, for example for electrical equipment, where the importance of process gas flow through any gaps is negligible and importance is placed on the flame quenching effect of the gap.

Consequently, in this document, the testing and classification related to Equipment Groups and installation conditions have been subdivided more than is usually the case in other parts of the ISO/IEC 80079 and IEC 60079 series of standards. In particular,

- Equipment Group IIA is subdivided into sub-groups IIA1 and IIA,
- Equipment Group IIB is subdivided into sub-groups IIB1, IIB2, IIB3 and IIB, and
- the type "detonation arrester" is divided into four sub-types, which take into account specific installation situations.

The test conditions lead to the limits for use which are most important for the user. This document specifies this safety relevant information and its dissemination through the manufacturer's written instructions for use and the marking of the flame arresters.

The limits for use are also a link to more general (operational) safety considerations and regulations, which remain the responsibility the user and regulators. Annex B and Annex C offer some guidance on these aspects.

## EXPLOSIVE ATMOSPHERES –

### Part 49: Flame arresters – Performance requirements, test methods and limits for use

#### 1 Scope

This document specifies the requirements for flame arresters that prevent flame transmission when explosive gas-air or vapour-air mixtures are present. It establishes uniform principles for the classification, basic construction and information for use, including the marking of flame arresters, and specifies test methods to verify the safety requirements and determine safe limits of use.

This document is applicable to pressures ranging from 80 kPa to 160 kPa and temperatures ranging from  $-20\text{ °C}$  to  $+200\text{ °C}$ .

NOTE 1 For flame arresters with operational conditions inside the scope, but outside atmospheric conditions, see Annex E.

NOTE 2 In designing and testing flame arresters for operation under conditions other than those specified above, this document can be used as a guide. This document can also be used to design any additional testing related to the specific conditions of use. This is particularly important when high temperatures and pressures are applied. The test mixtures might need to be modified in these cases.

This document does not apply to the following:

- external safety-related measurement and control equipment that might be required to keep the operational conditions within the established safe limits;

NOTE 3 Integrated measurement and control equipment, such as integrated temperature and flame sensors as well as parts which, for example, intentionally melt (retaining pin), burn away (weather hoods) or bend (bimetallic strips), are within the scope of this document.

- flame arresters used for explosive mixtures of vapours and gases, which tend to self-decompose (for example, acetylene) or which are chemically unstable;
- flame arresters used for carbon disulfide, due to its special properties;
- flame arresters whose intended use is for mixtures other than gas-air or vapour-air mixtures (for example, higher oxygen-nitrogen ratio, chlorine as oxidant);
- flame arrester test procedures for reciprocating internal combustion engines;

NOTE 4 Flame arresters for specific applications (e.g. reciprocating internal combustion engines) can use this document as a guide for design but be subject to testing related to their specific use.

- fast acting valves, extinguishing systems and other explosion isolating systems;
- Flame arresters used in gas detectors (those being covered for example, by IEC 60079-29-1 and IEC 62990-1).



## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60079-1, *Explosive atmospheres – Part 1: Equipment protection by flameproof enclosures "d"*

ISO/IEC 80079-34, *Explosive atmospheres – Part 34: Application of quality management systems for Ex Product manufacture*